



# August 1-7, 2016 Chlorine Residuals

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/1/2016	86	14814 Santa Gertrudis Dr.	3.86	3.39
8/1/2016	46	8903 McNorton Rd.	3.15	2.75
8/1/2016	65	726 Westchester Dr.	2.25	1.55
8/1/2016	63	2314 Summers St.	1.38	0.82
8/1/2016	13	1505 6th St.	1.52	0.93
8/1/2016	4	14233 Playa del Rey	3.38	2.84
8/1/2016	15	6130 Parkway Dr.	3.20	2.57
8/1/2016	23	5506 Wooldridge Rd.	3.21	2.63
8/1/2016	29	1601 La Joya St.	2.55	1.83
8/1/2016	52	221 Junior Beck Dr.	2.36	1.82
8/1/2016	96	14926 Windward Dr.	3.46	3.21
8/1/2016	8	1126 Cornerstone Dr.	3.08	2.74
8/1/2016	73	5649 King Trl.	3.00	2.75
8/1/2016	31	4306 Cedar St.	1.60	1.09
8/1/2016	26	225 Eastgate Dr.	1.39	1.07
8/1/2016	87	5226 Northwest Trl.	3.07	2.72
8/1/2016	53	9105 Stock Dr.	1.32	1.02
8/1/2016	61	234 Saratoga Blvd.	2.81	2.42
8/1/2016	60	1346 Calle San Marcos	2.03	1.59
8/2/2016	16	4205 Wildcat Dr.	0.61	0.00
8/2/2016	87	5226 Northwest Trl.	1.14	0.48
8/2/2016	16	4205 Wildcat Dr.	0.99	0.01
8/2/2016	90	11722 Haven Dr.	2.11	1.65
8/2/2016	88	4214 Western Dr.	1.14	0.02
8/2/2016	16	4205 Wildcat Dr.	1.16	0.02
8/2/2016	87	5226 Northwest Trl.	0.40	0.17
8/2/2016	90	11722 Haven Dr.	1.91	0.76
8/2/2016	93	11025 Annaville Rd.	1.36	0.04
8/2/2016	90	11722 Haven Dr.	2.02	1.47
8/2/2016	16	4205 Wildcat Dr.	1.56	0.00
8/2/2016	90	11722 Haven Dr.	1.79	1.31
8/2/2016	87	5226 Northwest Trl.	0.76	0.01
8/2/2016	88	4214 Western Dr.	2.41	0.00
8/2/2016	90	11722 Haven Dr.	1.54	0.83
8/2/2016	89	3814 Castle Ridge Dr.	0.80	0.42
8/2/2016	93	11025 Annaville Rd.	2.00	0.00
8/2/2016	88	4214 Western Dr.	2.35	0.00
8/2/2016	16	4205 Wildcat Dr.	1.92	0.01
8/2/2016	87	5226 Northwest Trl.	1.30	0.01

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/2/2016	16	4205 Wildcat Dr.	2.16	0.00
8/2/2016	89	3814 Castle Ridge Dr.	0.63	0.29
8/2/2016	93	11025 Annaville Rd.	2.04	0.01
8/2/2016	90	11722 Haven Dr.	1.29	0.85
8/2/2016	91	2713 Wind Rock Dr.	1.59	0.06
8/2/2016	86	14814 Santa Gertrudis Dr.	2.26	1.94
8/2/2016	90	11722 Haven Dr.	1.15	0.55
8/2/2016	91	2713 Wind Rock Dr.	1.86	0.06
8/2/2016	89	3814 Castle Ridge Dr.	0.53	0.08
8/2/2016	86	14814 Santa Gertrudis Dr.	0.73	0.01
8/2/2016	87	5226 Northwest Trl.	1.58	0.01
8/2/2016	91	2713 Wind Rock Dr.	2.13	0.00
8/2/2016	90	11722 Haven Dr.	1.35	0.68
8/2/2016	89	3814 Castle Ridge Dr.	0.53	0.14
8/2/2016	92	334 Wildwood Dr.	1.25	0.02
8/2/2016	16	4205 Wildcat Dr.	2.45	0.00
8/2/2016	91	2713 Wind Rock Dr.	2.36	0.00
8/2/2016	90	11722 Haven Dr.	1.46	0.07
8/2/2016	89	3814 Castle Ridge Dr.	0.69	0.00
8/2/2016	87	5226 Northwest Trl.	1.64	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	1.39	0.32
8/2/2016	44	9602 Wilkins Dr.	0.36	0.04
8/2/2016	90	11722 Haven Dr.	1.29	0.09
8/2/2016	87	5226 Northwest Trl.	1.85	0.00
8/2/2016	89	3814 Castle Ridge Dr.	0.79	0.01
8/2/2016	86	14814 Santa Gertrudis Dr.	1.52	0.02
8/2/2016	92	334 Wildwood Dr.	2.31	0.01
8/2/2016	44	9602 Wilkins Dr.	0.51	0.00
8/2/2016	16	4205 Wildcat Dr.	2.62	0.00
8/2/2016	89	3814 Castle Ridge Dr.	1.07	0.04
8/2/2016	90	11722 Haven Dr.	1.37	0.05
8/2/2016	92	334 Wildwood Dr.	2.69	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	1.62	0.00
8/2/2016	87	5226 Northwest Trl.	2.03	0.08
8/2/2016	44	9602 Wilkins Dr.	1.10	0.04
8/2/2016	89	3814 Castle Ridge Dr.	1.16	0.00
8/2/2016	88	4214 Western Dr.	3.07	0.00
8/2/2016	90	11722 Haven Dr.	1.31	0.06
8/2/2016	87	5226 Northwest Trl.	1.99	0.00
8/2/2016	90	11722 Haven Dr.	1.70	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	1.84	0.00
8/2/2016	89	3814 Castle Ridge Dr.	1.46	0.00
8/2/2016	44	9602 Wilkins Dr.	1.48	0.02
8/2/2016	46	8903 McNorton Rd.	1.84	0.00
8/2/2016	87	5226 Northwest Trl.	1.81	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	1.98	0.00
8/2/2016	93	11025 Annaville Rd.	3.07	0.00

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/2/2016	89	3814 Castle Ridge Dr.	1.58	0.00
8/2/2016	44	9602 Wilkins Dr.	1.86	0.00
8/2/2016	91	2713 Wind Rock Dr.	3.08	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	2.06	0.00
8/2/2016	46	8903 McNorton Rd.	2.33	0.00
8/2/2016	89	3814 Castle Ridge Dr.	1.89	0.00
8/2/2016	87	5226 Northwest Trl.	1.96	0.00
8/2/2016	90	11722 Haven Dr.	2.47	0.00
8/2/2016	46	8903 McNorton Rd.	2.49	0.00
8/2/2016	44	9602 Wilkins Dr.	2.18	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	2.10	0.00
8/2/2016	47	8121 Barrogate Dr.	1.24	0.00
8/2/2016	87	5226 Northwest Trl.	2.46	0.00
8/2/2016	89	3814 Castle Ridge Dr.	2.07	0.00
8/2/2016	90	11722 Haven Dr.	2.24	0.00
8/2/2016	44	9602 Wilkins Dr.	2.65	0.00
8/2/2016	89	3814 Castle Ridge Dr.	2.29	0.00
8/2/2016	90	11722 Haven Dr.	2.57	0.00
8/2/2016	87	5226 Northwest Trl.	2.43	0.00
8/2/2016	50	5534 IH 37 Access Rd.	1.04	0.01
8/2/2016	62	5809 Hampshire Rd.	0.92	0.01
8/2/2016	48	1237 Southern Minerals Rd.	2.69	0.03
8/2/2016	53	9105 Stock Dr.	1.58	1.32
8/2/2016	9	1000 International Dr.	1.03	0.08
8/2/2016	49	113 Commerce St.	1.75	0.00
8/2/2016	62	5809 Hampshire Rd.	1.04	0.01
8/2/2016	47	8121 Barrogate Dr.	2.34	0.00
8/2/2016	50	5534 IH 37 Access Rd.	1.22	0.01
8/2/2016	51	249 Gibson Ln.	1.75	0.08
8/2/2016	9	1000 International Dr.	1.02	0.45
8/2/2016	49	113 Commerce St.	1.96	0.00
8/2/2016	62	5809 Hampshire Rd.	1.03	0.03
8/2/2016	47	8121 Barrogate Dr.	2.56	0.00
8/2/2016	9	1000 International Dr.	2.24	0.00
8/2/2016	48	1237 Southern Minerals Rd.	3.28	0.00
8/2/2016	51	249 Gibson Ln.	2.06	0.00
8/2/2016	49	113 Commerce St.	2.11	0.00
8/2/2016	9	1000 International Dr.	2.32	0.00
8/2/2016	53	9105 Stock Dr.	2.42	0.00
8/2/2016	50	5534 IH 37 Access Rd.	0.93	0.00
8/2/2016	51	249 Gibson Ln.	2.21	0.00
8/2/2016	61	234 Saratoga Blvd.	1.83	0.00
8/2/2016	49	113 Commerce St.	2.16	0.00
8/2/2016	62	5809 Hampshire Rd.	1.98	0.00
8/2/2016	52	221 Junior Beck Dr.	0.93	0.65
8/2/2016	46	8903 McNorton Rd.	3.06	0.00
8/2/2016	89	3814 Castle Ridge Dr.	2.79	0.00

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/2/2016	50	5534 IH 37 Access Rd.	1.23	0.02
8/2/2016	92	334 Wildwood Dr.	3.09	0.00
8/2/2016	61	234 Saratoga Blvd.	2.25	0.00
8/2/2016	87	5226 Northwest Trl.	2.70	0.00
8/2/2016	62	5809 Hampshire Rd.	2.23	0.00
8/2/2016	90	11722 Haven Dr.	2.51	0.00
8/2/2016	61	234 Saratoga Blvd.	2.10	0.00
8/2/2016	44	9602 Wilkins Dr.	2.80	0.00
8/2/2016	62	5809 Hampshire Rd.	2.22	0.03
8/2/2016	52	221 Junior Beck Dr.	0.35	0.08
8/2/2016	47	8121 Barrogate Dr.	2.73	0.00
8/2/2016	86	14814 Santa Gertrudis Dr.	2.00	0
8/2/2016	50	5534 IH 37 Access Rd.	1.81	0.03
8/2/2016	65	726 Westchester Dr.	0.79	0.52
8/2/2016	29	1601 La Joya St.	2.13	0
8/2/2016	60	1346 Calle San Marcos	1.30	0.97
8/2/2016	29	1601 La Joya St.	2.25	0
8/2/2016	65	726 Westchester Dr.	1.65	0
8/2/2016	25	4101 Bascule Dr.	0.72	0
8/2/2016	50	5534 IH 37 Access Rd.	1.72	0
8/2/2016	52	221 Junior Beck Dr.	0.76	0.39
8/2/2016	1	4810 Neptune St.	2.32	0
8/2/2016	60	1346 Calle San Marcos	1.00	0.67
8/2/2016	25	4101 Bascule Dr.	0.72	0
8/2/2016	65	726 Westchester Dr.	2.85	0
8/2/2016	1	4810 Neptune St.	2.25	0
8/2/2016	65	726 Westchester Dr.	2.96	0
8/2/2016	60	1346 Calle San Marcos	0.84	0.51
8/2/2016	25	4101 Bascule Dr.	0.80	0
8/2/2016	50	5534 IH 37 Access Rd.	2.22	0.02
8/2/2016	25	4101 Bascule Dr.	0.91	0
8/2/2016	60	1346 Calle San Marcos	0.49	0.15
8/2/2016	50	5534 IH 37 Access Rd.	2.13	0.01
8/2/2016	52	221 Junior Beck Dr.	0.99	0.76
8/2/2016	53	9105 Stock Dr.	2.20	0
8/2/2016	12	2219 Buford Ave.	1.87	0
8/2/2016	63	2314 Summers St.	1.43	0
8/3/2016	29	1601 La Joya St.	2.34	0.61
8/3/2016	29	1601 La Joya St.	2.21	0
8/3/2016	9	1000 International Dr.	2.22	0
8/3/2016	52	221 Junior Beck Dr.	2.34	0
8/3/2016	53	9105 Stock Dr.	2.04	0
8/3/2016	18	902 Nueces Bay Blvd.	2.62	0.08
8/3/2016	52	221 Junior Beck Dr.	2.36	0
8/3/2016	49	113 Commerce St.	2.07	0
8/3/2016	18	902 Nueces Bay Blvd.	2.77	0.01
8/3/2016	25	4101 Bascule Dr.	2.70	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/3/2016	48	1237 Southern Minerals Rd.	3.34	0
8/3/2016	25	4101 Bascule Dr.	2.60	0
8/3/2016	64	4013 Hidalgo St.	2.50	0
8/3/2016	62	5809 Hampshire Rd.	3.05	0
8/3/2016	26	225 Eastgate Dr.	1.08	0
8/3/2016	19	1301 Horne Rd.	2.36	0
8/3/2016	64	4013 Hidalgo St.	2.52	0
8/3/2016	50	5534 IH 37 Access Rd.	2.77	0
8/3/2016	63	2314 Summers St.	1.02	0.04
8/3/2016	65	726 Westchester Dr.	2.58	0
8/3/2016	60	1346 Calle San Marcos	1.84	0.02
8/3/2016	19	1301 Horne Rd.	2.23	0.01
8/3/2016	26	225 Eastgate Dr.	0.86	0
8/3/2016	28	1718 Bois d' Arc Pl.	2.29	0.02
8/3/2016	1	4810 Neptune St.	2.64	0
8/3/2016	60	1346 Calle San Marcos	1.94	0
8/3/2016	51	249 Gibson Ln.	2.22	0
8/3/2016	28	1718 Bois d' Arc Pl.	2.31	0
8/3/2016	27	2823 S Port Ave.	2.60	0.01
8/3/2016	63	2314 Summers St.	1.40	0.04
8/3/2016	61	234 Saratoga Blvd.	2.29	0
8/3/2016	60	1346 Calle San Marcos	1.80	0.01
8/3/2016	27	2823 S Port Ave.	2.13	0.04
8/3/2016	57	1409 Arlington Dr.	2.52	0
8/3/2016	18	902 Nueces Bay Blvd.	2.91	0
8/3/2016	57	1409 Arlington Dr.	2.52	0
8/3/2016	60	1346 Calle San Marcos	1.70	0.02
8/3/2016	12	2219 Buford Ave.	1.81	0
8/3/2016	26	225 Eastgate Dr.	1.41	0
8/3/2016	60	1346 Calle San Marcos	2.13	0.01
8/3/2016	68	5322 Alejandro St.	2.63	0
8/3/2016	60	1346 Calle San Marcos	2.02	0.03
8/3/2016	54	510 St. Charles St.	0.94	0.01
8/3/2016	68	5322 Alejandro St.	2.22	0
8/3/2016	60	1346 Calle San Marcos	1.86	0
8/3/2016	26	225 Eastgate Dr.	1.79	0
8/3/2016	28	1718 Bois d' Arc Pl.	2.49	0
8/3/2016	28	1718 Bois d' Arc Pl.	2.65	0
8/3/2016	12	2219 Buford Ave.	2.03	0
8/3/2016	63	2314 Summers St.	1.45	0
8/3/2016	22	6713 Weber Rd.	2.01	0
8/3/2016	55	514 Belden St.	1.62	0
8/3/2016	12	2219 Buford Ave.	1.98	0
8/3/2016	26	225 Eastgate Dr.	1.84	0
8/3/2016	5	4609 Evelyn St.	2.10	0.04
8/3/2016	22	6713 Weber Rd.	2.02	0.01
8/3/2016	67	509 S. Carancahua St.	1.71	0.03

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/3/2016	12	2219 Buford Ave.	2.08	0
8/3/2016	5	4609 Evelyn St.	1.08	0.05
8/3/2016	56	202 Amistad St.	1.66	0.03
8/3/2016	14	922 Rosedale Dr.	2.01	0.01
8/3/2016	10	3146 Saratoga Blvd.	1.97	0
8/3/2016	55	514 Belden St.	1.79	0
8/3/2016	63	2314 Summers St.	1.68	0
8/3/2016	5	4609 Evelyn St.	1.87	0.09
8/3/2016	73	5649 King Trl.	1.83	0
8/3/2016	10	3146 Saratoga Blvd.	1.93	0
8/3/2016	6	1213 10th St.	1.21	0
8/3/2016	14	922 Rosedale Dr.	1.72	0.01
8/3/2016	67	509 S. Carancahua St.	1.86	0
8/3/2016	26	225 Eastgate Dr.	1.87	0
8/3/2016	66	635 Southern St.	1.93	0.02
8/3/2016	5	4609 Evelyn St.	1.81	0.01
8/3/2016	38	7525 Annemasse St.	0.50	0
8/3/2016	6	1213 10th St.	1.92	0
8/3/2016	10	3146 Saratoga Blvd.	1.80	0
8/3/2016	63	2314 Summers St.	1.87	
8/3/2016	56	202 Amistad St.	1.78	0.04
8/3/2016	5	4609 Evelyn St.	2.11	0.03
8/3/2016	55	514 Belden St.	1.92	0.01
8/3/2016	26	225 Eastgate Dr.	2.02	0.07
8/3/2016	6	1213 10th St.	1.99	0
8/3/2016	14	922 Rosedale Dr.	2.08	0
8/3/2016	66	635 Southern St.	2.16	0.01
8/3/2016	38	7525 Annemasse St.	0.51	0
8/3/2016	10	3146 Saratoga Blvd.	1.96	0
8/3/2016	26	225 Eastgate Dr.	2.01	1.94
8/3/2016	32	4901 Hakei Dr.	1.57	0.02
8/3/2016	67	509 S. Carancahua St.	1.80	0.01
8/3/2016	6	1213 10th St.	2.15	0
8/3/2016	73	5649 King Trl.	1.99	0
8/3/2016	20	3901 Cott St.	2.22	0
8/3/2016	66	635 Southern St.	2.17	0.07
8/3/2016	10	3146 Saratoga Blvd.	1.96	0
8/3/2016	14	922 Rosedale Dr.	2.06	0
8/3/2016	32	4901 Hakei Dr.	1.49	0
8/3/2016	78	7602 Timber Crest Dr.	0.52	0.29
8/3/2016	32	4901 Hakei Dr.	1.49	0
8/3/2016	6	1213 10th St.	2.15	0
8/3/2016	20	3901 Cott St.	2.27	0
8/3/2016	66	635 Southern St.	2.30	0
8/3/2016	38	7525 Annemasse St.	0.69	0
8/3/2016	10	3146 Saratoga Blvd.	1.92	0
8/3/2016	32	4901 Hakei Dr.	1.45	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/3/2016	72	7717 Starnberg Lake Dr.	1.29	0.88
8/3/2016	56	202 Amistad St.	1.99	0.04
8/3/2016	73	5649 King Trl.	1.99	0
8/3/2016	5	4609 Evelyn St.	2.18	0
8/3/2016	26	225 Eastgate Dr.	2.02	0
8/3/2016	78	7602 Timber Crest Dr.	0.58	0.2
8/3/2016	55	514 Belden St.	2.05	0
8/3/2016	32	4901 Hakel Dr.	1.49	0
8/3/2016	10	3146 Saratoga Blvd.	1.81	0
8/3/2016	52	221 Junior Beck Dr.	2.26	0
8/3/2016	18	902 Nueces Bay Blvd.	2.63	0
8/3/2016	54	510 St. Charles St.	1.44	0.03
8/3/2016	55	514 Belden St.	2.12	0
8/3/2016	63	2314 Summers St.	2.07	0
8/3/2016	38	7525 Annemasse St.	0.78	0
8/3/2016	72	7717 Starnberg Lake Dr.	1.26	0.85
8/3/2016	25	4101 Bascule Dr.	2.75	0
8/3/2016	73	5649 King Trl.	2.18	0
8/3/2016	27	2823 S Port Ave.	2.41	0
8/3/2016	69	4013 Donaho Dr.	1.35	0
8/3/2016	67	509 S. Carancahua St.	1.91	0
8/3/2016	64	4013 Hidalgo St.	2.38	0
8/3/2016	78	7602 Timber Crest Dr.	0.44	0.08
8/3/2016	13	1505 6th St.	1.81	0
8/3/2016	73	5649 King Trl.	2.08	0
8/3/2016	19	1301 Horne Rd.	2.37	0
8/3/2016	69	4013 Donaho Dr.	1.29	0.08
8/3/2016	72	7717 Starnberg Lake Dr.	0.94	0.61
8/3/2016	63	2314 Summers St.	2.13	0
8/3/2016	38	7525 Annemasse St.	0.92	0
8/3/2016	28	1718 Bois d' Arc Pl.	2.44	0
8/3/2016	54	510 St. Charles St.	1.67	0.04
8/3/2016	74	7910 Impala Dr.	0.43	0.1
8/3/2016	78	7602 Timber Crest Dr.	0.50	0.1
8/3/2016	13	1505 6th St.	2.07	0
8/3/2016	60	1346 Calle San Marcos	1.93	0
8/3/2016	56	202 Amistad St.	2.05	0
8/3/2016	67	509 S. Carancahua St.	1.92	0
8/3/2016	13	1505 6th St.	2.08	0
8/3/2016	56	202 Amistad St.	2.14	0
8/3/2016	2	5809 St. Andrews Dr.	1.49	0
8/3/2016	58	4801 French Dr.	2.28	0
8/3/2016	30	3100 Brawner Pkwy.	2.09	0
8/3/2016	23	5506 Wooldridge Rd.	1.46	0
8/3/2016	54	510 St. Charles St.	1.90	0
8/3/2016	59	3633 Capri Dr.	2.12	0
8/3/2016	31	4306 Cedar St.	0.96	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/3/2016	58	4801 French Dr.	2.04	0
8/3/2016	35	4702 Congressional Dr.	1.44	0
8/3/2016	32	4901 Hakei Dr.	1.73	0.02
8/3/2016	2	5809 St. Andrews Dr.	1.47	0
8/3/2016	59	3633 Capri Dr.	2.06	0
8/3/2016	54	510 St. Charles St.	1.89	0
8/3/2016	23	5506 Wooldridge Rd.	1.45	0
8/3/2016	30	3100 Brawner Pkwy.	2.32	0
8/3/2016	31	4306 Cedar St.	1.53	0
8/3/2016	67	509 S. Carancahua St.	2.32	0
8/3/2016	33	3913 Ocean Dr.	1.89	0
8/3/2016	32	4901 Hakei Dr.	1.84	0
8/3/2016	35	4702 Congressional Dr.	1.60	0
8/3/2016	67	509 S. Carancahua St.	2.36	0
8/3/2016	2	5809 St. Andrews Dr.	1.54	0
8/3/2016	38	7525 Annemasse St.	1.40	0
8/3/2016	54	510 St. Charles St.	2.00	0
8/3/2016	23	5506 Wooldridge Rd.	1.58	0
8/3/2016	31	4306 Cedar St.	1.61	0.02
8/3/2016	7	617 Carmel Pkwy.	1.06	0
8/3/2016	10	3146 Saratoga Blvd.	1.97	0
8/3/2016	35	4702 Congressional Dr.	1.66	0
8/3/2016	32	4901 Hakei Dr.	2.18	0
8/3/2016	2	5809 St. Andrews Dr.	1.52	0
8/3/2016	69	4013 Donaho Dr.	2.09	0
8/3/2016	32	4901 Hakei Dr.	2.20	0
8/3/2016	33	3913 Ocean Dr.	1.95	0
8/3/2016	23	5506 Wooldridge Rd.	1.65	0
8/3/2016	54	510 St. Charles St.	1.97	0
8/3/2016	10	3146 Saratoga Blvd.	2.02	0
8/3/2016	35	4702 Congressional Dr.	1.70	0
8/3/2016	31	4306 Cedar St.	1.91	0
8/3/2016	7	617 Carmel Pkwy.	1.06	0.08
8/3/2016	69	4013 Donaho Dr.	2.18	0
8/3/2016	10	3146 Saratoga Blvd.	2.01	0
8/3/2016	33	3913 Ocean Dr.	1.21	0
8/3/2016	7	617 Carmel Pkwy.	1.09	0.03
8/3/2016	13	1505 6th St.	1.81	0
8/3/2016	54	510 St. Charles St.	1.94	0
8/4/2016	33	3913 Ocean Dr.	2.25	0
8/4/2016	54	510 St. Charles St.	2.03	0.03
8/4/2016	33	3913 Ocean Dr.	2.33	0
8/4/2016	54	510 St. Charles St.	2.00	0
8/4/2016	7	617 Carmel Pkwy.	2.41	0
8/4/2016	7	617 Carmel Pkwy.	2.33	0
8/4/2016	63	2314 Summers St.	2.24	0
8/4/2016	55	514 Belden St.	2.54	0.01



Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/4/2016	58	4801 French Dr.	2.28	0.05
8/4/2016	35	4702 Congressional Dr.	2.24	0
8/4/2016	67	509 S. Carancahua St.	2.32	0.01
8/4/2016	31	4306 Cedar St.	2.05	0
8/4/2016	59	3633 Capri Dr.	2.42	0.09
8/4/2016	35	4702 Congressional Dr.	2.28	0.12
8/4/2016	31	4306 Cedar St.	2.34	0
8/4/2016	13	1505 6th St.	2.23	0
8/4/2016	69	4013 Donaho Dr.	2.63	0
8/4/2016	80	7042 Arapahoe St.	2.19	0
8/4/2016	2	5809 St. Andrews Dr.	2.03	0.03
8/4/2016	85	302 Glenmore St.	1.78	0
8/4/2016	80	7042 Arapahoe St.	2.20	0
8/4/2016	22	6713 Weber Rd.	2.35	0
8/4/2016	12	2219 Buford Ave.	2.80	0
8/4/2016	2	5809 St. Andrews Dr.	1.94	0
8/4/2016	10	3146 Saratoga Blvd.	2.54	0
8/4/2016	72	7717 Starnberg Lake Dr.	1.84	0
8/4/2016	77	5018 Cape Ann Dr.	2.20	0
8/4/2016	26	225 Eastgate Dr.	2.20	0
8/4/2016	2	5809 St. Andrews Dr.	1.83	0
8/4/2016	78	7602 Timber Crest Dr.	1.82	0
8/4/2016	77	5018 Cape Ann Dr.	2.12	0.03
8/4/2016	60	1346 Calle San Marcos	2.03	0
8/4/2016	72	7717 Starnberg Lake Dr.	1.50	0
8/4/2016	34	4341 Harry St.	2.48	0.01
8/4/2016	38	7525 Annemasse St.	1.90	0
8/4/2016	73	5649 King Trl.	2.34	0
8/4/2016	56	202 Amistad St.	2.25	0
8/4/2016	78	7602 Timber Crest Dr.	1.75	0.01
8/4/2016	34	4341 Harry St.	2.58	0
8/4/2016	74	7910 Impala Dr.	1.82	0
8/4/2016	72	7717 Starnberg Lake Dr.	2.13	0
8/4/2016	99	3926 Elvis Dr.	1.91	0
8/4/2016	66	635 Southern St.	2.58	0
8/4/2016	21	913 Lum Ave.	2.75	0.07
8/4/2016	72	7717 Starnberg Lake Dr.	2.06	0
8/4/2016	38	7525 Annemasse St.	1.89	0
8/4/2016	21	913 Lum Ave.	2.56	0.01
8/4/2016	78	7602 Timber Crest Dr.	1.69	0
8/4/2016	57	1409 Arlington Dr.	2.75	0
8/4/2016	2	5809 St. Andrews Dr.	2.23	0
8/4/2016	81	6630 Meadowheights Dr.	2.10	0
8/4/2016	15	6130 Parkway Dr.	2.27	0
8/4/2016	74	7910 Impala Dr.	1.83	0
8/4/2016	85	302 Glenmore St.	1.79	0
8/4/2016	39	5929 Long Creek Dr.	2.20	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/4/2016	5	4609 Evelyn St.	2.40	0
8/4/2016	23	5506 Wooldridge Rd.	2.17	0
8/4/2016	37	6502 Brockhampton St.	1.95	0
8/4/2016	81	6630 Meadowheights Dr.	2.09	0
8/4/2016	15	6130 Parkway Dr.	2.26	0
8/4/2016	3	3013 S Fork Dr.	2.37	0
8/4/2016	39	5929 Long Creek Dr.	2.25	0
8/4/2016	23	5506 Wooldridge Rd.	2.15	0
8/4/2016	68	5322 Alejandro St.	2.37	0
8/4/2016	8	1126 Cornerstone Dr.	2.05	0
8/4/2016	85	302 Glenmore St.	1.92	0
8/4/2016	99	3926 Elvis Dr.	2.07	0.09
8/4/2016	78	7602 Timber Crest Dr.	1.68	0.05
8/4/2016	36	1338 Sandstone Dr.	1.70	0
8/4/2016	23	5506 Wooldridge Rd.	2.22	0
8/4/2016	75	2938 Oso Pkwy.	1.99	0
8/4/2016	70	1633 E. Manor Dr.	2.18	0
8/4/2016	99	3926 Elvis Dr.	2.10	0
8/4/2016	32	4901 Hakeel Dr.	2.46	0
8/4/2016	85	302 Glenmore St.	2.14	0
8/4/2016	3	3013 S Fork Dr.	2.39	0
8/4/2016	82	2101 Whispering Oak Dr.	1.41	0.01
8/4/2016	70	1633 E. Manor Dr.	2.28	0
8/4/2016	36	1338 Sandstone Dr.	1.78	0
8/4/2016	71	5510 Fox Run Dr.	2.17	0
8/4/2016	85	302 Glenmore St.	2.01	0
8/4/2016	30	3100 Brawner Pkwy.	2.55	0
8/4/2016	23	5506 Wooldridge Rd.	2.13	0
8/4/2016	36	1338 Sandstone Dr.	1.91	0
8/4/2016	38	7525 Annemasse St.	1.93	0.02
8/4/2016	78	7602 Timber Crest Dr.	1.68	0
8/4/2016	8	1126 Cornerstone Dr.	2.20	0
8/4/2016	37	6502 Brockhampton St.	2.03	0
8/4/2016	14	922 Rosedale Dr.	2.40	0
8/4/2016	71	5510 Fox Run Dr.	2.23	0
8/4/2016	33	3913 Ocean Dr.	2.58	0.03
8/4/2016	37	6502 Brockhampton St.	2.06	0
8/4/2016	74	7910 Impala Dr.	1.94	0
8/4/2016	4	14233 Playa del Rey	1.31	0
8/4/2016	20	3901 Cott St.	2.82	0
8/4/2016	75	2938 Oso Pkwy.	2.28	0
8/4/2016	7	617 Carmel Pkwy.	2.42	0
8/4/2016	84	3640 Flour Bluff Dr.	2.13	0
8/4/2016	78	7602 Timber Crest Dr.	1.93	0
8/4/2016	36	1338 Sandstone Dr.	1.98	0
8/4/2016	75	2938 Oso Pkwy.	2.34	0
8/4/2016	84	3640 Flour Bluff Dr.	2.20	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/4/2016	36	1338 Sandstone Dr.	2.09	0
8/4/2016	35	4702 Congressional Dr.	2.36	0
8/4/2016	76	1109 Harbor Lights Dr.	2.17	0
8/4/2016	38	7525 Annemasse St.	2.01	0.04
8/4/2016	24	2342 Rodd Field Rd.	2.04	0
8/4/2016	78	7602 Timber Crest Dr.	2.00	0.11
8/4/2016	82	2101 Whispering Oak Dr.	1.68	0.02
8/4/2016	76	1109 Harbor Lights Dr.	2.28	0
8/4/2016	36	1338 Sandstone Dr.	2.12	0
8/4/2016	6	1213 10th St.	2.70	0.06
8/4/2016	24	2342 Rodd Field Rd.	2.08	0
8/4/2016	38	7525 Annemasse St.	2.02	0
8/4/2016	78	7602 Timber Crest Dr.	1.95	0
8/4/2016	42	753 Orleans Dr.	1.96	0
8/4/2016	24	2342 Rodd Field Rd.	2.15	0
8/4/2016	31	4306 Cedar St.	2.49	0
8/4/2016	4	14233 Playa del Rey	1.65	0
8/4/2016	79	905 Egyptian Dr.	2.24	0
8/4/2016	41	1609 Amber Dr.	2.16	0
8/4/2016	40	9550 Quetzal St.	1.91	0
8/4/2016	79	905 Egyptian Dr.	2.37	0
8/4/2016	41	1609 Amber Dr.	2.24	0
8/4/2016	11	534 Military Dr.	1.70	0
8/4/2016	4	14233 Playa del Rey	1.60	0
8/4/2016	2	5809 St. Andrews Dr.	2.30	0.08
8/4/2016	82	2101 Whispering Oak Dr.	2.07	0
8/4/2016	78	7602 Timber Crest Dr.	1.88	0
8/4/2016	40	9550 Quetzal St.	2.15	0
8/4/2016	82	2101 Whispering Oak Dr.	2.01	0
8/4/2016	11	534 Military Dr.	1.75	0
8/4/2016	42	753 Orleans Dr.	1.82	0
8/4/2016	4	14233 Playa del Rey	1.67	0
8/4/2016	74	7910 Impala Dr.	1.61	0
8/4/2016	40	9550 Quetzal St.	2.20	0
8/4/2016	11	534 Military Dr.	1.95	0
8/4/2016	43	245 Caribbean Dr.	1.98	0
8/4/2016	80	7042 Arapahoe St.	2.19	0
8/4/2016	11	534 Military Dr.	1.64	0
8/4/2016	83	4101 Summit Dr.	0.47	0
8/4/2016	4	14233 Playa del Rey	1.71	0
8/4/2016	42	753 Orleans Dr.	2.16	0
8/4/2016	43	245 Caribbean Dr.	1.98	0
8/4/2016	42	753 Orleans Dr.	2.03	0
8/4/2016	97	13902 Skysail St.	1.81	0
8/4/2016	83	4101 Summit Dr.	1.44	0.2
8/4/2016	11	534 Military Dr.	1.81	0
8/4/2016	4	14233 Playa del Rey	1.88	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/4/2016	45	15222 Cruiser St.	1.89	0
8/4/2016	94	15209 Caravel Dr.	1.35	0.02
8/4/2016	43	245 Caribbean Dr.	1.92	0
8/4/2016	96	14926 Windward Dr.	1.54	0
8/4/2016	11	534 Military Dr.	1.90	0
8/4/2016	83	4101 Summit Dr.	1.81	0
8/4/2016	4	14233 Playa del Rey	1.89	0
8/4/2016	45	15222 Cruiser St.	1.93	0
8/4/2016	97	13902 Skysail St.	1.93	0.02
8/4/2016	11	534 Military Dr.	2.00	0
8/4/2016	43	245 Caribbean Dr.	1.88	0
8/4/2016	94	15209 Caravel Dr.	1.55	0.03
8/4/2016	11	534 Military Dr.	2.01	0
8/4/2016	4	14233 Playa del Rey	1.93	0
8/4/2016	83	4101 Summit Dr.	1.78	0.01
8/4/2016	74	7910 Impala Dr.	2.29	0
8/4/2016	78	7602 Timber Crest Dr.	2.05	0
8/4/2016	74	7910 Impala Dr.	2.32	0
8/4/2016	78	7602 Timber Crest Dr.	2.04	0
8/5/2016	34	4341 Harry St.	2.58	0
8/5/2016	77	5018 Cape Ann Dr.	2.53	0
8/5/2016	48	1237 Southern Minerals Rd.	3.78	0
8/5/2016	85	302 Glenmore St.	2.31	0
8/5/2016	79	905 Egyptian Dr.	2.50	0
8/5/2016	21	913 Lum Ave.	2.60	0
8/5/2016	4	14233 Playa del Rey	2.20	0
8/5/2016	43	245 Caribbean Dr.	2.26	0.11
8/5/2016	72	7717 Starnberg Lake Dr.	2.21	0
8/5/2016	70	1633 E. Manor Dr.	2.53	0
8/5/2016	4	14233 Playa del Rey	2.11	0
8/5/2016	98	15806 Almeria Ave.	2.04	0.01
8/5/2016	83	4101 Summit Dr.	1.67	0
8/5/2016	78	7602 Timber Crest Dr.	2.34	0
8/5/2016	23	5506 Wooldridge Rd.	2.60	0
8/5/2016	96	14926 Windward Dr.	2.03	0
8/5/2016	95	15837 El Socorro Loop	1.79	0
8/5/2016	38	7525 Annemasse St.	2.27	0
8/5/2016	71	5510 Fox Run Dr.	2.53	0
8/5/2016	96	14926 Windward Dr.	2.02	0
8/5/2016	98	15806 Almeria Ave.	2.06	0
8/5/2016	83	4101 Summit Dr.	2.23	0
8/5/2016	15	6130 Parkway Dr.	2.59	0
8/5/2016	74	7910 Impala Dr.	2.28	0
8/5/2016	43	245 Caribbean Dr.	2.14	0
8/5/2016	45	15222 Cruiser St.	2.18	0
8/5/2016	95	15837 El Socorro Loop	1.78	0.02
8/5/2016	39	5929 Long Creek Dr.	2.66	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/5/2016	83	4101 Summit Dr.	2.24	0
8/5/2016	45	15222 Cruiser St.	2.16	0
8/5/2016	99	3926 Elvis Dr.	2.42	0
8/5/2016	94	15209 Caravel Dr.	2.08	0
8/5/2016	36	1338 Sandstone Dr.	2.26	0
8/5/2016	3	3013 S Fork Dr.	2.44	0
8/5/2016	94	15209 Caravel Dr.	1.97	0
8/5/2016	75	2938 Oso Pkwy.	2.39	0
8/5/2016	94	15209 Caravel Dr.	2.08	0
8/5/2016	42	753 Orleans Dr.	2.21	0
8/5/2016	76	1109 Harbor Lights Dr.	2.23	0
8/5/2016	24	2342 Rodd Field Rd.	2.37	0
8/5/2016	97	13902 Skysail St.	2.18	0
8/5/2016	95	15837 El Socorro Loop	1.76	0.09
8/5/2016	82	2101 Whispering Oak Dr.	2.18	0
8/5/2016	81	6630 Meadowheights Dr.	2.67	0
8/5/2016	40	9550 Quetzal St.	2.22	0
8/5/2016	97	13902 Skysail St.	2.06	0
8/5/2016	37	6502 Brockhampton St.	2.36	0
8/5/2016	94	15209 Caravel Dr.	1.86	0
8/5/2016	11	534 Military Dr.	2.25	0
8/5/2016	95	15837 El Socorro Loop	1.84	0.01
8/5/2016	8	1126 Cornerstone Dr.	2.49	0
8/5/2016	95	15837 El Socorro Loop	1.99	0
8/5/2016	84	3640 Flour Bluff Dr.	2.45	0
8/5/2016	95	15837 El Socorro Loop	1.95	0
8/5/2016	95	15837 El Socorro Loop	1.94	0.05
8/5/2016	95	15837 El Socorro Loop	1.87	0
8/5/2016	94	15209 Caravel Dr.	2.06	0.03
8/5/2016	41	1609 Amber Dr.	2.48	0
8/5/2016	95	15837 El Socorro Loop	1.87	0
8/5/2016	95	15837 El Socorro Loop	2.01	0
8/5/2016	95	15837 El Socorro Loop	2.06	0
8/5/2016	96	14926 Windward Dr.	2.13	0
8/5/2016	45	15222 Cruiser St.	2.17	0
8/5/2016	94	15209 Caravel Dr.	2.06	0.03
8/5/2016	4	14233 Playa del Rey	2.00	0
8/5/2016	98	15806 Almeria Ave.	2.11	0
8/5/2016	97	13902 Skysail St.	2.22	0
8/5/2016	95	15837 El Socorro Loop	2.11	0
8/5/2016	43	245 Caribbean Dr.	2.38	0
8/5/2016	83	4101 Summit Dr.	2.08	0
8/6/2016	98	15806 Almeria Ave.	2.15	0
8/6/2016	38	7525 Annemasse St.	2.36	0
8/6/2016	25	4101 Bascule Dr.	3.18	0
8/6/2016	93	11025 Annville Rd.	3.63	0
8/7/2016	97	13902 Skysail St.	2.26	0

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
8/7/2016	8	1126 Cornerstone Dr.	2.20	0
8/7/2016	26	225 Eastgate Dr.	2.78	0
8/7/2016	86	14814 Santa Gertrudis Dr.	2.91	0
8/5/2016	94	15209 Caravel Dr.	2.08	0
8/5/2016	42	753 Orleans Dr.	2.21	0
8/5/2016	76	1109 Harbor Lights Dr.	2.23	0
8/5/2016	24	2342 Rodd Field Rd.	2.37	0
8/5/2016	97	13902 Skysail St.	2.18	0
8/5/2016	95	15837 El Socorro Loop	1.76	0.09
8/5/2016	82	2101 Whispering Oak Dr.	2.18	0
8/5/2016	81	6630 Meadowheights Dr.	2.67	0
8/5/2016	40	9550 Quetzal St.	2.22	0
8/5/2016	97	13902 Skysail St.	2.06	0
8/5/2016	37	6502 Brockhampton St.	2.36	0
8/5/2016	94	15209 Caravel Dr.	1.86	0
8/5/2016	11	534 Military Dr.	2.25	0
8/5/2016	95	15837 El Socorro Loop	1.84	0.01
8/5/2016	8	1126 Cornerstone Dr.	2.49	0
8/5/2016	95	15837 El Socorro Loop	1.99	0
8/5/2016	84	3640 Flour Bluff Dr.	2.45	0
8/5/2016	95	15837 El Socorro Loop	1.95	0
8/5/2016	95	15837 El Socorro Loop	1.94	0.05
8/5/2016	95	15837 El Socorro Loop	1.87	0
8/5/2016	94	15209 Caravel Dr.	2.06	0.03
8/5/2016	41	1609 Amber Dr.	2.48	0
8/5/2016	95	15837 El Socorro Loop	1.87	0
8/5/2016	95	15837 El Socorro Loop	2.01	0
8/5/2016	95	15837 El Socorro Loop	2.06	0
8/5/2016	96	14926 Windward Dr.	2.13	0
8/5/2016	45	15222 Cruiser St.	2.17	0
8/5/2016	94	15209 Caravel Dr.	2.06	0.03
8/5/2016	4	14233 Playa del Rey	2.00	0
8/5/2016	98	15806 Almeria Ave.	2.11	0
8/5/2016	97	13902 Skysail St.	2.22	0
8/5/2016	95	15837 El Socorro Loop	2.11	0
8/5/2016	43	245 Caribbean Dr.	2.38	0
8/5/2016	83	4101 Summit Dr.	2.08	0
8/6/2016	98	15806 Almeria Ave.	2.15	0
8/6/2016	38	7525 Annemasse St.	2.36	0
8/6/2016	25	4101 Bascule Dr.	3.18	0
8/6/2016	93	11025 Annaville Rd.	3.63	0
8/7/2016	97	13902 Skysail St.	2.26	0
8/7/2016	8	1126 Cornerstone Dr.	2.20	0
8/7/2016	26	225 Eastgate Dr.	2.78	0
8/7/2016	86	14814 Santa Gertrudis Dr.	2.91	0

**Note: A disinfectant conversion from free chlorine to monochloramine took place from 8/2/2016-8/5/2016.**