



January 2016 Chlorine Residuals

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/1/2016	41	1609 Amber St.	2.51
1/1/2016	42	753 Orleans Dr.	2.21
1/1/2016	45	15222 Cruiser St.	3.83
1/1/2016	79	905 Egyptian Dr.	1.53
1/2/2016	25	4101 Bascule Dr.	2.55
1/2/2016	38	7525 Annemasse St.	2.83
1/2/2016	93	11025 Annville Rd.	3.78
1/2/2016	98	15806 Almeria Ave.	1.85
1/3/2016	8	1126 Cornerstone Dr.	3.07
1/3/2016	26	225 Eastgate Dr.	2.62
1/3/2016	86	14814 Santa Gertrudis Dr.	3.17
1/3/2016	97	13902 Skysail St.	2.89
1/4/2016	4	14233 Playa del Rey	2.41
1/4/2016	13	1505 6th St.	2.47
1/4/2016	15	6130 Parkway Dr.	1.89
1/4/2016	23	5506 Wooldridge Rd.	2.32
1/4/2016	29	1601 La Joya St.	3.48
1/4/2016	46	8903 McNorton Rd.	3.70
1/4/2016	52	221 Junior Beck Dr.	2.57
1/4/2016	63	2314 Summers St.	2.73
1/4/2016	65	726 Westchester Dr.	3.07
1/4/2016	86	14814 Santa Gertrudis Dr.	3.48
1/5/2016	8	1126 Cornerstone Dr.	3.13
1/5/2016	26	225 Eastgate Dr.	2.57
1/5/2016	31	4306 Cedar St.	2.51
1/5/2016	53	9105 Stock Dr.	2.81
1/5/2016	60	1346 Calle San Marcos	1.74
1/5/2016	61	234 Saratoga Blvd.	3.49
1/5/2016	73	5649 King Trl.	3.14
1/5/2016	87	5226 Northwest Trl.	3.79
1/5/2016	96	14926 Windward Dr.	2.06
1/6/2016	9	1000 International Dr.	3.01
1/6/2016	11	534 Military Dr.	2.86
1/6/2016	16	4205 Wildcat Dr.	3.61
1/6/2016	18	902 Nueces Bay Blvd.	3.27
1/6/2016	21	913 Lum Ave.	3.12
1/6/2016	24	2342 Rodd Field Rd.	3.50
1/6/2016	28	1718 Bois d Arc Pl.	3.04
1/6/2016	32	4901 Hakel Dr.	2.84
1/6/2016	41	1609 Amber St.	2.87

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/6/2016	42	753 Orleans Dr.	2.66
1/6/2016	45	15222 Cruiser St.	2.21
1/6/2016	49	113 Commerce St.	2.89
1/6/2016	54	510 St. Charles St.	2.25
1/6/2016	55	514 Belden St.	2.70
1/6/2016	71	5510 Fox Run Dr.	3.11
1/6/2016	79	905 Egyptian Dr.	2.34
1/6/2016	97	13902 Skysail St.	2.68
1/7/2016	1	4810 Neptune St.	3.39
1/7/2016	14	922 Rosedale Dr.	2.71
1/7/2016	36	1338 Sandstone Dr.	1.99
1/7/2016	40	9550 Quetzal St.	2.83
1/7/2016	59	3633 Capri Dr.	2.67
1/7/2016	62	5809 Hampshire Rd.	3.43
1/7/2016	88	4214 Western Dr.	3.70
1/7/2016	94	15209 Caravel Dr.	2.06
1/8/2016	5	4609 Evelyn St.	2.40
1/8/2016	9	1000 International Dr.	2.99
1/8/2016	21	913 Lum Ave.	2.73
1/8/2016	28	1718 Bois d Arc Pl.	3.15
1/8/2016	30	3100 Brawner Pkwy	2.45
1/8/2016	32	4901 Hakel Dr.	2.55
1/8/2016	39	5929 Long Creek Dr.	2.62
1/8/2016	47	8121 Barrogate Dr.	3.46
1/8/2016	48	1237 Southern Minerals Rd.	3.84
1/8/2016	49	113 Commerce St.	2.83
1/8/2016	70	1633 E. Manor Dr.	2.50
1/8/2016	75	2938 Oso Pkwy	3.17
1/8/2016	94	15209 Caravel Dr.	2.07
1/9/2016	25	4101 Bascule Dr.	2.58
1/9/2016	38	7525 Annemasse St.	2.99
1/9/2016	93	11025 Annville Rd.	3.71
1/9/2016	98	15806 Almeria Ave.	2.81
1/10/2016	8	1126 Cornerstone Dr.	2.66
1/10/2016	26	225 Eastgate Dr.	2.74
1/10/2016	86	14814 Santa Gertrudis Dr.	2.98
1/10/2016	97	13902 Skysail St.	3.39
1/11/2016	38	7525 Annemasse St.	2.72
1/11/2016	45	15222 Cruiser St.	2.24
1/11/2016	51	249 Gibson Ln.	3.31
1/11/2016	58	4801 French Dr.	2.73
1/11/2016	72	7717 Starnberg Lake Dr.	3.01
1/11/2016	77	5018 Cape Ann Dr.	1.82
1/11/2016	83	4101 Summit Dr.	1.47
1/11/2016	93	11025 Annville Rd.	4.00
1/12/2016	33	3913 Ocean Dr.	1.95
1/12/2016	67	509 S. Carancahua St.	2.56

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/12/2016	68	5322 Alejandro St.	2.71
1/12/2016	76	1109 Harbor Lights Dr.	1.73
1/12/2016	81	6630 Meadowheights Dr.	2.92
1/12/2016	85	302 Glenmore St.	1.37
1/12/2016	90	11722 Haven Dr.	3.28
1/12/2016	95	15837 El Socorro Loop	1.52
1/13/2016	5	4609 Evelyn St.	2.24
1/13/2016	25	4101 Bascule Dr.	2.88
1/13/2016	30	3100 Brawner Pkwy	2.75
1/13/2016	39	5929 Long Creek Dr.	2.58
1/13/2016	47	8121 Barrogate Dr.	3.20
1/13/2016	48	1237 Southern Minerals Rd.	3.60
1/13/2016	64	4013 Hidalgo St.	3.44
1/13/2016	66	635 Southern St.	3.08
1/13/2016	69	4013 Donaho Dr.	3.09
1/13/2016	70	1633 E. Manor Dr.	2.53
1/13/2016	74	7910 Impala Dr.	2.68
1/13/2016	75	2938 Oso Pkwy	3.31
1/13/2016	78	7602 Timber Crest Dr.	3.12
1/13/2016	91	2713 Wind Rock Dr.	3.67
1/13/2016	94	15209 Caravel Dr.	2.66
1/13/2016	98	15806 Almeria Ave.	2.61
1/14/2016	4	14233 Playa del Rey	2.80
1/14/2016	6	1213 10th St.	1.95
1/14/2016	20	3901 Cott St.	3.12
1/14/2016	22	6713 Weber Rd.	2.75
1/14/2016	27	2823 S Port Ave.	3.45
1/14/2016	84	3640 Flour Bluff Dr.	3.00
1/14/2016	89	3814 Castle Ridge Dr.	3.06
1/14/2016	99	3926 Elvis Dr.	2.54
1/15/2016	4	14233 Playa del Rey	3.25
1/15/2016	13	1505 6th St.	2.98
1/15/2016	15	6130 Parkway Dr.	3.01
1/15/2016	23	5506 Wooldridge Rd.	2.95
1/15/2016	29	1601 La Joya St.	3.28
1/15/2016	46	8903 McNorton Rd.	3.66
1/15/2016	52	221 Junior Beck Dr.	3.38
1/15/2016	63	2314 Summers St.	2.31
1/15/2016	65	726 Westchester Dr.	2.85
1/15/2016	86	14814 Santa Gertrudis Dr.	3.27
1/16/2016	25	4101 Bascule Dr.	2.78
1/16/2016	38	7525 Annemasse St.	3.03
1/16/2016	93	11025 Annaville Rd.	3.82
1/16/2016	98	15806 Almeria Ave.	3.16
1/17/2016	8	1126 Cornerstone Dr.	3.06
1/17/2016	26	225 Eastgate Dr.	2.86
1/17/2016	86	14814 Santa Gertrudis Dr.	3.06

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/17/2016	97	13902 Skysail St.	3.73
1/18/2016	2	5809 St. Andrews Dr.	2.55
1/18/2016	7	617 Carmel Pkwy	1.66
1/18/2016	8	1126 Cornerstone Dr.	2.62
1/18/2016	12	2219 Buford Ave.	2.14
1/18/2016	19	1301 Horne Rd.	2.89
1/18/2016	26	225 Eastgate Dr.	2.65
1/18/2016	31	4306 Cedar St.	2.38
1/18/2016	35	4702 Congressional Dr.	2.89
1/18/2016	53	9105 Stock Dr.	2.10
1/18/2016	56	202 Amistad St.	1.99
1/18/2016	60	1346 Calle San Marcos	1.45
1/18/2016	61	234 Saratoga Blvd.	3.30
1/18/2016	73	5649 King Trl.	2.91
1/18/2016	80	7042 Arapahoe St.	2.69
1/18/2016	82	2101 Whispering Oak Dr.	2.29
1/18/2016	87	5226 Northwest Trl.	3.67
1/18/2016	92	334 Wildwood Dr.	3.73
1/18/2016	96	14926 Windward Dr.	2.36
1/18/2016	96	14926 Windward Dr.	3.00
1/19/2016	3	3013 S. Fork Dr.	3.40
1/19/2016	10	3146 Saratoga Blvd.	2.74
1/19/2016	11	534 Military Dr.	2.70
1/19/2016	16	4205 Wildcat Dr.	4.11
1/19/2016	18	902 Nueces Bay Blvd.	2.65
1/19/2016	24	2342 Rodd Field Rd.	3.29
1/19/2016	34	4341 Harry St.	2.24
1/19/2016	37	6502 Brockhampton St.	2.88
1/19/2016	43	245 Caribbean Dr.	2.79
1/19/2016	44	9602 Wilkins Dr.	3.68
1/19/2016	50	5534 IH 37 Access Rd.	3.31
1/19/2016	54	510 St. Charles St.	1.38
1/19/2016	55	514 Belden St.	1.93
1/19/2016	57	1409 Arlington Dr.	2.61
1/19/2016	71	5510 Fox Run Dr.	2.87
1/19/2016	97	13902 Skysail St.	3.79
1/19/2016	97	13902 Skysail St.	3.74
1/20/2016	1	4810 Neptune St.	3.44
1/20/2016	14	922 Rosedale Dr.	2.76
1/20/2016	36	1338 Sandstone Dr.	2.38
1/20/2016	40	9550 Quetzal St.	2.87
1/20/2016	59	3633 Capri Dr.	2.79
1/20/2016	62	5809 Hampshire Rd.	3.50
1/20/2016	88	4214 Western Dr.	3.88
1/20/2016	94	15209 Caravel Dr.	2.78
1/21/2016	38	7525 Annemasse St.	3.32
1/21/2016	45	15222 Cruiser St.	3.82

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/21/2016	51	249 Gibson Ln.	3.49
1/21/2016	58	4801 French Dr.	2.78
1/21/2016	72	7717 Starnberg Lake Dr.	3.17
1/21/2016	77	5018 Cape Ann Dr.	2.35
1/21/2016	83	4101 Summit Dr.	1.34
1/21/2016	93	11025 Annaville Rd.	3.68
1/22/2016	33	3913 Ocean Dr.	2.25
1/22/2016	67	509 S. Carancahua St.	2.64
1/22/2016	68	5322 Alejandro St.	2.74
1/22/2016	76	1109 Harbor Lights Dr.	2.29
1/22/2016	81	6630 Meadowheights Dr.	2.95
1/22/2016	85	302 Glenmore St.	1.69
1/22/2016	90	11722 Haven Dr.	2.92
1/22/2016	95	15837 El Socorro Loop	2.04
1/23/2016	25	4101 Bascule Dr.	2.84
1/23/2016	38	7525 Annemasse St.	3.35
1/23/2016	93	11025 Annaville Rd.	3.81
1/23/2016	98	15806 Almeria Ave.	2.24
1/24/2016	8	1126 Cornerstone Dr.	2.89
1/24/2016	26	225 Eastgate Dr.	2.66
1/24/2016	86	14814 Santa Gertrudis Dr.	3.13
1/24/2016	97	13902 Skysail St.	3.33
1/25/2016	25	4101 Bascule Dr.	3.28
1/25/2016	64	4013 Hidalgo St.	3.64
1/25/2016	66	635 Southern St.	3.70
1/25/2016	69	4013 Donaho Dr.	3.42
1/25/2016	74	7910 Impala Dr.	2.83
1/25/2016	78	7602 Timber Crest Dr.	3.94
1/25/2016	91	2713 Wind Rock Dr.	3.95
1/25/2016	98	15806 Almeria Ave.	2.41
1/26/2016	4	14233 Playa del Rey	2.35
1/26/2016	6	1213 10th St.	2.40
1/26/2016	20	3901 Cott St.	2.90
1/26/2016	22	6713 Weber Rd.	3.00
1/26/2016	27	2823 S Port Ave.	3.60
1/26/2016	84	3640 Flour Bluff Dr.	3.19
1/26/2016	89	3814 Castle Ridge Dr.	3.35
1/26/2016	99	3926 Elvis Dr.	2.84
1/27/2016	2	5809 St. Andrews Dr.	3.01
1/27/2016	7	617 Carmel Pkwy	2.48
1/27/2016	11	534 Military Dr.	3.01
1/27/2016	12	2219 Buford Ave.	3.42
1/27/2016	19	1301 Horne Rd.	3.25
1/27/2016	35	4702 Congressional Dr.	3.37
1/27/2016	40	9550 Quetzal St.	3.06
1/27/2016	43	245 Caribbean Dr.	3.01
1/27/2016	45	15222 Cruiser St.	2.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/27/2016	56	202 Amistad St.	2.99
1/27/2016	76	1109 Harbor Lights Dr.	2.35
1/27/2016	80	7042 Arapahoe St.	2.71
1/27/2016	82	2101 Whispering Oak Dr.	2.81
1/27/2016	83	4101 Summit Dr.	1.95
1/27/2016	92	334 Wildwood Dr.	3.72
1/27/2016	94	15209 Caravel Dr.	3.49
1/27/2016	96	14926 Windward Dr.	2.97
1/28/2016	3	3013 S. Fork Dr.	3.37
1/28/2016	10	3146 Saratoga Blvd.	2.66
1/28/2016	34	4341 Harry St.	2.48
1/28/2016	37	6502 Brockhampton St.	2.98
1/28/2016	43	245 Caribbean Dr.	3.15
1/28/2016	44	9602 Wilkins Dr.	3.41
1/28/2016	50	5534 IH 37 Access Rd.	3.37
1/28/2016	54	510 St. Charles St.	2.04
1/28/2016	55	514 Belden St.	2.51
1/28/2016	56	202 Amistad St.	2.81
1/28/2016	57	1409 Arlington Dr.	2.85
1/28/2016	77	5018 Cape Ann Dr.	2.09
1/28/2016	79	905 Egyptian Dr.	2.56
1/28/2016	85	302 Glenmore St.	2.07
1/28/2016	93	11025 Annville Rd.	3.57
1/28/2016	97	13902 Skysail St.	3.96
1/29/2016	48	1237 Southern Minerals Rd.	3.54
1/29/2016	49	113 Commerce St.	3.01
1/29/2016	51	249 Gibson Ln.	2.96
1/29/2016	69	4013 Donaho Dr.	2.86
1/29/2016	74	7910 Impala Dr.	2.84
1/29/2016	78	7602 Timber Crest Dr.	3.16
1/29/2016	87	5226 Northwest Trl.	3.16
1/29/2016	98	15806 Almeria Ave.	2.48
1/30/2016	25	4101 Bascule Dr.	2.43
1/30/2016	38	7525 Annemasse St.	2.67
1/30/2016	93	11025 Annville Rd.	3.73
1/30/2016	98	15806 Almeria Ave.	2.36
1/31/2016	8	1126 Cornerstone Dr.	2.60
1/31/2016	26	225 Eastgate Dr.	2.43
1/31/2016	86	14814 Santa Gertrudis Dr.	2.99
1/31/2016	97	13902 Skysail St.	2.75