



May 2016 Chlorine Residuals

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/1/2016	8	1126 Cornerstone Dr.	2.41	NA
5/1/2016	26	225 Eastgate Dr.	2.60	NA
5/1/2016	86	14814 Santa Gertrudis Dr.	2.53	NA
5/1/2016	97	13902 Skysail St.	2.60	NA
5/2/2016	4	14233 Playa del Rey	3.24	NA
5/2/2016	13	1505 6th St.	2.23	NA
5/2/2016	15	6130 Parkway Dr.	2.04	NA
5/2/2016	23	5506 Wooldridge Rd.	1.99	NA
5/2/2016	29	1601 La Joya St.	2.28	NA
5/2/2016	46	8903 McNorton Rd.	2.80	NA
5/2/2016	52	221 Junior Beck Dr.	2.36	NA
5/2/2016	63	2314 Summers St.	1.39	NA
5/2/2016	65	726 Westchester Dr.	2.25	NA
5/2/2016	86	14814 Santa Gertrudis Dr.	3.00	NA
5/3/2016	8	1126 Cornerstone Dr.	1.97	NA
5/3/2016	26	225 Eastgate Dr.	1.48	NA
5/3/2016	31	4306 Cedar St.	1.54	NA
5/3/2016	53	9105 Stock Dr.	2.04	NA
5/3/2016	60	1346 Calle San Marcos	1.17	NA
5/3/2016	61	234 Saratoga Blvd.	3.00	NA
5/3/2016	73	5649 King Trl.	2.08	NA
5/3/2016	85	302 Glenmore St.	0.61	NA
5/3/2016	87	5226 Northwest Trl.	3.14	NA
5/3/2016	96	14926 Windward Dr.	1.84	NA
5/4/2016	11	534 Military Dr.	1.43	NA
5/4/2016	16	4205 Wildcat Dr.	3.65	NA
5/4/2016	18	902 Nueces Bay Blvd.	3.13	NA
5/4/2016	24	2342 Rodd Field Rd.	1.76	NA
5/4/2016	54	510 St. Charles St.	0.55	NA
5/4/2016	55	514 Belden St.	1.75	NA
5/4/2016	71	5510 Fox Run Dr.	2.08	NA
5/4/2016	85	302 Glenmore St.	0.61	NA
5/4/2016	97	13902 Skysail St.	3.41	NA
5/5/2016	1	4810 Neptune St.	3.00	NA
5/5/2016	14	922 Rosedale Dr.	2.82	NA
5/5/2016	36	1338 Sandstone Dr.	1.05	NA
5/5/2016	40	9550 Quetzal St.	0.57	NA
5/5/2016	59	3633 Capri Dr.	2.67	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/5/2016	62	5809 Hampshire Rd.	3.59	NA
5/5/2016	88	4214 Western Dr.	4.02	NA
5/5/2016	94	15209 Caravel Dr.	2.57	NA
5/6/2016	9	1000 International Dr.	2.81	NA
5/6/2016	21	913 Lum Ave.	1.14	NA
5/6/2016	28	1718 Bois d Arc Pl.	2.93	NA
5/6/2016	32	4901 Hakel Dr.	1.59	NA
5/6/2016	41	1609 Amber St.	1.91	NA
5/6/2016	42	753 Orleans Dr.	1.62	NA
5/6/2016	45	15222 Cruiser St.	3.67	NA
5/6/2016	49	113 Commerce St.	3.13	NA
5/6/2016	79	905 Egyptian Dr.	1.46	NA
5/7/2016	25	4101 Bascule Dr.	2.80	NA
5/7/2016	38	7525 Annemasse St.	2.56	NA
5/7/2016	79	905 Egyptian Dr.	1.47	NA
5/7/2016	93	11025 Annville Rd.	3.43	NA
5/7/2016	98	15806 Almeria Ave.	2.77	NA
5/7/2016	79 DN	845 Egyptian Dr.	1.31	NA
5/7/2016	79 UP	913 Egyptian Dr.	1.45	NA
5/8/2016	8	1126 Cornerstone Dr.	3.14	NA
5/8/2016	26	225 Eastgate Dr.	1.37	NA
5/8/2016	86	14814 Santa Gertrudis Dr.	2.95	NA
5/8/2016	97	13902 Skysail St.	3.77	NA
5/9/2016	38	7525 Annemasse St.	3.20	NA
5/9/2016	45	15222 Cruiser St.	2.01	NA
5/9/2016	51	249 Gibson Ln.	2.87	NA
5/9/2016	58	4801 French Dr.	2.24	NA
5/9/2016	72	7717 Starnberg Lake Dr.	3.20	NA
5/9/2016	77	5018 Cape Ann Dr.	1.06	NA
5/9/2016	83	4101 Summit Dr.	0.91	NA
5/9/2016	93	11025 Annville Rd.	3.64	NA
5/10/2016	33	3913 Ocean Dr.	1.04	NA
5/10/2016	67	509 S. Carancahua St.	1.48	NA
5/10/2016	68	5322 Alejandro St.	2.29	NA
5/10/2016	76	1109 Harbor Lights Dr.	0.70	NA
5/10/2016	81	6630 Meadowheights Dr.	1.81	NA
5/10/2016	85	302 Glenmore St.	1.18	NA
5/10/2016	90	11722 Haven Dr.	2.70	NA
5/10/2016	95	15837 El Socorro Loop	1.74	NA
5/10/2016	54 DN	3721 Seagull Blvd	0.43	NA
5/10/2016	54 UP	3933 Seagull Blvd	0.30	NA
5/11/2016	25	4101 Bascule Dr.	2.53	NA
5/11/2016	40	9550 Quetzal St.	0.49	NA
5/11/2016	54	510 St. Charles St.	1.54	NA
5/11/2016	64	4013 Hidalgo St.	2.66	NA
5/11/2016	66	635 Southern St.	1.76	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/11/2016	67	509 S. Carancahua St.	1.23	NA
5/11/2016	69	4013 Donaho Dr.	1.53	NA
5/11/2016	74	7910 Impala Dr.	2.23	NA
5/11/2016	76	1109 Harbor Lights Dr.	0.77	NA
5/11/2016	78	7602 Timber Crest Dr.	3.21	NA
5/11/2016	83	4101 Summit Dr.	0.60	NA
5/11/2016	85	302 Glenmore St.	1.15	NA
5/11/2016	91	2713 Wind Rock Dr.	3.48	NA
5/11/2016	98	15806 Almeria Ave.	2.87	NA
5/12/2016	4	14233 Playa del Rey	3.02	NA
5/12/2016	6	1213 10th St.	1.39	NA
5/12/2016	20	3901 Cott St.	2.74	NA
5/12/2016	22	6713 Weber Rd.	1.70	NA
5/12/2016	27	2823 S Port Ave.	2.77	NA
5/12/2016	40	9550 Quetzal St.	2.59	NA
5/12/2016	40	9550 Quetzal St.	0.47	NA
5/12/2016	40	9550 Quetzal St.	0.18	NA
5/12/2016	54	510 St. Charles St.	1.15	NA
5/12/2016	54	510 St. Charles St.	1.27	NA
5/12/2016	67	509 S. Carancahua St.	1.85	NA
5/12/2016	67	509 S. Carancahua St.	2.01	NA
5/12/2016	76	1109 Harbor Lights Dr.	1.02	NA
5/12/2016	76	1109 Harbor Lights Dr.	0.86	NA
5/12/2016	83	4101 Summit Dr.	1.48	NA
5/12/2016	83	4101 Summit Dr.	1.81	NA
5/12/2016	84	3640 Flour Bluff Dr.	2.49	NA
5/12/2016	85	302 Glenmore St.	0.67	NA
5/12/2016	85	302 Glenmore St.	0.60	NA
5/12/2016	89	3814 Castle Ridge Dr.	2.92	NA
5/12/2016	99	3926 Elvis Dr.	2.48	NA
5/13/2016	39	5929 Long Creek Dr.	2.07	NA
5/13/2016	40	9550 Quetzal St.	1.50	NA
5/13/2016	40	9550 Quetzal St.	0.27	NA
5/13/2016	40	9550 Quetzal St.	0.21	NA
5/13/2016	40	9550 Quetzal St.	0.75	NA
5/13/2016	54	510 St. Charles St.	0.99	NA
5/13/2016	70	1633 E. Manor Dr.	2.14	NA
5/13/2016	75	2938 Oso Pkwy	3.06	NA
5/13/2016	76	1109 Harbor Lights Dr.	0.87	NA
5/13/2016	77	5018 Cape Ann Dr.	1.16	NA
5/13/2016	83	4101 Summit Dr.	1.58	NA
5/13/2016	85	302 Glenmore St.	0.67	NA
5/13/2016	85	302 Glenmore St.	0.91	NA
5/13/2016	85	302 Glenmore St.	0.64	NA
5/13/2016	94	15209 Caravel Dr.	2.68	NA
5/13/2016	99	3926 Elvis Dr.	2.93	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/13/2016	99 DN	3925 Elvis Dr.	2.70	NA
5/13/2016	99 UP	3925 Priscilla Dr.	2.79	NA
5/14/2016	7	617 Carmel Pkwy	1.61	NA
5/14/2016	11	534 Military Dr.	2.11	NA
5/14/2016	15	6130 Parkway Dr.	1.88	NA
5/14/2016	18	902 Nueces Bay Blvd.	2.59	NA
5/14/2016	19	1301 Horne Rd.	2.53	NA
5/14/2016	32	4901 Hakeel Dr.	2.13	NA
5/14/2016	38	7525 Annemasse St.	2.92	NA
5/14/2016	40	9550 Quetzal St.	2.52	NA
5/14/2016	40	9550 Quetzal St.	2.44	NA
5/14/2016	40	9550 Quetzal St.	2.30	NA
5/14/2016	45	15222 Cruiser St.	3.23	NA
5/14/2016	47	8121 Barrogate Dr.	3.24	NA
5/14/2016	54	510 St. Charles St.	1.30	NA
5/14/2016	54	510 St. Charles St.	1.39	NA
5/14/2016	54	510 St. Charles St.	1.40	NA
5/14/2016	62	5809 Hampshire Rd.	3.24	NA
5/14/2016	67	509 S. Carancahua St.	0.54	NA
5/14/2016	67	509 S. Carancahua St.	0.51	NA
5/14/2016	75	2938 Oso Pkwy	2.97	NA
5/14/2016	76	1109 Harbor Lights Dr.	0.95	NA
5/14/2016	76	1109 Harbor Lights Dr.	0.75	NA
5/14/2016	76	1109 Harbor Lights Dr.	0.60	NA
5/14/2016	77	5018 Cape Ann Dr.	1.37	NA
5/14/2016	80	7042 Arapahoe St.	2.92	NA
5/14/2016	83	4101 Summit Dr.	1.51	NA
5/14/2016	83	4101 Summit Dr.	1.43	NA
5/14/2016	85	302 Glenmore St.	0.52	NA
5/14/2016	85	302 Glenmore St.	0.63	NA
5/14/2016	85	302 Glenmore St.	0.68	NA
5/14/2016	85	302 Glenmore St.	1.05	NA
5/14/2016	85	302 Glenmore St.	0.77	NA
5/14/2016	87	5226 Northwest Trl.	3.17	NA
5/15/2016	7	617 Carmel Pkwy	0.51	NA
5/15/2016	11	534 Military Dr.	2.18	NA
5/15/2016	15	6130 Parkway Dr.	1.22	NA
5/15/2016	18	902 Nueces Bay Blvd.	2.86	NA
5/15/2016	19	1301 Horne Rd.	2.07	NA
5/15/2016	32	4901 Hakeel Dr.	1.54	NA
5/15/2016	38	7525 Annemasse St.	2.89	NA
5/15/2016	40	9550 Quetzal St.	1.96	NA
5/15/2016	45	15222 Cruiser St.	3.45	NA
5/15/2016	47	8121 Barrogate Dr.	3.10	NA
5/15/2016	54	510 St. Charles St.	1.05	NA
5/15/2016	54	510 St. Charles St.	1.07	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/15/2016	54	510 St. Charles St.	0.49	NA
5/15/2016	62	5809 Hampshire Rd.	2.98	NA
5/15/2016	67	509 S. Carancahua St.	2.15	NA
5/15/2016	67	509 S. Carancahua St.	1.93	NA
5/15/2016	75	2938 Oso Pkwy	2.81	NA
5/15/2016	76	1109 Harbor Lights Dr.	0.53	NA
5/15/2016	76	1109 Harbor Lights Dr.	0.62	NA
5/15/2016	76	1109 Harbor Lights Dr.	1.77	NA
5/15/2016	77	5018 Cape Ann Dr.	0.83	NA
5/15/2016	80	7042 Arapahoe St.	2.80	NA
5/15/2016	83	4101 Summit Dr.	1.59	NA
5/15/2016	83	4101 Summit Dr.	1.82	NA
5/15/2016	85	302 Glenmore St.	0.58	NA
5/15/2016	85	302 Glenmore St.	0.65	NA
5/15/2016	87	5226 Northwest Trl.	3.26	NA
5/16/2016	2	5809 St. Andrews Dr.	1.80	NA
5/16/2016	7	617 Carmel Pkwy	0.66	NA
5/16/2016	11	534 Military Dr.	2.29	NA
5/16/2016	12	2219 Buford Ave.	2.74	NA
5/16/2016	15	6130 Parkway Dr.	1.29	NA
5/16/2016	18	902 Nueces Bay Blvd.	2.97	NA
5/16/2016	19	1301 Horne Rd.	2.36	NA
5/16/2016	19	1301 Horne Rd.	2.50	NA
5/16/2016	32	4901 Hakel Dr.	1.84	NA
5/16/2016	35	4702 Congressional Dr.	1.86	NA
5/16/2016	38	7525 Annemasse St.	3.13	NA
5/16/2016	40	9550 Quetzal St.	1.79	NA
5/16/2016	40	9550 Quetzal St.	1.82	NA
5/16/2016	45	15222 Cruiser St.	3.45	NA
5/16/2016	47	8121 Barrogate Dr.	3.13	NA
5/16/2016	54	510 St. Charles St.	0.92	NA
5/16/2016	54	510 St. Charles St.	0.87	NA
5/16/2016	56	202 Amistad St.	1.07	NA
5/16/2016	62	5809 Hampshire Rd.	3.18	NA
5/16/2016	67	509 S. Carancahua St.	1.14	NA
5/16/2016	67	509 S. Carancahua St.	0.96	NA
5/16/2016	75	2938 Oso Pkwy	2.78	NA
5/16/2016	76	1109 Harbor Lights Dr.	2.52	NA
5/16/2016	76	1109 Harbor Lights Dr.	1.89	NA
5/16/2016	76	1109 Harbor Lights Dr.	1.53	NA
5/16/2016	77	5018 Cape Ann Dr.	0.64	NA
5/16/2016	80	7042 Arapahoe St.	2.93	NA
5/16/2016	80	7042 Arapahoe St.	2.79	NA
5/16/2016	82	2101 Whispering Oak Dr.	2.19	NA
5/16/2016	83	4101 Summit Dr.	1.48	NA
5/16/2016	83	4101 Summit Dr.	1.49	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/16/2016	85	302 Glenmore St.	0.52	NA
5/16/2016	85	302 Glenmore St.	0.89	NA
5/16/2016	85	302 Glenmore St.	0.92	NA
5/16/2016	87	5226 Northwest Trl.	3.58	NA
5/16/2016	92	334 Wildwood Dr.	3.53	NA
5/16/2016	96	14926 Windward Dr.	2.61	NA
5/17/2016	3	3013 S. Fork Dr.	1.99	NA
5/17/2016	7	617 Carmel Pkwy	0.44	NA
5/17/2016	7	617 Carmel Pkwy	0.65	NA
5/17/2016	7	617 Carmel Pkwy	0.75	NA
5/17/2016	7	617 Carmel Pkwy	0.56	NA
5/17/2016	7	617 Carmel Pkwy	1.03	NA
5/17/2016	10	3146 Saratoga Blvd.	1.52	NA
5/17/2016	34	4341 Harry St.	1.47	NA
5/17/2016	37	6502 Brockhampton St.	2.87	NA
5/17/2016	40	9550 Quetzal St.	2.36	NA
5/17/2016	43	245 Caribbean Dr.	2.41	NA
5/17/2016	44	9602 Wilkins Dr.	3.29	NA
5/17/2016	50	5534 IH 37 Access Rd.	3.32	NA
5/17/2016	54	510 St. Charles St.	0.87	NA
5/17/2016	54	510 St. Charles St.	0.88	NA
5/17/2016	57	1409 Arlington Dr.	1.37	NA
5/17/2016	67	509 S. Carancahua St.	1.05	NA
5/17/2016	76	1109 Harbor Lights Dr.	1.39	NA
5/17/2016	76	1109 Harbor Lights Dr.	1.55	NA
5/17/2016	77	5018 Cape Ann Dr.	0.78	NA
5/17/2016	77	5018 Cape Ann Dr.	0.44	NA
5/17/2016	77	5018 Cape Ann Dr.	0.36	NA
5/17/2016	83	4101 Summit Dr.	1.86	NA
5/17/2016	85	302 Glenmore St.	1.10	NA
5/17/2016	85	302 Glenmore St.	1.68	NA
5/17/2016	97	13902 Skysail St.	2.94	NA
5/18/2016	4	14233 Playa del Rey	3.39	NA
5/18/2016	4	14233 Playa del Rey	3.43	NA
5/18/2016	5	4609 Evelyn St.	2.04	NA
5/18/2016	7	617 Carmel Pkwy	1.03	NA
5/18/2016	7	617 Carmel Pkwy	0.36	NA
5/18/2016	7	617 Carmel Pkwy	1.67	NA
5/18/2016	7	617 Carmel Pkwy	1.62	NA
5/18/2016	7	617 Carmel Pkwy	1.63	NA
5/18/2016	7	617 Carmel Pkwy	1.62	NA
5/18/2016	7	617 Carmel Pkwy	1.28	NA
5/18/2016	7	617 Carmel Pkwy	1.28	NA
5/18/2016	9	1000 International Dr.	2.94	NA
5/18/2016	11	534 Military Dr.	1.64	NA
5/18/2016	12	2219 Buford Ave.	1.93	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/18/2016	13	1505 6th St.	1.66	NA
5/18/2016	15	6130 Parkway Dr.	1.65	NA
5/18/2016	15	6130 Parkway Dr.	1.69	NA
5/18/2016	19	1301 Horne Rd.	2.55	NA
5/18/2016	21	913 Lum Ave.	1.18	NA
5/18/2016	21	913 Lum Ave.	1.23	NA
5/18/2016	23	5506 Wooldridge Rd.	1.98	NA
5/18/2016	24	2342 Rodd Field Rd.	2.84	NA
5/18/2016	28	1718 Bois d Arc Pl.	2.81	NA
5/18/2016	29	1601 La Joya St.	3.06	NA
5/18/2016	30	3100 Brawner Pkwy	1.02	NA
5/18/2016	32	4901 Hakel Dr.	2.48	NA
5/18/2016	33	3913 Ocean Dr.	1.69	NA
5/18/2016	36	1338 Sandstone Dr.	1.20	NA
5/18/2016	39	5929 Long Creek Dr.	1.60	NA
5/18/2016	41	1609 Amber St.	2.28	NA
5/18/2016	42	753 Orleans Dr.	1.65	NA
5/18/2016	43	245 Caribbean Dr.	1.47	NA
5/18/2016	45	15222 Cruiser St.	1.65	NA
5/18/2016	45	15222 Cruiser St.	1.69	NA
5/18/2016	46	8903 McNorton Rd.	3.54	NA
5/18/2016	47	8121 Barrogate Dr.	3.26	NA
5/18/2016	48	1237 Southern Minerals Rd.	3.70	NA
5/18/2016	49	113 Commerce St.	2.63	NA
5/18/2016	52	221 Junior Beck Dr.	2.31	NA
5/18/2016	56	202 Amistad St.	2.10	NA
5/18/2016	56	202 Amistad St.	1.96	NA
5/18/2016	63	2314 Summers St.	1.20	NA
5/18/2016	65	726 Westchester Dr.	2.20	NA
5/18/2016	66	635 Southern St.	2.16	NA
5/18/2016	66	635 Southern St.	0.67	NA
5/18/2016	70	1633 E. Manor Dr.	1.57	NA
5/18/2016	71	5510 Fox Run Dr.	0.96	NA
5/18/2016	75	2938 Oso Pkwy	2.54	NA
5/18/2016	77	5018 Cape Ann Dr.	0.66	NA
5/18/2016	77	5018 Cape Ann Dr.	1.07	NA
5/18/2016	77	5018 Cape Ann Dr.	1.08	NA
5/18/2016	77	5018 Cape Ann Dr.	1.27	NA
5/18/2016	77	5018 Cape Ann Dr.	1.32	NA
5/18/2016	77	5018 Cape Ann Dr.	1.14	NA
5/18/2016	79	905 Egyptian Dr.	0.97	NA
5/18/2016	79	905 Egyptian Dr.	1.07	NA
5/18/2016	85	302 Glenmore St.	1.49	NA
5/18/2016	85	302 Glenmore St.	1.49	NA
5/18/2016	85	302 Glenmore St.	1.68	NA
5/18/2016	85	302 Glenmore St.	1.10	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/18/2016	85	302 Glenmore St.	0.94	NA
5/18/2016	86	14814 Santa Gertrudis Dr.	3.11	NA
5/18/2016	92	334 Wildwood Dr.	3.55	NA
5/18/2016	94	15209 Caravel Dr.	2.39	NA
5/18/2016	94	15209 Caravel Dr.	2.47	NA
5/18/2016	95	15837 El Socorro Loop	1.70	NA
5/18/2016	96	14926 Windward Dr.	2.94	NA
5/18/2016	97	13902 Skysail St.	3.48	NA
5/18/2016	98	15806 Almeria Ave.	1.58	NA
5/19/2016	1	4810 Neptune St.	2.83	NA
5/19/2016	2	5809 St. Andrews Dr.	1.69	NA
5/19/2016	7	617 Carmel Pkwy	1.05	NA
5/19/2016	8	1126 Cornerstone Dr.	2.84	NA
5/19/2016	11	534 Military Dr.	2.11	NA
5/19/2016	14	922 Rosedale Dr.	1.31	NA
5/19/2016	16	4205 Wildcat Dr.	0.85	0.30
5/19/2016	16	4205 Wildcat Dr.	1.34	0.01
5/19/2016	16	4205 Wildcat Dr.	0.77	0.02
5/19/2016	16	4205 Wildcat Dr.	0.47	0.11
5/19/2016	16	4205 Wildcat Dr.	1.03	0.71
5/19/2016	16	4205 Wildcat Dr.	1.55	0.97
5/19/2016	16	4205 Wildcat Dr.	1.69	1.17
5/19/2016	16	4205 Wildcat Dr.	1.59	1.23
5/19/2016	18	902 Nueces Bay Blvd.	2.61	NA
5/19/2016	24	2342 Rodd Field Rd.	3.29	NA
5/19/2016	25	4101 Bascule Dr.	2.27	NA
5/19/2016	26	225 Eastgate Dr.	2.16	NA
5/19/2016	31	4306 Cedar St.	1.43	NA
5/19/2016	35	4702 Congressional Dr.	1.73	NA
5/19/2016	36	1338 Sandstone Dr.	1.01	NA
5/19/2016	38	7525 Annemasse St.	3.05	NA
5/19/2016	40	9550 Quetzal St.	2.31	NA
5/19/2016	40	9550 Quetzal St.	2.26	NA
5/19/2016	44	9602 Wilkins Dr.	3.07	0.00
5/19/2016	44	9602 Wilkins Dr.	2.99	0.00
5/19/2016	45	15222 Cruiser St.	1.83	NA
5/19/2016	51	249 Gibson Ln.	2.86	NA
5/19/2016	53	9105 Stock Dr.	2.18	NA
5/19/2016	54	510 St. Charles St.	0.86	NA
5/19/2016	54	510 St. Charles St.	0.54	NA
5/19/2016	55	514 Belden St.	1.11	NA
5/19/2016	58	4801 French Dr.	2.14	NA
5/19/2016	59	3633 Capri Dr.	2.31	NA
5/19/2016	60	1346 Calle San Marcos	1.06	NA
5/19/2016	61	234 Saratoga Blvd.	2.73	NA
5/19/2016	62	5809 Hampshire Rd.	3.07	NA

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/19/2016	64	4013 Hidalgo St.	2.75	NA
5/19/2016	66	635 Southern St.	2.78	NA
5/19/2016	67	509 S. Carancahua St.	0.70	NA
5/19/2016	69	4013 Donaho Dr.	1.14	NA
5/19/2016	71	5510 Fox Run Dr.	1.05	NA
5/19/2016	72	7717 Starnberg Lake Dr.	2.69	NA
5/19/2016	73	5649 King Trl.	3.44	NA
5/19/2016	74	7910 Impala Dr.	1.59	NA
5/19/2016	76	1109 Harbor Lights Dr.	2.03	NA
5/19/2016	77	5018 Cape Ann Dr.	0.97	NA
5/19/2016	77	5018 Cape Ann Dr.	0.69	NA
5/19/2016	77	5018 Cape Ann Dr.	0.51	NA
5/19/2016	77	5018 Cape Ann Dr.	0.50	NA
5/19/2016	77	5018 Cape Ann Dr.	0.69	NA
5/19/2016	77	5018 Cape Ann Dr.	0.45	NA
5/19/2016	78	7602 Timber Crest Dr.	3.17	NA
5/19/2016	80	7042 Arapahoe St.	2.90	NA
5/19/2016	82	2101 Whispering Oak Dr.	1.94	NA
5/19/2016	83	4101 Summit Dr.	1.14	NA
5/19/2016	83	4101 Summit Dr.	2.26	NA
5/19/2016	85	302 Glenmore St.	1.35	NA
5/19/2016	85	302 Glenmore St.	0.58	NA
5/19/2016	85	302 Glenmore St.	1.26	NA
5/19/2016	86	14814 Santa Gertrudis Dr.	3.08	0.00
5/19/2016	87	5226 Northwest Trl.	3.00	NA
5/19/2016	87	5226 Northwest Trl.	2.02	0.00
5/19/2016	87	5226 Northwest Trl.	1.60	0.05
5/19/2016	87	5226 Northwest Trl.	1.62	0.03
5/19/2016	87	5226 Northwest Trl.	0.93	0.02
5/19/2016	87	5226 Northwest Trl.	0.84	0.00
5/19/2016	88	4214 Western Dr.	3.68	NA
5/19/2016	88	4214 Western Dr.	2.06	0.06
5/19/2016	88	4214 Western Dr.	2.21	0.04
5/19/2016	88	4214 Western Dr.	2.15	0.05
5/19/2016	88	4214 Western Dr.	1.48	0.00
5/19/2016	88	4214 Western Dr.	1.72	0.00
5/19/2016	88	4214 Western Dr.	1.50	0.04
5/19/2016	88	4214 Western Dr.	1.10	0.06
5/19/2016	89	3814 Castle Ridge Dr.	2.70	0.00
5/19/2016	89	3814 Castle Ridge Dr.	2.74	0.00
5/19/2016	89	3814 Castle Ridge Dr.	2.62	0.00
5/19/2016	89	3814 Castle Ridge Dr.	2.78	0.00
5/19/2016	89	3814 Castle Ridge Dr.	2.63	0.00
5/19/2016	89	3814 Castle Ridge Dr.	2.69	0.00
5/19/2016	90	11722 Haven Dr.	2.79	1.88
5/19/2016	90	11722 Haven Dr.	1.70	0.05

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/19/2016	90	11722 Haven Dr.	1.29	0.14
5/19/2016	90	11722 Haven Dr.	1.01	0.28
5/19/2016	90	11722 Haven Dr.	1.67	0.38
5/19/2016	90	11722 Haven Dr.	1.72	0.55
5/19/2016	91	2713 Wind Rock Dr.	3.54	NA
5/19/2016	91	2713 Wind Rock Dr.	3.73	0.00
5/19/2016	91	2713 Wind Rock Dr.	3.69	0.01
5/19/2016	91	2713 Wind Rock Dr.	3.37	0.00
5/19/2016	91	2713 Wind Rock Dr.	3.36	0.00
5/19/2016	91	2713 Wind Rock Dr.	2.76	0.00
5/19/2016	91	2713 Wind Rock Dr.	2.28	0.01
5/19/2016	92	334 Wildwood Dr.	3.61	0.00
5/19/2016	92	334 Wildwood Dr.	3.60	0.00
5/19/2016	93	11025 Annville Rd.	3.72	NA
5/19/2016	93	11025 Annville Rd.	3.30	0.00
5/19/2016	93	11025 Annville Rd.	2.88	0.00
5/19/2016	93	11025 Annville Rd.	1.95	0.00
5/19/2016	93	11025 Annville Rd.	2.04	0.00
5/19/2016	93	11025 Annville Rd.	2.13	0.00
5/19/2016	93	11025 Annville Rd.	1.96	0.02
5/19/2016	93	11025 Annville Rd.	2.30	0.00
5/19/2016	93	11025 Annville Rd.	2.21	0.00
5/19/2016	94	15209 Caravel Dr.	3.06	NA
5/19/2016	96	14926 Windward Dr.	2.09	NA
5/19/2016	96	14926 Windward Dr.	2.38	NA
5/19/2016	97	13902 Skysail St.	3.04	NA
5/19/2016	98	15806 Almeria Ave.	1.72	NA
5/20/2016	2	5809 St. Andrews Dr.	2.05	0.00
5/20/2016	2	5809 St. Andrews Dr.	0.97	0.00
5/20/2016	2	5809 St. Andrews Dr.	1.20	0.00
5/20/2016	7	617 Carmel Pkwy	1.07	NA
5/20/2016	16	4205 Wildcat Dr.	2.69	2.10
5/20/2016	38	7525 Annemasse St.	2.65	0.00
5/20/2016	38	7525 Annemasse St.	2.65	0.00
5/20/2016	38	7525 Annemasse St.	2.44	0.00
5/20/2016	38	7525 Annemasse St.	2.05	0.00
5/20/2016	38	7525 Annemasse St.	2.04	0.00
5/20/2016	38	7525 Annemasse St.	1.97	0.00
5/20/2016	38	7525 Annemasse St.	1.89	0.00
5/20/2016	38	7525 Annemasse St.	1.55	0.23
5/20/2016	38	7525 Annemasse St.	1.55	0.13
5/20/2016	38	7525 Annemasse St.	1.78	0.20
5/20/2016	44	9602 Wilkins Dr.	0.28	0.15
5/20/2016	44	9602 Wilkins Dr.	0.30	0.06
5/20/2016	44	9602 Wilkins Dr.	0.36	0.00
5/20/2016	44	9602 Wilkins Dr.	0.37	0.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/20/2016	44	9602 Wilkins Dr.	0.42	0.12
5/20/2016	44	9602 Wilkins Dr.	0.50	0.38
5/20/2016	44	9602 Wilkins Dr.	0.60	0.26
5/20/2016	44	9602 Wilkins Dr.	0.81	0.41
5/20/2016	44	9602 Wilkins Dr.	0.94	0.53
5/20/2016	44	9602 Wilkins Dr.	1.03	0.50
5/20/2016	46	8903 McNorton Rd.	0.69	0.29
5/20/2016	46	8903 McNorton Rd.	0.70	0.23
5/20/2016	46	8903 McNorton Rd.	1.00	0.79
5/20/2016	46	8903 McNorton Rd.	1.31	0.94
5/20/2016	47	8121 Barrogate Dr.	1.78	0.67
5/20/2016	47	8121 Barrogate Dr.	0.89	0.19
5/20/2016	47	8121 Barrogate Dr.	0.90	0.33
5/20/2016	47	8121 Barrogate Dr.	0.45	0.14
5/20/2016	47	8121 Barrogate Dr.	0.68	0.36
5/20/2016	47	8121 Barrogate Dr.	0.84	0.43
5/20/2016	47	8121 Barrogate Dr.	0.85	0.50
5/20/2016	48	1237 Southern Minerals Rd.	0.44	0.07
5/20/2016	48	1237 Southern Minerals Rd.	0.51	0.10
5/20/2016	48	1237 Southern Minerals Rd.	0.60	0.11
5/20/2016	48	1237 Southern Minerals Rd.	0.81	0.52
5/20/2016	48	1237 Southern Minerals Rd.	0.98	0.71
5/20/2016	48	1237 Southern Minerals Rd.	1.16	0.58
5/20/2016	48	1237 Southern Minerals Rd.	1.27	0.66
5/20/2016	48	1237 Southern Minerals Rd.	1.55	0.93
5/20/2016	54	510 St. Charles St.	0.75	NA
5/20/2016	60	1346 Calle San Marcos	0.19	NA
5/20/2016	60	1346 Calle San Marcos	1.21	NA
5/20/2016	60	1346 Calle San Marcos	1.17	NA
5/20/2016	62	5809 Hampshire Rd.	0.30	0.06
5/20/2016	62	5809 Hampshire Rd.	0.32	0.06
5/20/2016	69	4013 Donaho Dr.	0.33	0.08
5/20/2016	69	4013 Donaho Dr.	0.31	0.06
5/20/2016	72	7717 Starnberg Lake Dr.	2.63	0.00
5/20/2016	72	7717 Starnberg Lake Dr.	2.51	0.00
5/20/2016	72	7717 Starnberg Lake Dr.	2.29	2.00
5/20/2016	72	7717 Starnberg Lake Dr.	2.00	1.69
5/20/2016	72	7717 Starnberg Lake Dr.	2.06	1.15
5/20/2016	72	7717 Starnberg Lake Dr.	1.99	0.64
5/20/2016	72	7717 Starnberg Lake Dr.	2.17	1.69
5/20/2016	72	7717 Starnberg Lake Dr.	2.34	0.63
5/20/2016	72	7717 Starnberg Lake Dr.	2.38	0.87
5/20/2016	72	7717 Starnberg Lake Dr.	1.12	0.24
5/20/2016	73	5649 King Trl.	2.46	0.10
5/20/2016	73	5649 King Trl.	2.65	0.24
5/20/2016	73	5649 King Trl.	2.85	0.35

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/20/2016	73	5649 King Trl.	2.68	0.22
5/20/2016	73	5649 King Trl.	2.97	0.32
5/20/2016	73	5649 King Trl.	2.34	0.30
5/20/2016	73	5649 King Trl.	1.88	0.18
5/20/2016	74	7910 Impala Dr.	2.29	0.00
5/20/2016	74	7910 Impala Dr.	2.36	0.00
5/20/2016	74	7910 Impala Dr.	2.07	0.00
5/20/2016	74	7910 Impala Dr.	2.07	0.00
5/20/2016	74	7910 Impala Dr.	1.92	0.00
5/20/2016	74	7910 Impala Dr.	1.75	0.00
5/20/2016	76	1109 Harbor Lights Dr.	2.34	NA
5/20/2016	77	5018 Cape Ann Dr.	0.79	NA
5/20/2016	77	5018 Cape Ann Dr.	0.53	NA
5/20/2016	78	7602 Timber Crest Dr.	2.95	0.00
5/20/2016	78	7602 Timber Crest Dr.	2.78	2.28
5/20/2016	78	7602 Timber Crest Dr.	2.80	0.27
5/20/2016	78	7602 Timber Crest Dr.	2.39	1.75
5/20/2016	78	7602 Timber Crest Dr.	1.31	0.96
5/20/2016	78	7602 Timber Crest Dr.	2.68	0.81
5/20/2016	78	7602 Timber Crest Dr.	2.31	0.42
5/20/2016	78	7602 Timber Crest Dr.	2.08	0.97
5/20/2016	79	905 Egyptian Dr.	1.52	1.15
5/20/2016	80	7042 Arapahoe St.	0.66	NA
5/20/2016	80	7042 Arapahoe St.	0.51	0.54
5/20/2016	80	7042 Arapahoe St.	0.76	0.58
5/20/2016	80	7042 Arapahoe St.	0.67	0.45
5/20/2016	80	7042 Arapahoe St.	0.67	0.56
5/20/2016	80	7042 Arapahoe St.	0.72	0.07
5/20/2016	83	4101 Summit Dr.	1.50	NA
5/20/2016	85	302 Glenmore St.	0.51	NA
5/20/2016	86	14814 Santa Gertrudis Dr.	1.08	0.07
5/20/2016	86	14814 Santa Gertrudis Dr.	3.38	2.73
5/20/2016	87	5226 Northwest Trl.	1.75	1.28
5/20/2016	88	4214 Western Dr.	0.59	0.27
5/20/2016	88	4214 Western Dr.	2.24	1.78
5/20/2016	88	4214 Western Dr.	1.93	2.59
5/20/2016	88	4214 Western Dr.	2.38	2.10
5/20/2016	89	3814 Castle Ridge Dr.	1.00	0.39
5/20/2016	89	3814 Castle Ridge Dr.	0.87	0.21
5/20/2016	89	3814 Castle Ridge Dr.	0.92	0.13
5/20/2016	89	3814 Castle Ridge Dr.	0.90	0.59
5/20/2016	89	3814 Castle Ridge Dr.	0.78	0.39
5/20/2016	89	3814 Castle Ridge Dr.	0.59	0.09
5/20/2016	89	3814 Castle Ridge Dr.	0.45	0.11
5/20/2016	89	3814 Castle Ridge Dr.	0.55	0.10
5/20/2016	89	3814 Castle Ridge Dr.	0.95	0.15

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/20/2016	89	3814 Castle Ridge Dr.	0.77	0.21
5/20/2016	89	3814 Castle Ridge Dr.	0.70	0.32
5/20/2016	89	3814 Castle Ridge Dr.	0.58	0.16
5/20/2016	90	11722 Haven Dr.	2.36	0.14
5/20/2016	90	11722 Haven Dr.	2.54	0.00
5/20/2016	90	11722 Haven Dr.	2.24	0.22
5/20/2016	90	11722 Haven Dr.	1.87	0.00
5/20/2016	90	11722 Haven Dr.	1.18	0.00
5/20/2016	90	11722 Haven Dr.	0.81	0.27
5/20/2016	90	11722 Haven Dr.	0.34	0.05
5/20/2016	90	11722 Haven Dr.	2.01	0.00
5/20/2016	90	11722 Haven Dr.	1.04	0.46
5/20/2016	90	11722 Haven Dr.	0.63	0.00
5/20/2016	90	11722 Haven Dr.	0.54	0.11
5/20/2016	90	11722 Haven Dr.	0.72	0.28
5/20/2016	90	11722 Haven Dr.	0.65	0.21
5/20/2016	91	2713 Wind Rock Dr.	0.41	0.10
5/20/2016	91	2713 Wind Rock Dr.	0.24	0.08
5/20/2016	91	2713 Wind Rock Dr.	0.45	0.13
5/20/2016	91	2713 Wind Rock Dr.	0.55	0.22
5/20/2016	91	2713 Wind Rock Dr.	0.56	0.99
5/20/2016	91	2713 Wind Rock Dr.	1.01	0.70
5/20/2016	92	334 Wildwood Dr.	0.45	0.11
5/20/2016	92	334 Wildwood Dr.	0.61	0.24
5/20/2016	92	334 Wildwood Dr.	0.75	0.36
5/20/2016	92	334 Wildwood Dr.	0.91	0.55
5/20/2016	92	334 Wildwood Dr.	0.97	0.64
5/20/2016	93	11025 Annville Rd.	0.53	0.13
5/20/2016	93	11025 Annville Rd.	0.90	0.16
5/20/2016	93	11025 Annville Rd.	0.82	0.28
5/20/2016	93	11025 Annville Rd.	1.12	0.63
5/20/2016	93	11025 Annville Rd.	1.36	0.59
5/20/2016	93	11025 Annville Rd.	1.70	1.24
5/20/2016	98	15806 Almeria Ave.	2.29	NA
5/20/2016	99	3926 Elvis Dr.	2.24	0.00
5/20/2016	99	3926 Elvis Dr.	2.70	0.00
5/21/2016	1	4810 Neptune St.	1.35	1.01
5/21/2016	2	5809 St. Andrews Dr.	1.79	0.12
5/21/2016	2	5809 St. Andrews Dr.	1.78	0.15
5/21/2016	2	5809 St. Andrews Dr.	1.77	0.18
5/21/2016	2	5809 St. Andrews Dr.	1.77	0.22
5/21/2016	2	5809 St. Andrews Dr.	1.70	0.16
5/21/2016	2	5809 St. Andrews Dr.	1.60	0.29
5/21/2016	2	5809 St. Andrews Dr.	1.58	0.20
5/21/2016	2	5809 St. Andrews Dr.	1.55	0.17
5/21/2016	2	5809 St. Andrews Dr.	1.45	0.19

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/21/2016	2	5809 St. Andrews Dr.	1.30	0.19
5/21/2016	4	14233 Playa del Rey	1.88	0.96
5/21/2016	4	14233 Playa del Rey	2.07	1.10
5/21/2016	4	14233 Playa del Rey	1.88	0.75
5/21/2016	4	14233 Playa del Rey	0.87	0.88
5/21/2016	4	14233 Playa del Rey	0.64	0.23
5/21/2016	4	14233 Playa del Rey	0.51	0.21
5/21/2016	4	14233 Playa del Rey	0.98	0.78
5/21/2016	4	14233 Playa del Rey	0.87	0.48
5/21/2016	8	1126 Cornerstone Dr.	0.84	0.15
5/21/2016	8	1126 Cornerstone Dr.	0.42	0.16
5/21/2016	8	1126 Cornerstone Dr.	0.75	0.13
5/21/2016	8	1126 Cornerstone Dr.	0.35	0.23
5/21/2016	9	1000 International Dr.	1.01	0.51
5/21/2016	9	1000 International Dr.	1.02	0.54
5/21/2016	9	1000 International Dr.	1.00	0.56
5/21/2016	9	1000 International Dr.	1.01	0.56
5/21/2016	9	1000 International Dr.	1.02	0.62
5/21/2016	9	1000 International Dr.	0.95	0.43
5/21/2016	9	1000 International Dr.	1.65	1.39
5/21/2016	18	902 Nueces Bay Blvd.	0.75	0.29
5/21/2016	18	902 Nueces Bay Blvd.	0.37	0.19
5/21/2016	18	902 Nueces Bay Blvd.	0.69	0.28
5/21/2016	18	902 Nueces Bay Blvd.	0.90	0.23
5/21/2016	18	902 Nueces Bay Blvd.	0.67	0.48
5/21/2016	18	902 Nueces Bay Blvd.	0.54	0.35
5/21/2016	22	6713 Weber Rd.	0.54	0.15
5/21/2016	22	6713 Weber Rd.	0.49	0.06
5/21/2016	26	225 Eastgate Dr.	0.29	0.01
5/21/2016	26	225 Eastgate Dr.	0.36	0.38
5/21/2016	26	225 Eastgate Dr.	0.51	0.37
5/21/2016	26	225 Eastgate Dr.	0.58	0.22
5/21/2016	26	225 Eastgate Dr.	0.57	0.26
5/21/2016	26	225 Eastgate Dr.	0.53	0.31
5/21/2016	35	4702 Congressional Dr.	1.79	0.17
5/21/2016	35	4702 Congressional Dr.	1.85	0.18
5/21/2016	35	4702 Congressional Dr.	1.57	0.17
5/21/2016	35	4702 Congressional Dr.	1.52	0.09
5/21/2016	35	4702 Congressional Dr.	1.61	0.33
5/21/2016	35	4702 Congressional Dr.	1.60	0.24
5/21/2016	35	4702 Congressional Dr.	1.53	0.06
5/21/2016	35	4702 Congressional Dr.	1.49	0.15
5/21/2016	35	4702 Congressional Dr.	0.51	0.13
5/21/2016	38	7525 Annemasse St.	1.41	0.32
5/21/2016	38	7525 Annemasse St.	0.66	0.07
5/21/2016	38	7525 Annemasse St.	0.59	0.20

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/21/2016	38	7525 Annemasse St.	0.70	0.16
5/21/2016	38	7525 Annemasse St.	1.41	0.87
5/21/2016	38	7525 Annemasse St.	1.60	0.77
5/21/2016	38	7525 Annemasse St.	1.54	0.90
5/21/2016	38	7525 Annemasse St.	2.00	1.20
5/21/2016	38	7525 Annemasse St.	1.90	1.19
5/21/2016	42	753 Orleans Dr.	1.20	0.17
5/21/2016	42	753 Orleans Dr.	0.87	0.17
5/21/2016	42	753 Orleans Dr.	0.83	0.11
5/21/2016	42	753 Orleans Dr.	0.79	0.49
5/21/2016	42	753 Orleans Dr.	0.70	0.15
5/21/2016	44	9602 Wilkins Dr.	1.46	1.01
5/21/2016	47	8121 Barrogate Dr.	0.77	0.33
5/21/2016	47	8121 Barrogate Dr.	1.90	1.25
5/21/2016	48	1237 Southern Minerals Rd.	2.39	1.82
5/21/2016	49	113 Commerce St.	0.24	0.03
5/21/2016	49	113 Commerce St.	0.23	0.07
5/21/2016	49	113 Commerce St.	0.28	0.07
5/21/2016	49	113 Commerce St.	0.32	0.07
5/21/2016	49	113 Commerce St.	0.51	0.11
5/21/2016	49	113 Commerce St.	0.40	0.09
5/21/2016	49	113 Commerce St.	0.66	0.19
5/21/2016	49	113 Commerce St.	0.76	0.18
5/21/2016	49	113 Commerce St.	0.74	0.18
5/21/2016	49	113 Commerce St.	0.67	0.24
5/21/2016	49	113 Commerce St.	0.60	0.23
5/21/2016	49	113 Commerce St.	0.50	0.12
5/21/2016	50	5534 IH 37 Access Rd.	0.78	0.35
5/21/2016	50	5534 IH 37 Access Rd.	0.81	0.37
5/21/2016	50	5534 IH 37 Access Rd.	1.05	0.68
5/21/2016	50	5534 IH 37 Access Rd.	1.53	1.04
5/21/2016	51	249 Gibson Ln.	1.65	1.06
5/21/2016	51	249 Gibson Ln.	1.84	1.34
5/21/2016	52	221 Junior Beck Dr.	0.45	0.09
5/21/2016	52	221 Junior Beck Dr.	0.52	0.18
5/21/2016	52	221 Junior Beck Dr.	0.98	0.59
5/21/2016	53	9105 Stock Dr.	1.99	1.46
5/21/2016	54	510 St. Charles St.	0.44	0.11
5/21/2016	54	510 St. Charles St.	0.71	0.18
5/21/2016	54	510 St. Charles St.	0.54	0.31
5/21/2016	54	510 St. Charles St.	0.40	0.16
5/21/2016	55	514 Belden St.	0.90	0.20
5/21/2016	55	514 Belden St.	0.62	0.19
5/21/2016	55	514 Belden St.	0.65	0.27
5/21/2016	55	514 Belden St.	0.46	0.33
5/21/2016	55	514 Belden St.	0.37	0.16

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/21/2016	61	234 Saratoga Blvd.	2.39	1.89
5/21/2016	62	5809 Hampshire Rd.	1.14	0.66
5/21/2016	62	5809 Hampshire Rd.	0.90	0.62
5/21/2016	62	5809 Hampshire Rd.	1.16	0.81
5/21/2016	63	2314 Summers St.	0.94	0.30
5/21/2016	63	2314 Summers St.	0.91	0.36
5/21/2016	63	2314 Summers St.	0.91	0.60
5/21/2016	63	2314 Summers St.	0.64	0.37
5/21/2016	63	2314 Summers St.	0.47	0.15
5/21/2016	64	4013 Hidalgo St.	0.64	0.24
5/21/2016	64	4013 Hidalgo St.	0.33	0.00
5/21/2016	64	4013 Hidalgo St.	0.65	0.19
5/21/2016	64	4013 Hidalgo St.	0.47	0.19
5/21/2016	64	4013 Hidalgo St.	0.44	0.26
5/21/2016	64	4013 Hidalgo St.	0.38	0.13
5/21/2016	65	726 Westchester Dr.	0.56	0.12
5/21/2016	65	726 Westchester Dr.	2.78	2.29
5/21/2016	71	5510 Fox Run Dr.	0.80	0.09
5/21/2016	71	5510 Fox Run Dr.	1.03	0.12
5/21/2016	71	5510 Fox Run Dr.	0.94	0.08
5/21/2016	71	5510 Fox Run Dr.	1.01	0.07
5/21/2016	71	5510 Fox Run Dr.	1.05	0.11
5/21/2016	71	5510 Fox Run Dr.	1.09	0.11
5/21/2016	71	5510 Fox Run Dr.	1.12	0.13
5/21/2016	71	5510 Fox Run Dr.	1.11	0.18
5/21/2016	72	7717 Starnberg Lake Dr.	2.04	1.68
5/21/2016	73	5649 King Trl.	1.93	1.32
5/21/2016	73	5649 King Trl.	1.32	0.94
5/21/2016	74	7910 Impala Dr.	1.25	0.18
5/21/2016	74	7910 Impala Dr.	1.20	0.13
5/21/2016	74	7910 Impala Dr.	0.98	0.17
5/21/2016	74	7910 Impala Dr.	1.01	0.15
5/21/2016	74	7910 Impala Dr.	1.00	0.12
5/21/2016	74	7910 Impala Dr.	1.03	0.10
5/21/2016	78	7602 Timber Crest Dr.	2.48	2.08
5/21/2016	80	7042 Arapahoe St.	0.98	0.57
5/21/2016	80	7042 Arapahoe St.	0.48	0.08
5/21/2016	80	7042 Arapahoe St.	0.69	0.14
5/21/2016	80	7042 Arapahoe St.	0.80	0.33
5/21/2016	80	7042 Arapahoe St.	1.12	0.80
5/21/2016	80	7042 Arapahoe St.	1.11	0.36
5/21/2016	80	7042 Arapahoe St.	1.23	0.83
5/21/2016	81	6630 Meadowheights Dr.	1.67	0.26
5/21/2016	81	6630 Meadowheights Dr.	1.44	0.36
5/21/2016	81	6630 Meadowheights Dr.	1.29	0.37
5/21/2016	89	3814 Castle Ridge Dr.	0.36	0.11

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/21/2016	89	3814 Castle Ridge Dr.	1.04	0.77
5/21/2016	89	3814 Castle Ridge Dr.	1.18	0.89
5/21/2016	90	11722 Haven Dr.	0.47	0.22
5/21/2016	90	11722 Haven Dr.	1.78	1.39
5/21/2016	97	13902 Skysail St.	1.90	0.91
5/21/2016	97	13902 Skysail St.	1.71	0.84
5/21/2016	97	13902 Skysail St.	1.77	0.54
5/21/2016	97	13902 Skysail St.	0.91	0.18
5/21/2016	97	13902 Skysail St.	0.52	0.36
5/21/2016	97	13902 Skysail St.	0.42	0.16
5/21/2016	97	13902 Skysail St.	0.37	0.14
5/22/2016	2	5809 St. Andrews Dr.	1.04	0.45
5/22/2016	2	5809 St. Andrews Dr.	1.06	0.74
5/22/2016	3	3013 S. Fork Dr.	2.49	1.99
5/22/2016	4	14233 Playa del Rey	0.34	0.07
5/22/2016	4	14233 Playa del Rey	2.03	1.68
5/22/2016	5	4609 Evelyn St.	0.57	0.10
5/22/2016	5	4609 Evelyn St.	0.56	0.09
5/22/2016	5	4609 Evelyn St.	0.57	0.08
5/22/2016	5	4609 Evelyn St.	0.56	0.09
5/22/2016	5	4609 Evelyn St.	0.53	0.17
5/22/2016	10	3146 Saratoga Blvd.	0.42	0.13
5/22/2016	10	3146 Saratoga Blvd.	0.36	0.13
5/22/2016	10	3146 Saratoga Blvd.	0.31	0.04
5/22/2016	10	3146 Saratoga Blvd.	0.34	0.19
5/22/2016	10	3146 Saratoga Blvd.	0.31	0.13
5/22/2016	10	3146 Saratoga Blvd.	0.63	0.20
5/22/2016	10	3146 Saratoga Blvd.	0.46	0.24
5/22/2016	10	3146 Saratoga Blvd.	0.92	0.82
5/22/2016	15	6130 Parkway Dr.	1.03	0.65
5/22/2016	15	6130 Parkway Dr.	0.94	0.80
5/22/2016	15	6130 Parkway Dr.	0.97	0.67
5/22/2016	15	6130 Parkway Dr.	1.06	0.70
5/22/2016	18	902 Nueces Bay Blvd.	0.91	0.60
5/22/2016	18	902 Nueces Bay Blvd.	1.08	0.85
5/22/2016	19	1301 Horne Rd.	0.44	0.15
5/22/2016	19	1301 Horne Rd.	0.43	0.08
5/22/2016	19	1301 Horne Rd.	0.45	0.10
5/22/2016	19	1301 Horne Rd.	0.36	0.10
5/22/2016	19	1301 Horne Rd.	0.31	0.07
5/22/2016	19	1301 Horne Rd.	0.35	0.06
5/22/2016	19	1301 Horne Rd.	0.29	0.06
5/22/2016	19	1301 Horne Rd.	0.33	0.08
5/22/2016	19	1301 Horne Rd.	0.26	0.03
5/22/2016	19	1301 Horne Rd.	0.45	0.09
5/22/2016	19	1301 Horne Rd.	0.46	0.15

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/22/2016	19	1301 Horne Rd.	0.52	0.17
5/22/2016	19	1301 Horne Rd.	0.74	0.29
5/22/2016	22	6713 Weber Rd.	0.32	0.11
5/22/2016	22	6713 Weber Rd.	0.36	0.09
5/22/2016	22	6713 Weber Rd.	0.39	0.18
5/22/2016	22	6713 Weber Rd.	0.47	0.17
5/22/2016	22	6713 Weber Rd.	0.59	0.45
5/22/2016	22	6713 Weber Rd.	0.85	0.61
5/22/2016	22	6713 Weber Rd.	0.44	0.16
5/22/2016	23	5506 Wooldridge Rd.	1.15	0.73
5/22/2016	25	4101 Bascule Dr.	1.65	1.00
5/22/2016	25	4101 Bascule Dr.	1.23	1.02
5/22/2016	28	1718 Bois d Arc Pl.	1.48	0.81
5/22/2016	28	1718 Bois d Arc Pl.	1.24	0.46
5/22/2016	28	1718 Bois d Arc Pl.	1.25	0.64
5/22/2016	28	1718 Bois d Arc Pl.	1.15	0.60
5/22/2016	28	1718 Bois d Arc Pl.	1.12	0.60
5/22/2016	28	1718 Bois d Arc Pl.	1.18	0.76
5/22/2016	29	1601 La Joya St.	2.31	1.73
5/22/2016	30	3100 Brawner Pkwy	0.60	0.13
5/22/2016	30	3100 Brawner Pkwy	0.51	0.28
5/22/2016	30	3100 Brawner Pkwy	0.48	0.11
5/22/2016	30	3100 Brawner Pkwy	0.70	0.24
5/22/2016	30	3100 Brawner Pkwy	0.63	0.28
5/22/2016	31	4306 Cedar St.	0.41	0.13
5/22/2016	31	4306 Cedar St.	0.41	0.11
5/22/2016	31	4306 Cedar St.	0.41	0.13
5/22/2016	31	4306 Cedar St.	0.46	0.16
5/22/2016	32	4901 Hakel Dr.	0.48	0.19
5/22/2016	32	4901 Hakel Dr.	0.41	0.08
5/22/2016	32	4901 Hakel Dr.	0.41	0.13
5/22/2016	32	4901 Hakel Dr.	0.51	0.19
5/22/2016	32	4901 Hakel Dr.	0.51	0.19
5/22/2016	32	4901 Hakel Dr.	0.54	0.23
5/22/2016	32	4901 Hakel Dr.	0.42	0.10
5/22/2016	35	4702 Congressional Dr.	1.05	0.37
5/22/2016	35	4702 Congressional Dr.	1.11	0.67
5/22/2016	35	4702 Congressional Dr.	0.86	0.80
5/22/2016	35	4702 Congressional Dr.	0.90	0.49
5/22/2016	35	4702 Congressional Dr.	1.02	0.77
5/22/2016	35	4702 Congressional Dr.	1.01	0.67
5/22/2016	35	4702 Congressional Dr.	0.94	0.75
5/22/2016	37	6502 Brockhampton St.	0.69	0.24
5/22/2016	37	6502 Brockhampton St.	0.92	0.60
5/22/2016	37	6502 Brockhampton St.	1.21	1.05
5/22/2016	39	5929 Long Creek Dr.	0.90	0.69

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/22/2016	39	5929 Long Creek Dr.	0.85	0.55
5/22/2016	39	5929 Long Creek Dr.	0.96	0.81
5/22/2016	39	5929 Long Creek Dr.	0.97	0.81
5/22/2016	40	9550 Quetzal St.	0.54	0.21
5/22/2016	45	15222 Cruiser St.	1.64	1.31
5/22/2016	49	113 Commerce St.	1.46	1.00
5/22/2016	52	221 Junior Beck Dr.	0.53	0.20
5/22/2016	52	221 Junior Beck Dr.	0.82	0.42
5/22/2016	52	221 Junior Beck Dr.	0.83	0.45
5/22/2016	52	221 Junior Beck Dr.	0.79	0.43
5/22/2016	52	221 Junior Beck Dr.	0.51	0.26
5/22/2016	52	221 Junior Beck Dr.	0.41	0.09
5/22/2016	52	221 Junior Beck Dr.	0.47	0.14
5/22/2016	52	221 Junior Beck Dr.	0.79	0.44
5/22/2016	52	221 Junior Beck Dr.	0.60	0.23
5/22/2016	52	221 Junior Beck Dr.	0.35	0.04
5/22/2016	52	221 Junior Beck Dr.	0.26	0.04
5/22/2016	52	221 Junior Beck Dr.	0.29	0.05
5/22/2016	52	221 Junior Beck Dr.	0.51	0.12
5/22/2016	52	221 Junior Beck Dr.	0.25	0.07
5/22/2016	52	221 Junior Beck Dr.	0.29	0.04
5/22/2016	52	221 Junior Beck Dr.	0.29	0.06
5/22/2016	52	221 Junior Beck Dr.	0.72	0.42
5/22/2016	54	510 St. Charles St.	0.25	0.03
5/22/2016	54	510 St. Charles St.	0.26	0.10
5/22/2016	54	510 St. Charles St.	0.27	0.10
5/22/2016	54	510 St. Charles St.	0.28	0.09
5/22/2016	54	510 St. Charles St.	0.64	0.50
5/22/2016	54	510 St. Charles St.	0.56	0.18
5/22/2016	54	510 St. Charles St.	0.71	0.27
5/22/2016	59	3633 Capri Dr.	0.39	0.07
5/22/2016	59	3633 Capri Dr.	0.31	0.13
5/22/2016	59	3633 Capri Dr.	0.76	0.36
5/22/2016	59	3633 Capri Dr.	1.00	0.64
5/22/2016	59	3633 Capri Dr.	0.99	0.66
5/22/2016	59	3633 Capri Dr.	1.19	0.76
5/22/2016	60	1346 Calle San Marcos	0.29	0.04
5/22/2016	60	1346 Calle San Marcos	0.88	0.35
5/22/2016	60	1346 Calle San Marcos	1.01	0.60
5/22/2016	63	2314 Summers St.	0.26	0.00
5/22/2016	63	2314 Summers St.	0.23	0.50
5/22/2016	63	2314 Summers St.	0.27	0.06
5/22/2016	63	2314 Summers St.	0.30	0.10
5/22/2016	63	2314 Summers St.	0.33	0.06
5/22/2016	63	2314 Summers St.	0.32	0.06
5/22/2016	64	4013 Hidalgo St.	0.89	0.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/22/2016	64	4013 Hidalgo St.	1.48	0.87
5/22/2016	68	5322 Alejandro St.	1.20	0.72
5/22/2016	68	5322 Alejandro St.	1.27	0.75
5/22/2016	68	5322 Alejandro St.	1.16	0.92
5/22/2016	69	4013 Donaho Dr.	0.55	0.16
5/22/2016	69	4013 Donaho Dr.	0.66	0.21
5/22/2016	69	4013 Donaho Dr.	0.37	0.13
5/22/2016	69	4013 Donaho Dr.	0.54	0.23
5/22/2016	69	4013 Donaho Dr.	0.55	0.21
5/22/2016	69	4013 Donaho Dr.	0.60	0.28
5/22/2016	69	4013 Donaho Dr.	0.69	0.30
5/22/2016	69	4013 Donaho Dr.	0.76	0.46
5/22/2016	69	4013 Donaho Dr.	0.57	0.33
5/22/2016	71	5510 Fox Run Dr.	0.40	0.26
5/22/2016	71	5510 Fox Run Dr.	0.24	0.07
5/22/2016	71	5510 Fox Run Dr.	0.44	0.07
5/22/2016	71	5510 Fox Run Dr.	0.38	0.08
5/22/2016	74	7910 Impala Dr.	0.64	0.22
5/22/2016	74	7910 Impala Dr.	0.48	0.14
5/22/2016	74	7910 Impala Dr.	3.08	2.55
5/22/2016	75	2938 Oso Pkwy	0.55	0.11
5/22/2016	75	2938 Oso Pkwy	1.30	0.91
5/22/2016	76	1109 Harbor Lights Dr.	0.25	0.06
5/22/2016	77	5018 Cape Ann Dr.	0.14	0.02
5/22/2016	84	3640 Flour Bluff Dr.	1.08	0.61
5/22/2016	85	302 Glenmore St.	0.11	0.05
5/22/2016	94	15209 Caravel Dr.	0.50	0.11
5/22/2016	94	15209 Caravel Dr.	1.36	1.13
5/22/2016	95	15837 El Socorro Loop	0.89	0.21
5/22/2016	95	15837 El Socorro Loop	0.52	0.16
5/22/2016	96	14926 Windward Dr.	0.76	0.30
5/22/2016	96	14926 Windward Dr.	1.24	0.89
5/22/2016	96	14926 Windward Dr.	1.64	1.20
5/22/2016	97	13902 Skysail St.	1.01	0.52
5/22/2016	97	13902 Skysail St.	2.24	1.74
5/22/2016	98	15806 Almeria Ave.	0.73	0.35
5/22/2016	98	15806 Almeria Ave.	1.25	0.85
5/22/2016	99	3926 Elvis Dr.	2.13	1.59
5/23/2016	4	14233 Playa del Rey	0.81	0.37
5/23/2016	5	4609 Evelyn St.	0.45	0.12
5/23/2016	5	4609 Evelyn St.	1.79	1.41
5/23/2016	6	1213 10th St.	0.92	0.64
5/23/2016	7	617 Carmel Pkwy	0.98	0.65
5/23/2016	8	1126 Cornerstone Dr.	1.40	0.95
5/23/2016	8	1126 Cornerstone Dr.	1.80	1.21
5/23/2016	8	1126 Cornerstone Dr.	1.85	1.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/23/2016	11	534 Military Dr.	2.26	1.80
5/23/2016	12	2219 Buford Ave.	1.87	1.38
5/23/2016	13	1505 6th St.	0.76	0.30
5/23/2016	13	1505 6th St.	2.19	1.43
5/23/2016	14	922 Rosedale Dr.	0.65	0.13
5/23/2016	14	922 Rosedale Dr.	0.89	0.61
5/23/2016	14	922 Rosedale Dr.	1.11	0.56
5/23/2016	14	922 Rosedale Dr.	1.30	0.77
5/23/2016	14	922 Rosedale Dr.	1.36	0.82
5/23/2016	14	922 Rosedale Dr.	1.37	0.98
5/23/2016	19	1301 Horne Rd.	1.29	0.41
5/23/2016	19	1301 Horne Rd.	1.05	0.60
5/23/2016	19	1301 Horne Rd.	1.38	0.86
5/23/2016	20	3901 Cott St.	1.11	0.65
5/23/2016	20	3901 Cott St.	0.69	0.43
5/23/2016	20	3901 Cott St.	0.84	0.40
5/23/2016	20	3901 Cott St.	1.05	0.68
5/23/2016	21	913 Lum Ave.	1.31	0.77
5/23/2016	22	6713 Weber Rd.	0.42	0.20
5/23/2016	22	6713 Weber Rd.	0.96	0.57
5/23/2016	22	6713 Weber Rd.	1.08	0.77
5/23/2016	24	2342 Rodd Field Rd.	2.81	2.33
5/23/2016	26	225 Eastgate Dr.	0.20	0.03
5/23/2016	26	225 Eastgate Dr.	0.67	0.26
5/23/2016	26	225 Eastgate Dr.	0.70	0.30
5/23/2016	26	225 Eastgate Dr.	0.75	0.33
5/23/2016	26	225 Eastgate Dr.	0.95	0.46
5/23/2016	26	225 Eastgate Dr.	0.86	0.51
5/23/2016	26	225 Eastgate Dr.	0.83	0.27
5/23/2016	26	225 Eastgate Dr.	0.87	0.46
5/23/2016	26	225 Eastgate Dr.	1.71	1.31
5/23/2016	27	2823 S Port Ave.	2.06	1.63
5/23/2016	30	3100 Brawner Pkwy	0.97	0.67
5/23/2016	31	4306 Cedar St.	0.30	0.05
5/23/2016	31	4306 Cedar St.	1.03	0.83
5/23/2016	31	4306 Cedar St.	0.77	0.50
5/23/2016	31	4306 Cedar St.	0.94	0.71
5/23/2016	31	4306 Cedar St.	0.73	0.33
5/23/2016	32	4901 Hakel Dr.	0.36	0.06
5/23/2016	32	4901 Hakel Dr.	0.49	0.14
5/23/2016	32	4901 Hakel Dr.	0.97	0.71
5/23/2016	33	3913 Ocean Dr.	0.22	0.05
5/23/2016	33	3913 Ocean Dr.	0.29	0.09
5/23/2016	33	3913 Ocean Dr.	0.42	0.09
5/23/2016	33	3913 Ocean Dr.	0.46	0.15
5/23/2016	33	3913 Ocean Dr.	0.44	0.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/23/2016	33	3913 Ocean Dr.	0.47	0.22
5/23/2016	33	3913 Ocean Dr.	1.29	0.86
5/23/2016	34	4341 Harry St.	0.36	0.08
5/23/2016	34	4341 Harry St.	0.39	0.22
5/23/2016	34	4341 Harry St.	0.43	0.17
5/23/2016	34	4341 Harry St.	0.99	0.58
5/23/2016	34	4341 Harry St.	1.31	0.94
5/23/2016	36	1338 Sandstone Dr.	0.28	0.10
5/23/2016	36	1338 Sandstone Dr.	0.52	0.05
5/23/2016	36	1338 Sandstone Dr.	0.42	0.18
5/23/2016	40	9550 Quetzal St.	1.82	1.00
5/23/2016	41	1609 Amber St.	1.66	0.05
5/23/2016	41	1609 Amber St.	1.30	0.90
5/23/2016	42	753 Orleans Dr.	1.30	0.89
5/23/2016	43	245 Caribbean Dr.	1.41	0.78
5/23/2016	43	245 Caribbean Dr.	1.44	0.93
5/23/2016	52	221 Junior Beck Dr.	0.45	0.10
5/23/2016	52	221 Junior Beck Dr.	0.28	0.07
5/23/2016	52	221 Junior Beck Dr.	0.24	0.04
5/23/2016	52	221 Junior Beck Dr.	0.27	0.15
5/23/2016	52	221 Junior Beck Dr.	0.87	0.61
5/23/2016	52	221 Junior Beck Dr.	1.23	1.07
5/23/2016	54	510 St. Charles St.	0.88	0.51
5/23/2016	54	510 St. Charles St.	0.82	0.51
5/23/2016	54	510 St. Charles St.	0.95	0.44
5/23/2016	54	510 St. Charles St.	0.85	0.36
5/23/2016	54	510 St. Charles St.	0.89	0.51
5/23/2016	54	510 St. Charles St.	1.14	0.66
5/23/2016	55	514 Belden St.	1.54	0.91
5/23/2016	56	202 Amistad St.	0.38	0.08
5/23/2016	56	202 Amistad St.	0.39	0.12
5/23/2016	56	202 Amistad St.	0.64	0.35
5/23/2016	56	202 Amistad St.	0.78	0.38
5/23/2016	56	202 Amistad St.	0.84	0.48
5/23/2016	56	202 Amistad St.	0.88	0.43
5/23/2016	56	202 Amistad St.	0.92	0.44
5/23/2016	56	202 Amistad St.	1.13	0.66
5/23/2016	57	1409 Arlington Dr.	1.16	0.48
5/23/2016	57	1409 Arlington Dr.	1.18	0.81
5/23/2016	58	4801 French Dr.	0.34	0.05
5/23/2016	58	4801 French Dr.	0.46	0.29
5/23/2016	58	4801 French Dr.	0.78	0.39
5/23/2016	58	4801 French Dr.	0.63	0.32
5/23/2016	58	4801 French Dr.	0.99	0.60
5/23/2016	58	4801 French Dr.	1.87	1.30
5/23/2016	63	2314 Summers St.	0.82	0.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/23/2016	63	2314 Summers St.	1.06	0.56
5/23/2016	63	2314 Summers St.	0.95	0.45
5/23/2016	63	2314 Summers St.	1.01	0.48
5/23/2016	63	2314 Summers St.	1.08	0.45
5/23/2016	63	2314 Summers St.	1.34	0.80
5/23/2016	64	4013 Hidalgo St.	1.01	0.69
5/23/2016	66	635 Southern St.	1.35	0.90
5/23/2016	67	509 S. Carancahua St.	1.15	0.64
5/23/2016	67	509 S. Carancahua St.	1.26	0.84
5/23/2016	69	4013 Donaho Dr.	0.82	0.51
5/23/2016	69	4013 Donaho Dr.	2.31	1.85
5/23/2016	70	1633 E. Manor Dr.	0.92	0.57
5/23/2016	70	1633 E. Manor Dr.	0.87	0.57
5/23/2016	70	1633 E. Manor Dr.	0.87	0.73
5/23/2016	70	1633 E. Manor Dr.	0.99	0.62
5/23/2016	71	5510 Fox Run Dr.	0.55	0.30
5/23/2016	71	5510 Fox Run Dr.	0.68	0.23
5/23/2016	71	5510 Fox Run Dr.	0.63	0.27
5/23/2016	71	5510 Fox Run Dr.	0.52	0.25
5/23/2016	71	5510 Fox Run Dr.	0.47	0.11
5/23/2016	71	5510 Fox Run Dr.	0.44	0.08
5/23/2016	71	5510 Fox Run Dr.	0.43	0.09
5/23/2016	71	5510 Fox Run Dr.	0.52	0.11
5/23/2016	71	5510 Fox Run Dr.	0.42	0.14
5/23/2016	71	5510 Fox Run Dr.	0.42	0.11
5/23/2016	71	5510 Fox Run Dr.	0.60	0.26
5/23/2016	71	5510 Fox Run Dr.	0.55	0.25
5/23/2016	71	5510 Fox Run Dr.	0.62	0.16
5/23/2016	71	5510 Fox Run Dr.	0.55	0.10
5/23/2016	71	5510 Fox Run Dr.	0.50	0.14
5/23/2016	71	5510 Fox Run Dr.	0.39	0.14
5/23/2016	71	5510 Fox Run Dr.	0.49	0.08
5/23/2016	71	5510 Fox Run Dr.	1.48	1.07
5/23/2016	76	1109 Harbor Lights Dr.	0.87	0.36
5/23/2016	76	1109 Harbor Lights Dr.	0.39	0.00
5/23/2016	76	1109 Harbor Lights Dr.	1.85	1.29
5/23/2016	77	5018 Cape Ann Dr.	0.19	0.03
5/23/2016	77	5018 Cape Ann Dr.	0.22	0.05
5/23/2016	77	5018 Cape Ann Dr.	0.30	0.06
5/23/2016	77	5018 Cape Ann Dr.	0.32	0.08
5/23/2016	77	5018 Cape Ann Dr.	0.47	0.08
5/23/2016	79	905 Egyptian Dr.	0.21	0.05
5/23/2016	79	905 Egyptian Dr.	0.27	0.05
5/23/2016	79	905 Egyptian Dr.	0.62	0.15
5/23/2016	79	905 Egyptian Dr.	0.90	0.18
5/23/2016	81	6630 Meadowheights Dr.	1.09	0.73

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/23/2016	82	2101 Whispering Oak Dr.	1.08	0.72
5/23/2016	83	4101 Summit Dr.	0.95	0.93
5/23/2016	84	3640 Flour Bluff Dr.	1.98	1.69
5/23/2016	85	302 Glenmore St.	0.14	0.04
5/23/2016	85	302 Glenmore St.	0.16	0.06
5/23/2016	85	302 Glenmore St.	0.22	0.02
5/23/2016	85	302 Glenmore St.	0.21	0.12
5/23/2016	95	15837 El Socorro Loop	0.74	0.18
5/23/2016	95	15837 El Socorro Loop	0.73	0.18
5/23/2016	95	15837 El Socorro Loop	0.40	0.02
5/23/2016	95	15837 El Socorro Loop	1.94	1.39
5/24/2016	1	4810 Neptune St.	2.79	2.45
5/24/2016	7	617 Carmel Pkwy	1.25	0.77
5/24/2016	11	534 Military Dr.	2.40	2.01
5/24/2016	15	6130 Parkway Dr.	1.26	0.72
5/24/2016	16	4205 Wildcat Dr.	3.83	3.37
5/24/2016	18	902 Nueces Bay Blvd.	2.42	1.76
5/24/2016	18	902 Nueces Bay Blvd.	2.46	2.05
5/24/2016	19	1301 Horne Rd.	2.04	1.62
5/24/2016	19	1301 Horne Rd.	2.03	1.46
5/24/2016	25	4101 Bascule Dr.	2.09	1.80
5/24/2016	26	225 Eastgate Dr.	1.27	0.91
5/24/2016	28	1718 Bois d Arc Pl.	2.46	2.12
5/24/2016	29	1601 La Joya St.	2.52	2.18
5/24/2016	32	4901 Hakeel Dr.	1.54	1.10
5/24/2016	36	1338 Sandstone Dr.	0.34	0.17
5/24/2016	36	1338 Sandstone Dr.	0.73	0.35
5/24/2016	36	1338 Sandstone Dr.	0.79	0.50
5/24/2016	38	7525 Annemasse St.	2.89	2.61
5/24/2016	40	9550 Quetzal St.	2.57	2.22
5/24/2016	45	15222 Cruiser St.	3.52	2.99
5/24/2016	46	8903 McNorton Rd.	3.16	2.68
5/24/2016	47	8121 Barrogate Dr.	2.45	2.13
5/24/2016	54	510 St. Charles St.	1.26	0.77
5/24/2016	60	1346 Calle San Marcos	0.70	0.30
5/24/2016	60	1346 Calle San Marcos	1.33	0.74
5/24/2016	62	5809 Hampshire Rd.	2.62	2.19
5/24/2016	64	4013 Hidalgo St.	2.67	2.32
5/24/2016	67	509 S. Carancahua St.	1.19	0.73
5/24/2016	75	2938 Oso Pkwy	2.89	2.66
5/24/2016	76	1109 Harbor Lights Dr.	1.33	0.85
5/24/2016	76	1109 Harbor Lights Dr.	1.20	0.76
5/24/2016	77	5018 Cape Ann Dr.	0.29	0.06
5/24/2016	77	5018 Cape Ann Dr.	0.41	0.11
5/24/2016	77	5018 Cape Ann Dr.	0.53	0.26
5/24/2016	77	5018 Cape Ann Dr.	0.70	0.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/24/2016	77	5018 Cape Ann Dr.	0.82	0.54
5/24/2016	77	5018 Cape Ann Dr.	0.96	0.60
5/24/2016	77	5018 Cape Ann Dr.	0.51	0.20
5/24/2016	77	5018 Cape Ann Dr.	1.16	0.86
5/24/2016	77	5018 Cape Ann Dr.	0.94	0.55
5/24/2016	79	905 Egyptian Dr.	0.72	0.14
5/24/2016	79	905 Egyptian Dr.	1.00	0.48
5/24/2016	79	905 Egyptian Dr.	1.19	0.66
5/24/2016	80	7042 Arapahoe St.	2.52	1.91
5/24/2016	83	4101 Summit Dr.	1.62	1.34
5/24/2016	85	302 Glenmore St.	0.24	0.05
5/24/2016	85	302 Glenmore St.	0.30	0.05
5/24/2016	85	302 Glenmore St.	0.36	0.08
5/24/2016	85	302 Glenmore St.	0.38	0.11
5/24/2016	85	302 Glenmore St.	0.46	0.15
5/24/2016	85	302 Glenmore St.	0.54	0.09
5/24/2016	85	302 Glenmore St.	0.55	0.16
5/24/2016	85	302 Glenmore St.	0.50	0.16
5/24/2016	85	302 Glenmore St.	0.52	0.16
5/24/2016	85	302 Glenmore St.	1.00	0.49
5/24/2016	85	302 Glenmore St.	1.36	0.90
5/24/2016	85	302 Glenmore St.	1.48	0.97
5/24/2016	85	302 Glenmore St.	1.24	0.81
5/24/2016	86	14814 Santa Gertrudis Dr.	2.69	2.27
5/24/2016	87	5226 Northwest Trl.	3.81	3.11
5/25/2016	4	14233 Playa del Rey	2.32	1.92
5/25/2016	7	617 Carmel Pkwy	NA	0.96
5/25/2016	37	6502 Brockhampton St.	2.20	1.47
5/25/2016	38	7525 Annemasse St.	3.14	2.82
5/25/2016	40	9550 Quetzal St.	NA	2.01
5/25/2016	45	15222 Cruiser St.	3.39	2.96
5/25/2016	54	510 St. Charles St.	1.00	0.62
5/25/2016	54	510 St. Charles St.	NA	0.77
5/25/2016	57	1409 Arlington Dr.	NA	1.62
5/25/2016	67	509 S. Carancahua St.	NA	0.82
5/25/2016	72	7717 Starnberg Lake Dr.	3.29	2.69
5/25/2016	73	5649 King Trl.	3.00	2.70
5/25/2016	74	7910 Impala Dr.	2.31	1.96
5/25/2016	76	1109 Harbor Lights Dr.	1.72	1.35
5/25/2016	76	1109 Harbor Lights Dr.	NA	0.92
5/25/2016	77	5018 Cape Ann Dr.	0.77	0.50
5/25/2016	77	5018 Cape Ann Dr.	0.76	0.48
5/25/2016	77	5018 Cape Ann Dr.	NA	0.30
5/25/2016	77	5018 Cape Ann Dr.	NA	0.52
5/25/2016	78	7602 Timber Crest Dr.	3.38	2.92
5/25/2016	80	7042 Arapahoe St.	2.45	1.88

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/25/2016	83	4101 Summit Dr.	NA	1.28
5/25/2016	85	302 Glenmore St.	0.52	0.25
5/25/2016	85	302 Glenmore St.	0.55	0.22
5/25/2016	85	302 Glenmore St.	0.80	0.49
5/25/2016	85	302 Glenmore St.	NA	0.53
5/25/2016	90	11722 Haven Dr.	NA	1.62
5/25/2016	94	15209 Caravel Dr.	2.23	1.78
5/25/2016	95	15837 El Socorro Loop	2.09	1.57
5/25/2016	96	14926 Windward Dr.	1.54	1.34
5/25/2016	97	13902 Skysail St.	3.49	3.09
5/25/2016	98	15806 Almeria Ave.	1.05	0.66
5/25/2016	99	3926 Elvis Dr.	2.98	2.77
5/26/2016	36	1338 Sandstone Dr.	NA	1.23
5/26/2016	40	9550 Quetzal St.	NA	2.27
5/26/2016	45	15222 Cruiser St.	3.10	2.63
5/26/2016	54	510 St. Charles St.	NA	1.10
5/26/2016	67	509 S. Carancahua St.	NA	1.22
5/26/2016	76	1109 Harbor Lights Dr.	2.23	1.87
5/26/2016	76	1109 Harbor Lights Dr.	NA	1.58
5/26/2016	77	5018 Cape Ann Dr.	1.09	0.73
5/26/2016	77	5018 Cape Ann Dr.	NA	0.31
5/26/2016	77	5018 Cape Ann Dr.	0.89	0.49
5/26/2016	77	5018 Cape Ann Dr.	0.89	0.49
5/26/2016	79	905 Egyptian Dr.	NA	0.53
5/26/2016	83	4101 Summit Dr.	NA	1.90
5/26/2016	85	302 Glenmore St.	1.14	0.82
5/26/2016	85	302 Glenmore St.	NA	0.45
5/27/2016	36	1338 Sandstone Dr.	NA	1.41
5/27/2016	40	9550 Quetzal St.	NA	1.55
5/27/2016	45	15222 Cruiser St.	2.83	2.31
5/27/2016	54	510 St. Charles St.	NA	1.19
5/27/2016	67	509 S. Carancahua St.	NA	0.92
5/27/2016	76	1109 Harbor Lights Dr.	2.04	1.63
5/27/2016	76	1109 Harbor Lights Dr.	NA	1.38
5/27/2016	77	5018 Cape Ann Dr.	0.85	0.58
5/27/2016	77	5018 Cape Ann Dr.	1.16	0.85
5/27/2016	77	5018 Cape Ann Dr.	0.75	0.53
5/27/2016	77	5018 Cape Ann Dr.	NA	0.85
5/27/2016	77	5018 Cape Ann Dr.	0.73	0.53
5/27/2016	79	905 Egyptian Dr.	NA	0.26
5/27/2016	79	905 Egyptian Dr.	NA	0.10
5/27/2016	79	905 Egyptian Dr.	NA	0.38
5/27/2016	79	905 Egyptian Dr.	1.42	1.10
5/27/2016	83	4101 Summit Dr.	NA	1.57
5/27/2016	85	302 Glenmore St.	1.21	0.91
5/27/2016	85	302 Glenmore St.	1.83	1.52

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/27/2016	85	302 Glenmore St.	NA	1.56
5/28/2016	7	617 Carmel Pkwy	1.42	1.08
5/28/2016	7	617 Carmel Pkwy	1.72	1.49
5/28/2016	25	4101 Bascule Dr.	1.98	1.52
5/28/2016	38	7525 Annemasse St.	2.56	2.00
5/28/2016	77	5018 Cape Ann Dr.	1.31	1.00
5/28/2016	77	5018 Cape Ann Dr.	1.39	1.15
5/28/2016	77	5018 Cape Ann Dr.	NA	1.02
5/28/2016	79	905 Egyptian Dr.	1.32	1.10
5/28/2016	79	905 Egyptian Dr.	1.48	1.16
5/28/2016	79	905 Egyptian Dr.	NA	1.18
5/28/2016	85	302 Glenmore St.	1.29	0.98
5/28/2016	85	302 Glenmore St.	1.92	1.80
5/28/2016	85	302 Glenmore St.	NA	1.59
5/28/2016	93	11025 Annville Rd.	3.25	2.93
5/28/2016	98	15806 Almeria Ave.	2.93	2.59
5/29/2016	7	617 Carmel Pkwy	1.54	1.09
5/29/2016	8	1126 Cornerstone Dr.	2.77	2.20
5/29/2016	26	225 Eastgate Dr.	1.65	1.26
5/29/2016	77	5018 Cape Ann Dr.	1.11	0.66
5/29/2016	77	5018 Cape Ann Dr.	NA	0.77
5/29/2016	77	5018 Cape Ann Dr.	1.41	0.98
5/29/2016	79	905 Egyptian Dr.	1.51	1.14
5/29/2016	79	905 Egyptian Dr.	NA	1.12
5/29/2016	85	302 Glenmore St.	1.20	1.08
5/29/2016	85	302 Glenmore St.	NA	0.75
5/29/2016	85	302 Glenmore St.	1.48	1.21
5/29/2016	86	14814 Santa Gertrudis Dr.	2.01	1.53
5/29/2016	97	13902 Skysail St.	2.87	2.57
5/30/2016	7	617 Carmel Pkwy	1.12	0.80
5/30/2016	8	1126 Cornerstone Dr.	2.49	2.20
5/30/2016	25	4101 Bascule Dr.	1.95	1.57
5/30/2016	26	225 Eastgate Dr.	1.88	1.37
5/30/2016	38	7525 Annemasse St.	2.42	2.17
5/30/2016	77	5018 Cape Ann Dr.	1.10	0.88
5/30/2016	77	5018 Cape Ann Dr.	NA	0.47
5/30/2016	77	5018 Cape Ann Dr.	0.82	0.55
5/30/2016	77	5018 Cape Ann Dr.	1.28	1.00
5/30/2016	79	905 Egyptian Dr.	1.29	0.96
5/30/2016	79	905 Egyptian Dr.	NA	0.99
5/30/2016	85	302 Glenmore St.	1.05	0.81
5/30/2016	85	302 Glenmore St.	NA	1.09
5/30/2016	86	14814 Santa Gertrudis Dr.	2.77	2.36
5/30/2016	93	11025 Annville Rd.	3.89	3.53
5/30/2016	97	13902 Skysail St.	3.51	3.12
5/30/2016	98	15806 Almeria Ave.	2.91	2.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
5/31/2016	4	14233 Playa del Rey	1.89	1.43
5/31/2016	36	1338 Sandstone Dr.	NA	1.77
5/31/2016	40	9550 Quetzal St.	NA	1.94
5/31/2016	54	510 St. Charles St.	NA	0.54
5/31/2016	67	509 S. Carancahua St.	NA	0.31
5/31/2016	76	1109 Harbor Lights Dr.	NA	1.80
5/31/2016	77	5018 Cape Ann Dr.	0.66	0.49
5/31/2016	77	5018 Cape Ann Dr.	0.61	0.32
5/31/2016	77	5018 Cape Ann Dr.	0.89	0.66
5/31/2016	77	5018 Cape Ann Dr.	1.09	0.80
5/31/2016	77	5018 Cape Ann Dr.	0.99	0.74
5/31/2016	77	5018 Cape Ann Dr.	NA	0.58
5/31/2016	77	5018 Cape Ann Dr.	0.95	0.64
5/31/2016	79	905 Egyptian Dr.	1.94	1.68
5/31/2016	79	905 Egyptian Dr.	NA	1.87
5/31/2016	83	4101 Summit Dr.	NA	1.51
5/31/2016	85	302 Glenmore St.	2.44	2.18
5/31/2016	85	302 Glenmore St.	NA	1.80
5/31/2016	93	11025 Annville Rd.	2.92	2.58

Note: A disinfectant conversion from monochloramine to free chlorine took place from 5/19/2016-5/24/2016.