



September 12-September 18, 2016 Chlorine Residuals

| Date Sampled | Site # | Address | Total Chlorine Residual (mg/L) |
|--------------|--------|-------------------------|--------------------------------|
| 9/12/2016 | 7 | 617 Carmel Pkwy. | 2.12 |
| 9/12/2016 | 79 | 905 Egyptian Dr. | 2.28 |
| 9/12/2016 | 82 | 2101 Whispering Oak Dr. | 2.31 |
| 9/12/2016 | 98 | 15806 Almeria Ave. | 2.67 |
| 9/12/2016 | 90 | 11722 Haven Dr. | 3.05 |
| 9/12/2016 | 56 | 202 Amistad St. | 2.72 |
| 9/12/2016 | 30 | 3100 Brawner Pkwy. | 2.66 |
| 9/12/2016 | 59 | 3633 Capri Dr. | 2.29 |
| 9/12/2016 | 85 | 302 Glenmore St. | 2.18 |
| 9/12/2016 | 77 | 5018 Cape Ann Dr. | 2.15 |
| 9/12/2016 | 40 | 9550 Quetzal St. | 2.58 |
| 9/12/2016 | 76 | 1109 Harbor Lights Dr. | 2.49 |
| 9/12/2016 | 54 | 510 St. Charles St. | 1.45 |
| 9/12/2016 | 54 | 510 St. Charles St. | 1.38 |
| 9/12/2016 | 54 | 510 St. Charles St. | 0.81 |
| 9/12/2016 | 54 | 510 St. Charles St. | 1.12 |
| 9/12/2016 | 54 | 510 St. Charles St. | 2.30 |
| 9/12/2016 | 54 | 510 St. Charles St. | 2.10 |
| 9/13/2016 | 93 | 11025 Annaville Rd. | 3.48 |
| 9/13/2016 | 51 | 249 Gibson Ln. | 2.72 |
| 9/13/2016 | 12 | 2219 Buford Ave. | 2.75 |
| 9/13/2016 | 60 | 1346 Calle San Marcos | 2.49 |
| 9/13/2016 | 31 | 4306 Cedar St. | 2.17 |
| 9/13/2016 | 11 | 534 Military Dr. | 2.51 |
| 9/13/2016 | 97 | 13902 Skysail St. | 2.51 |
| 9/13/2016 | 54 | 510 St. Charles St. | 1.49 |
| 9/13/2016 | 54 | 510 St. Charles St. | 1.91 |
| 9/13/2016 | 54 | 510 St. Charles St. | 2.39 |
| 9/14/2016 | 94 | 15209 Caravel Dr. | 2.36 |
| 9/14/2016 | 41 | 1609 Amber Dr. | 2.49 |
| 9/14/2016 | 75 | 2938 Oso Pkwy. | 2.51 |
| 9/14/2016 | 81 | 6630 Meadowheights Dr. | 3.16 |
| 9/14/2016 | 5 | 4609 Evelyn St. | 2.47 |
| 9/14/2016 | 67 | 509 S. Carancahua St. | 2.60 |
| 9/14/2016 | 53 | 9105 Stock Dr. | 2.79 |
| 9/14/2016 | 88 | 4214 Western Dr. | 3.47 |
| 9/14/2016 | 90 | 11722 Haven Dr. | 3.08 |
| 9/14/2016 | 47 | 8121 Barrogate Dr. | 3.28 |
| 9/14/2016 | 50 | 5534 IH 37 Access Rd. | 3.30 |

| Date Sampled | Site # | Address | Total Chlorine Residual (mg/L) |
|--------------|--------|----------------------------|--------------------------------|
| 9/14/2016 | 14 | 922 Rosedale Dr. | 2.71 |
| 9/14/2016 | 68 | 5322 Alejandro St. | 2.80 |
| 9/14/2016 | 71 | 5510 Fox Run Dr. | 3.02 |
| 9/14/2016 | 36 | 1338 Sandstone Dr. | 2.33 |
| 9/14/2016 | 45 | 15222 Cruiser St. | 2.15 |
| 9/14/2016 | 85 | 302 Glenmore St. | 2.38 |
| 9/14/2016 | 77 | 5018 Cape Ann Dr. | 1.78 |
| 9/14/2016 | 40 | 9550 Quetzal St. | 2.53 |
| 9/14/2016 | 76 | 1109 Harbor Lights Dr. | 2.67 |
| 9/14/2016 | 54 | 510 St. Charles St. | 1.86 |
| 9/14/2016 | 54 | 510 St. Charles St. | 1.84 |
| 9/14/2016 | 77 | 5018 Cape Ann Dr. | 1.75 |
| 9/15/2016 | 44 | 9602 Wilkins Dr. | 3.33 |
| 9/15/2016 | 48 | 1237 Southern Minerals Rd. | 3.34 |
| 9/15/2016 | 25 | 4101 Bascule Dr. | 2.65 |
| 9/15/2016 | 33 | 3913 Ocean Dr. | 2.49 |
| 9/15/2016 | 2 | 5809 St. Andrews Dr. | 2.74 |
| 9/15/2016 | 72 | 7717 Starnberg Lake Dr. | 2.50 |
| 9/15/2016 | 83 | 4101 Summit Dr. | 1.98 |
| 9/15/2016 | 95 | 15837 El Socorro Loop | 2.36 |
| 9/15/2016 | 54 | 510 St. Charles St. | 2.28 |
| 9/15/2016 | 77 | 5018 Cape Ann Dr. | 2.52 |
| 9/15/2016 | 85 | 302 Glenmore St. | 2.54 |
| 9/15/2016 | 2 | 5809 St. Andrews Dr. | 2.93 |
| 9/15/2016 | 72 | 7717 Starnberg Lake Dr. | 2.33 |
| 9/15/2016 | 83 | 4101 Summit Dr. | 1.97 |
| 9/15/2016 | 54 | 510 St. Charles St. | 2.49 |
| 9/15/2016 | 54 | 510 St. Charles St. | 2.27 |
| 9/15/2016 | 77 | 5018 Cape Ann Dr. | 2.33 |
| 9/16/2016 | 4 | 14233 Playa del Rey | 2.79 |
| 9/16/2016 | 84 | 3640 Flour Bluff Dr. | 2.80 |
| 9/16/2016 | 99 | 3926 Elvis Dr. | 2.74 |
| 9/16/2016 | 22 | 6713 Weber Rd. | 2.58 |
| 9/16/2016 | 20 | 3901 Cott St. | 2.75 |
| 9/16/2016 | 6 | 1213 10th St. | 2.66 |
| 9/16/2016 | 27 | 2823 S Port Ave. | 2.94 |
| 9/16/2016 | 89 | 3814 Castle Ridge Dr. | 3.01 |
| 9/16/2016 | 45 | 15222 Cruiser St. | 3.06 |
| 9/16/2016 | 42 | 753 Orleans Dr. | 2.61 |
| 9/16/2016 | 21 | 913 Lum Ave. | 2.52 |
| 9/16/2016 | 32 | 4901 Hakel Dr. | 2.52 |
| 9/16/2016 | 28 | 1718 Bois d' Arc Pl. | 2.87 |
| 9/16/2016 | 9 | 1000 International Dr. | 2.48 |
| 9/16/2016 | 49 | 113 Commerce St. | 2.86 |
| 9/16/2016 | 91 | 2713 Wind Rock Dr. | 3.34 |
| 9/16/2016 | 77 | 5018 Cape Ann Dr. | 2.40 |
| 9/16/2016 | 54 | 510 St. Charles St. | 2.34 |

| Date Sampled | Site # | Address | Total Chlorine Residual (mg/L) |
|--------------|--------|---------------------------|--------------------------------|
| 9/17/2016 | 98 | 15806 Almeria Ave. | 2.44 |
| 9/17/2016 | 38 | 7525 Annemasse St. | 2.65 |
| 9/17/2016 | 25 | 4101 Bascule Dr. | 2.79 |
| 9/17/2016 | 93 | 11025 Annville Rd. | 3.58 |
| 9/17/2016 | 77 | 5018 Cape Ann Dr. | 2.42 |
| 9/17/2016 | 54 | 510 St. Charles St. | 2.34 |
| 9/18/2016 | 97 | 13902 Skysail St. | 2.70 |
| 9/18/2016 | 8 | 1126 Cornerstone Dr. | 2.56 |
| 9/18/2016 | 26 | 225 Eastgate Dr. | 2.38 |
| 9/18/2016 | 86 | 14814 Santa Gertrudis Dr. | 2.34 |