



March 20 – March 26, 2017 Chlorine Residuals

Date Sampled	Site #	Address	Free Chlorine Residual (mg/L)
3/20/2017	4	14233 Playa del Rey	2.92
3/20/2017	3	3013 S Fork Dr.	2.49
3/20/2017	23	5506 Wooldridge Rd.	2.34
3/20/2017	29	1601 La Joya St.	2.74
3/20/2017	52	221 Junior Beck Dr.	1.79
3/20/2017	13	1505 6th St.	2.33
3/20/2017	65	726 Westchester Dr.	1.41
3/20/2017	86	14814 Santa Gertrudis Dr.	3.36
3/20/2017	83	4101 Summit Dr.	1.34
3/20/2017	11	534 Military Dr.	1.59
3/20/2017	40	9550 Quetzal St.	2.66
3/20/2017	76	1109 Harbor Lights Dr.	1.45
3/20/2017	85	302 Glenmore St.	1.27
3/20/2017	77	5018 Cape Ann Dr.	1.30
3/20/2017	54	3710 Seagull Blvd.	1.91
3/20/2017	23	5506 Wooldridge Rd.	1.96
3/20/2017	96	14926 Windward Dr.	2.64
3/20/2017	8	1126 Cornerstone Dr.	2.43
3/20/2017	70	1633 E. Manor Dr.	2.24
3/20/2017	15	6130 Parkway Dr.	2.40
3/20/2017	73	5649 King Trl.	3.46
3/20/2017	61	234 Saratoga Blvd.	2.65
3/20/2017	26	225 Eastgate Dr.	2.10
3/20/2017	87	5226 Northwest Trl.	3.41
3/20/2017	40	9550 Quetzal St.	1.47
3/21/2017	94	15209 Caravel Dr.	2.86
3/21/2017	24	2342 Rodd Field Rd.	2.41
3/21/2017	39	5929 Long Creek Dr.	1.96
3/21/2017	55	514 Belden St.	2.08
3/21/2017	18	902 Nueces Bay Blvd.	2.52
3/21/2017	1	4810 Neptune St.	1.89
3/21/2017	62	5809 Hampshire Rd.	2.38
3/21/2017	16	4205 Wildcat Dr.	2.30
3/21/2017	40	9550 Quetzal St.	1.38
3/21/2017	40	9550 Quetzal St.	1.29
3/22/2017	98	15806 Almeria Ave.	2.20
3/22/2017	74	7910 Impala Dr.	2.29
3/22/2017	78	7602 Timber Crest Dr.	1.88

Date Sampled	Site #	Address	Free Chlorine Residual (mg/L)
3/22/2017	69	4013 Donaho Dr.	1.24
3/22/2017	66	635 Southern St.	1.71
3/22/2017	64	4013 Hidalgo St.	2.27
3/22/2017	63	2314 Summers St.	1.99
3/22/2017	91	2713 Wind Rock Dr.	2.98
3/22/2017	96	14926 Windward Dr.	2.98
3/22/2017	38	7525 Annemasse St.	2.78
3/22/2017	80	7042 Arapahoe St.	2.15
3/22/2017	35	4702 Congressional Dr.	1.68
3/22/2017	58	4801 French Dr.	1.68
3/22/2017	19	1301 Horne Rd.	2.03
3/22/2017	92	334 Wildwood Dr.	2.96
3/22/2017	83	4101 Summit Dr.	1.27
3/22/2017	11	534 Military Dr.	1.93
3/22/2017	40	9550 Quetzal St.	1.30
3/22/2017	76	1109 Harbor Lights Dr.	1.42
3/22/2017	85	302 Glenmore St.	1.35
3/22/2017	77	5018 Cape Ann Dr.	1.51
3/22/2017	54	3710 Seagull Blvd.	1.86
3/22/2017	40	9550 Quetzal St.	1.28
3/23/2017	40	9550 Quetzal St.	1.23
3/23/2017	97	13902 Skysail St.	3.47
3/23/2017	43	245 Caribbean Dr.	1.39
3/23/2017	37	6502 Brockhampton St.	1.41
3/23/2017	34	4341 Harry St.	1.48
3/23/2017	10	3146 Saratoga Blvd.	2.32
3/23/2017	57	1409 Arlington Dr.	1.54
3/23/2017	46	8903 McNorton Rd.	3.14
3/23/2017	40	9550 Quetzal St.	1.57
3/24/2017	40	9550 Quetzal St.	1.67
3/24/2017	4	14233 Playa del Rey	3.22
3/24/2017	84	3640 Flour Bluff Dr.	2.87
3/24/2017	99	3926 Elvis Dr.	2.92
3/24/2017	22	6713 Weber Rd.	2.32
3/24/2017	20	3901 Cott St.	2.36
3/24/2017	6	1213 10th St.	2.02
3/24/2017	27	2823 S Port Ave.	2.44
3/24/2017	89	3814 Castle Ridge Dr.	1.66
3/24/2017	94	15209 Caravel Dr.	2.78
3/24/2017	41	1605 Amber Dr.	3.20
3/24/2017	75	2938 Oso Pkwy.	3.94
3/24/2017	81	6630 Meadowheights Dr.	2.44
3/24/2017	5	4609 Evelyn St.	2.09
3/24/2017	67	509 S. Carancahua St.	2.34
3/24/2017	53	9105 Stock Dr.	1.92
3/24/2017	88	4214 Western Dr.	3.18
3/24/2017	40	9550 Quetzal St.	1.60

Date Sampled	Site #	Address	Free Chlorine Residual (mg/L)
3/25/2017	40	9550 Quetzal St.	1.48
3/25/2017	98	15806 Almeria Ave.	2.87
3/25/2017	38	7525 Annemasse St.	2.44
3/25/2017	25	4101 Bascule Dr.	2.06
3/25/2017	93	11025 Annville Rd.	3.09
3/25/2017	40	9550 Quetzal St.	1.27
3/26/2017	40	9550 Quetzal St.	1.48
3/26/2017	97	13902 Skysail St.	2.94
3/26/2017	8	1126 Cornerstone Dr.	2.40
3/26/2017	26	225 Eastgate Dr.	2.24
3/26/2017	86	14814 Santa Gertrudis Dr.	2.32
3/26/2017	40	9550 Quetzal St.	1.48