



2019 Chlorine Residuals

January

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/1/2019	96	14900 Block of Windward Dr.	3.15
1/1/2019	38	7500 Block of Annemasse St.	3.42
1/1/2019	80	7000 Block of Arapahoe St.	3.25
1/1/2019	35	4700 Block of Congressional Dr.	3.13
1/1/2019	58	4800 Block of French Dr.	3.12
1/1/2019	19	1300 Block of Horne Rd.	3.49
1/1/2019	92	300 Block of Wildwood Dr.	3.93
1/2/2019	83	4100 Block of Summit Dr.	2.68
1/2/2019	40	9500 Block of Quetzal St.	2.53
1/2/2019	76	1100 Block of Harbor Lights Dr.	2.73
1/2/2019	85	300 Block of Glenmore St.	2.45
1/2/2019	77	5000 Block of Cape Ann Dr.	2.86
1/2/2019	97	13900 Block of Skysail St.	3.16
1/2/2019	43	200 Block of Caribbean Dr.	2.97
1/2/2019	37	6500 Block of Brockhampton St.	3.09
1/2/2019	34	4300 Block of Harry St.	3.24
1/2/2019	10	3100 Block of Saratoga Blvd.	3.20
1/2/2019	57	1400 Block of Arlington Dr.	3.37
1/2/2019	46	8900 Block of McNorton Rd.	3.74
1/2/2019	94	15200 Block of Caravel Dr.	3.12
1/2/2019	41	1600 Block of Amber Dr.	3.17
1/2/2019	75	2900 Block of Oso Pkwy.	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/2/2019	81	6600 Block of Meadowheights Dr.	3.51
1/2/2019	5	4600 Block of Evelyn St.	3.19
1/2/2019	67	500 Block of S Carancahua St.	3.46
1/2/2019	53	9100 Block of Stock Dr.	3.01
1/2/2019	88	4200 Block of Western Dr.	4.13
1/3/2019	4	14200 Block of Playa del Rey	3.16
1/3/2019	84	3600 Block of Flour Bluff Dr.	3.33
1/3/2019	99	3900 Block of Elvis Dr.	3.61
1/3/2019	22	6700 Block of Weber Rd.	3.85
1/3/2019	20	3900 Block of Cott St.	3.63
1/3/2019	6	1200 Block of 10th St.	3.28
1/3/2019	27	2800 Block of S Port Ave.	3.57
1/3/2019	89	3800 Block of Castle Ridge Dr.	3.18
1/4/2019	58	4800 Block of French Dr.	3.34
1/4/2019	95	15800 Block of El Socorro Loop	2.57
1/4/2019	59	3600 Block of Capri Dr.	3.41
1/4/2019	98	15800 Block of Almeria Ave.	2.88
1/4/2019	45	15200 Block of Cruiser St.	3.20
1/4/2019	42	700 Block of Orleans Dr.	3.06
1/4/2019	21	900 Block of Lum Ave.	3.40
1/4/2019	32	4900 Block of Hakel Dr.	3.56
1/4/2019	28	1700 Block of Bois d' Arc Pl.	3.66
1/4/2019	9	1000 Block of International Dr.	3.49
1/4/2019	49	100 Block of Commerce St.	3.49
1/4/2019	91	2700 Block of Wind Rock Dr.	3.73
1/5/2019	98	15800 Block of Almeria Ave.	3.27
1/5/2019	38	7500 Block of Annemasse St.	3.40

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/5/2019	25	4100 Block of Bascule Dr.	3.50
1/5/2019	93	11000 Block of Annville Rd.	3.94
1/6/2019	97	13900 Block of Skysail St.	3.32
1/6/2019	8	1100 Block of Cornerstone Dr.	3.41
1/6/2019	26	200 Block of Eastgate Dr.	3.36
1/6/2019	86	14800 Block of Santa Gertrudis Dr.	3.22
1/7/2019	83	4100 Block of Summit Dr.	2.55
1/7/2019	40	9500 Block of Quetzal St.	2.65
1/7/2019	76	1100 Block of Harbor Lights Dr.	2.73
1/7/2019	85	300 Block of Glenmore St.	2.60
1/7/2019	77	5000 Block of Cape Ann Dr.	2.87
1/7/2019	4	14200 Block of Playa del Rey	3.08
1/7/2019	3	3000 Block of S Fork Dr.	3.45
1/7/2019	23	5500 Block of Wooldridge Rd.	3.34
1/7/2019	29	1600 Block of La Joya St.	3.53
1/7/2019	52	200 Block of Junior Beck Dr.	4.16
1/7/2019	13	1500 Block of 6th St.	3.44
1/7/2019	65	700 Block of Westchester Dr.	3.62
1/7/2019	86	14800 Block of Santa Gertrudis Dr.	3.85
1/8/2019	96	14900 Block of Windward Dr.	2.90
1/8/2019	8	1100 Block of Cornerstone Dr.	3.47
1/8/2019	70	1600 Block of E Manor Dr.	3.79
1/8/2019	15	6100 Block of Parkway Dr.	3.60
1/8/2019	73	5600 Block of King Trl.	4.21
1/8/2019	61	200 Block of Saratoga Blvd.	4.04
1/8/2019	26	200 Block of Eastgate Dr.	3.98
1/8/2019	87	5200 Block of Northwest Trl.	3.76

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/9/2019	83	4100 Block of Summit Dr.	2.47
1/9/2019	40	9500 Block of Quetzal St.	2.96
1/9/2019	76	1100 Block of Harbor Lights Dr.	3.18
1/9/2019	85	300 Block of Glenmore St.	3.25
1/9/2019	77	5000 Block of Cape Ann Dr.	3.38
1/9/2019	94	15200 Block of Caravel Dr.	3.02
1/9/2019	24	2300 Block of Rodd Field Rd.	3.59
1/9/2019	39	5900 Block of Long Creek Dr.	3.21
1/9/2019	55	500 Block of Belden St.	3.75
1/9/2019	18	900 Block of Nueces Bay Blvd.	4.00
1/9/2019	1	4800 Block of Neptune St.	3.85
1/9/2019	62	5800 Block of Hampshire Rd.	3.96
1/9/2019	16	4200 Block of Wildcat Dr.	3.63
1/10/2019	66	600 Block of Southern St.	3.55
1/10/2019	64	4000 Block of Hidalgo St.	3.77
1/10/2019	63	2300 Block of Summers St.	3.57
1/10/2019	91	2700 Block of Wind Rock Dr.	3.67
1/10/2019	98	15800 Block of Almeria Ave.	2.84
1/10/2019	74	7900 Block of Impala Dr.	3.70
1/10/2019	78	7600 Block of Timber Crest Dr.	3.67
1/10/2019	69	4000 Block of Donaho Dr.	3.42
1/11/2019	98	15800 Block of Almeria Ave.	3.51
1/11/2019	82	2100 Block of Whispering Oak Dr.	3.42
1/11/2019	79	900 Block of Egyptian Dr.	3.23
1/11/2019	7	600 Block of Carmel Pkwy.	2.98
1/11/2019	59	3600 Block of Capri Dr.	3.42
1/11/2019	30	3100 Block of Brawner Pkwy.	3.35

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/11/2019	56	200 Block of Amistad St.	3.49
1/11/2019	90	11700 Block of Haven Dr.	3.72
1/12/2019	98	15800 Block of Almeria Ave.	2.81
1/12/2019	38	7500 Block of Annemasse St.	3.53
1/12/2019	25	4100 Block of Bascule Dr.	3.38
1/12/2019	93	11000 Block of Annaville Rd.	3.98
1/13/2019	97	13900 Block of Skysail St.	3.71
1/13/2019	8	1100 Block of Cornerstone Dr.	3.75
1/13/2019	26	200 Block of Eastgate Dr.	3.51
1/13/2019	86	14800 Block of Santa Gertrudis Dr.	3.22
1/14/2019	83	4100 Block of Summit Dr.	2.58
1/14/2019	40	9500 Block of Quetzal St.	2.68
1/14/2019	76	1100 Block of Harbor Lights Dr.	2.87
1/14/2019	85	300 Block of Glenmore St.	2.66
1/14/2019	77	5000 Block of Cape Ann Dr.	3.03
1/14/2019	97	13900 Block of Skysail St.	3.68
1/14/2019	11	500 Block of Military Dr.	3.05
1/14/2019	60	1300 Block of Calle San Marcos	3.07
1/14/2019	31	4300 Block of Cedar St.	3.17
1/14/2019	54	3700 Block of Seagull Blvd.	3.29
1/14/2019	12	2200 Block of Buford Ave.	3.43
1/14/2019	51	200 Block of Gibson Ln.	3.54
1/14/2019	93	11000 Block of Annaville Rd.	3.97
1/15/2019	45	15200 Block of Cruiser St.	3.53
1/15/2019	36	1300 Block of Sandstone Dr.	2.84
1/15/2019	71	5500 Block of Fox Run Dr.	2.94
1/15/2019	68	5300 Block of Alejandro St.	3.09

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/15/2019	14	900 Block of Rosedale Dr.	3.20
1/15/2019	50	5500 Block of IH 37 Access Rd.	3.70
1/15/2019	47	8100 Block of Barrogate Dr.	3.74
1/15/2019	90	11700 Block of Haven Dr.	3.52
1/16/2019	4	14200 Block of Playa del Rey	3.41
1/16/2019	3	3000 Block of S Fork Dr.	3.12
1/16/2019	23	5500 Block of Wooldridge Rd.	3.35
1/16/2019	29	1600 Block of La Joya St.	3.32
1/16/2019	52	200 Block of Junior Beck Dr.	3.57
1/16/2019	13	1500 Block of 6th St.	3.15
1/16/2019	65	700 Block of Westchester Dr.	3.43
1/16/2019	86	14800 Block of Santa Gertrudis Dr.	3.17
1/16/2019	83	4100 Block of Summit Dr.	2.57
1/16/2019	40	9500 Block of Quetzal St.	2.61
1/16/2019	76	1100 Block of Harbor Lights Dr.	2.61
1/16/2019	85	300 Block of Glenmore St.	2.71
1/16/2019	77	5000 Block of Cape Ann Dr.	2.95
1/16/2019	95	15800 Block of El Socorro Loop	2.62
1/16/2019	72	7700 Block of Starnberg Lake Dr.	3.45
1/16/2019	2	5800 Block of St. Andrews Dr.	3.24
1/16/2019	33	3900 Block of Ocean Dr.	3.01
1/16/2019	25	4100 Block of Bascule Dr.	3.54
1/16/2019	48	1200 Block of Southern Minerals Rd.	3.92
1/16/2019	44	9600 Block of Wilkins Dr.	3.60
1/17/2019	96	14900 Block of Windward Dr.	3.20
1/17/2019	8	1100 Block of Cornerstone Dr.	3.39
1/17/2019	70	1600 Block of E Manor Dr.	3.47

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/17/2019	15	6100 Block of Parkway Dr.	3.29
1/17/2019	73	5600 Block of King Trl.	3.68
1/17/2019	61	200 Block of Saratoga Blvd.	3.84
1/17/2019	26	200 Block of Eastgate Dr.	3.39
1/17/2019	87	5200 Block of Northwest Trl.	3.68
1/18/2019	94	15200 Block of Caravel Dr.	2.85
1/18/2019	24	2300 Block of Rodd Field Rd.	3.41
1/18/2019	39	5900 Block of Long Creek Dr.	3.11
1/18/2019	55	500 Block of Belden St.	3.57
1/18/2019	18	900 Block of Nueces Bay Blvd.	3.92
1/18/2019	1	4800 Block of Neptune St.	3.71
1/18/2019	62	5800 Block of Hampshire Rd.	3.91
1/18/2019	16	4200 Block of Wildcat Dr.	3.68
1/19/2019	98	15800 Block of Almeria Ave.	3.14
1/19/2019	38	7500 Block of Annemasse St.	3.29
1/19/2019	25	4100 Block of Bascule Dr.	3.41
1/19/2019	93	11000 Block of Annville Rd.	3.84
1/20/2019	97	13900 Block of Skysail St.	3.54
1/20/2019	8	1100 Block of Cornerstone Dr.	3.26
1/20/2019	26	200 Block of Eastgate Dr.	3.30
1/20/2019	86	14800 Block of Santa Gertrudis Dr.	3.02
1/21/2019	96	14900 Block of Windward Dr.	3.11
1/21/2019	38	7500 Block of Annemasse St.	3.12
1/21/2019	80	7000 Block of Arapahoe St.	3.26
1/21/2019	35	4700 Block of Congressional Dr.	3.44
1/21/2019	58	4800 Block of French Dr.	3.18
1/21/2019	19	1300 Block of Horne Rd.	3.25

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/21/2019	92	300 Block of Wildwood Dr.	3.92
1/21/2019	83	4100 Block of Summit Dr.	2.57
1/21/2019	40	9500 Block of Quetzal St.	2.56
1/21/2019	76	1100 Block of Harbor Lights Dr.	2.79
1/21/2019	85	300 Block of Glenmore St.	2.65
1/21/2019	77	5000 Block of Cape Ann Dr.	2.84
1/22/2019	97	13900 Block of Skysail St.	3.24
1/22/2019	43	200 Block of Caribbean Dr.	3.15
1/22/2019	37	6500 Block of Brockhampton St.	3.48
1/22/2019	34	4300 Block of Harry St.	3.08
1/22/2019	10	3100 Block of Saratoga Blvd.	3.04
1/22/2019	57	1400 Block of Arlington Dr.	3.15
1/22/2019	46	8900 Block of McNorton Rd.	3.83
1/23/2019	94	15200 Block of Caravel Dr.	2.83
1/23/2019	41	1600 Block of Amber Dr.	3.57
1/23/2019	75	2900 Block of Oso Pkwy.	3.71
1/23/2019	81	6600 Block of Meadowheights Dr.	3.58
1/23/2019	5	4600 Block of Evelyn St.	3.22
1/23/2019	67	500 Block of S Carancahua St.	3.51
1/23/2019	53	9100 Block of Stock Dr.	3.08
1/23/2019	88	4200 Block of Western Dr.	3.99
1/23/2019	83	4100 Block of Summit Dr.	2.56
1/23/2019	40	9500 Block of Quetzal St.	2.76
1/23/2019	76	1100 Block of Harbor Lights Dr.	2.94
1/23/2019	85	300 Block of Glenmore St.	2.61
1/23/2019	77	5000 Block of Cape Ann Dr.	3.02
1/24/2019	98	15800 Block of Almeria Ave.	3.33

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/24/2019	74	7900 Block of Impala Dr.	3.25
1/24/2019	78	7600 Block of Timber Crest Dr.	3.54
1/24/2019	69	4000 Block of Donaho Dr.	3.45
1/24/2019	66	600 Block of Southern St.	3.53
1/24/2019	64	4000 Block of Hidalgo St.	3.36
1/24/2019	63	2300 Block of Summers St.	3.38
1/24/2019	91	2700 Block of Wind Rock Dr.	3.43
1/24/2019	96	14900 Block of Windward Dr.	3.30
1/24/2019	3	3000 Block of S Fork Dr.	3.56
1/24/2019	29	1600 Block of La Joya St.	3.29
1/24/2019	5	4600 Block of Evelyn St.	3.26
1/24/2019	65	700 Block of Westchester Dr.	3.46
1/24/2019	13	1500 Block of 6th St.	3.32
1/24/2019	52	200 Block of Junior Beck Dr.	3.34
1/24/2019	86	14800 Block of Santa Gertrudis Dr.	3.09
1/25/2019	4	14200 Block of Playa del Rey	3.25
1/25/2019	84	3600 Block of Flour Bluff Dr.	3.14
1/25/2019	99	3900 Block of Elvis Dr.	3.31
1/25/2019	22	6700 Block of Weber Rd.	3.67
1/25/2019	20	3900 Block of Cott St.	3.50
1/25/2019	6	1200 Block of 10th St.	2.93
1/25/2019	27	2800 Block of S Port Ave.	3.75
1/25/2019	89	3800 Block of Castle Ridge Dr.	3.28
1/26/2019	98	15800 Block of Almeria Ave.	2.82
1/26/2019	38	7500 Block of Annemasse St.	3.34
1/26/2019	25	4100 Block of Bascule Dr.	3.39
1/26/2019	93	11000 Block of Annaville Rd.	3.85

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/27/2019	97	13900 Block of Skysail St.	3.29
1/27/2019	8	1100 Block of Cornerstone Dr.	3.17
1/27/2019	26	200 Block of Eastgate Dr.	3.45
1/27/2019	86	14800 Block of Santa Gertrudis Dr.	3.26
1/28/2019	4	14200 Block of Playa del Rey	3.19
1/28/2019	41	1600 Block of Amber Dr.	2.94
1/28/2019	67	500 Block of S Carancahua St.	3.69
1/28/2019	88	4200 Block of Western Dr.	3.89
1/28/2019	83	4100 Block of Summit Dr.	2.60
1/28/2019	40	9500 Block of Quetzal St.	2.57
1/28/2019	76	1100 Block of Harbor Lights Dr.	2.53
1/28/2019	85	300 Block of Glenmore St.	2.37
1/28/2019	77	5000 Block of Cape Ann Dr.	2.70
1/28/2019	45	15200 Block of Cruiser St.	2.79
1/28/2019	42	700 Block of Orleans Dr.	3.33
1/28/2019	21	900 Block of Lum Ave.	3.54
1/28/2019	32	4900 Block of Hakel Dr.	3.62
1/28/2019	28	1700 Block of Bois d' Arc Pl.	3.75
1/28/2019	9	1000 Block of International Dr.	3.59
1/28/2019	49	100 Block of Commerce St.	3.62
1/28/2019	91	2700 Block of Wind Rock Dr.	3.60
1/29/2019	98	15800 Block of Almeria Ave.	2.70
1/29/2019	82	2100 Block of Whispering Oak Dr.	3.14
1/29/2019	79	900 Block of Egyptian Dr.	3.31
1/29/2019	7	600 Block of Carmel Pkwy.	3.03
1/29/2019	59	3600 Block of Capri Dr.	3.30
1/29/2019	30	3100 Block of Brawner Pkwy.	3.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/29/2019	56	200 Block of Amistad St.	3.20
1/29/2019	90	11700 Block of Haven Dr.	3.39
1/29/2019	97	13900 Block of Skysail St.	3.12
1/29/2019	11	500 Block of Military Dr.	2.50
1/29/2019	60	1300 Block of Calle San Marcos	3.17
1/29/2019	31	4300 Block of Cedar St.	3.22
1/29/2019	54	3700 Block of Seagull Blvd.	3.26
1/29/2019	12	2200 Block of Buford Ave.	3.43
1/29/2019	51	200 Block of Gibson Ln.	3.48
1/29/2019	93	11000 Block of Annville Rd.	4.00
1/30/2019	45	15200 Block of Cruiser St.	3.33
1/30/2019	36	1300 Block of Sandstone Dr.	3.16
1/30/2019	71	5500 Block of Fox Run Dr.	3.19
1/30/2019	68	5300 Block of Alejandro St.	3.51
1/30/2019	14	900 Block of Rosedale Dr.	3.39
1/30/2019	50	5500 Block of IH 37 Access Rd.	4.09
1/30/2019	47	8100 Block of Barrogate Dr.	4.29
1/30/2019	90	11700 Block of Haven Dr.	3.82
1/30/2019	95	15800 Block of El Socorro Loop	2.55
1/30/2019	72	7700 Block of Starnberg Lake Dr.	3.42
1/30/2019	2	5800 Block of St. Andrews Dr.	2.78
1/30/2019	33	3900 Block of Ocean Dr.	3.19
1/30/2019	25	4100 Block of Bascule Dr.	3.51
1/30/2019	48	1200 Block of Southern Minerals Rd.	4.20
1/30/2019	44	9600 Block of Wilkins Dr.	3.88
1/30/2019	83	4100 Block of Summit Dr.	2.45
1/30/2019	40	9500 Block of Quetzal St.	2.87

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/30/2019	76	1100 Block of Harbor Lights Dr.	2.83
1/30/2019	85	300 Block of Glenmore St.	2.72
1/30/2019	77	5000 Block of Cape Ann Dr.	2.74
1/31/2019	95	15800 Block of El Socorro Loop	2.38
1/31/2019	23	5500 Block of Wooldridge Rd.	3.22
1/31/2019	55	500 Block of Belden St.	3.79
1/31/2019	86	14800 Block of Santa Gertrudis Dr.	3.47

February

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/1/2019	58	4800 Block of French Dr.	3.35
2/1/2019	95	15800 Block of El Socorro Loop	2.79
2/1/2019	59	3600 Block of Capri Dr.	3.25
2/1/2019	98	15800 Block of Almeria Ave.	2.61
2/1/2019	97	13900 Block of Skysail St.	3.23
2/1/2019	11	500 Block of Military Dr.	2.60
2/1/2019	60	1300 Block of Calle San Marcos	3.19
2/1/2019	31	4300 Block of Cedar St.	3.26
2/1/2019	54	3700 Block of Seagull Blvd.	3.40
2/1/2019	12	2200 Block of Buford Ave.	3.79
2/1/2019	51	200 Block of Gibson Ln.	3.89
2/1/2019	93	11000 Block of Annville Rd.	4.14
2/2/2019	98	15800 Block of Almeria Ave.	3.37
2/2/2019	38	7500 Block of Annemasse St.	3.73
2/2/2019	25	4100 Block of Bascule Dr.	3.70
2/2/2019	93	11000 Block of Annville Rd.	4.03

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/3/2019	97	13900 Block of Skysail St.	3.35
2/3/2019	8	1100 Block of Cornerstone Dr.	3.45
2/3/2019	26	200 Block of Eastgate Dr.	3.60
2/3/2019	86	14800 Block of Santa Gertrudis Dr.	3.45
2/4/2019	45	15200 Block of Cruiser St.	3.38
2/4/2019	36	1300 Block of Sandstone Dr.	3.00
2/4/2019	71	5500 Block of Fox Run Dr.	3.43
2/4/2019	68	5300 Block of Alejandro St.	3.45
2/4/2019	14	900 Block of Rosedale Dr.	3.24
2/4/2019	50	5500 Block of IH 37 Access Rd.	4.04
2/4/2019	47	8100 Block of Barrogate Dr.	4.32
2/4/2019	90	11700 Block of Haven Dr.	3.83
2/4/2019	83	4100 Block of Summit Dr.	2.36
2/4/2019	83	4100 Block of Summit Dr.	2.60
2/4/2019	40	9500 Block of Quetzal St.	2.83
2/4/2019	76	1100 Block of Harbor Lights Dr.	2.95
2/4/2019	85	300 Block of Glenmore St.	2.66
2/4/2019	77	5000 Block of Cape Ann Dr.	2.98
2/5/2019	20	3900 Block of Cott St.	3.81
2/5/2019	6	1200 Block of 10th St.	3.25
2/5/2019	27	2800 Block of S Port Ave.	3.56
2/5/2019	89	3800 Block of Castle Ridge Dr.	3.32
2/5/2019	4	14200 Block of Playa del Rey	3.44
2/5/2019	84	3600 Block of Flour Bluff Dr.	3.50
2/5/2019	99	3900 Block of Elvis Dr.	4.03
2/5/2019	22	6700 Block of Weber Rd.	3.70
2/6/2019	95	15800 Block of El Socorro Loop	2.53

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/6/2019	72	7700 Block of Starnberg Lake Dr.	3.44
2/6/2019	2	5800 Block of St. Andrews Dr.	3.00
2/6/2019	33	3900 Block of Ocean Dr.	3.19
2/6/2019	25	4100 Block of Bascule Dr.	3.63
2/6/2019	48	1200 Block of Southern Minerals Rd.	3.89
2/6/2019	44	9600 Block of Wilkins Dr.	3.60
2/6/2019	83	4100 Block of Summit Dr.	2.37
2/6/2019	40	9500 Block of Quetzal St.	2.91
2/6/2019	76	1100 Block of Harbor Lights Dr.	3.05
2/6/2019	85	300 Block of Glenmore St.	3.01
2/6/2019	77	5000 Block of Cape Ann Dr.	3.09
2/6/2019	28	1700 Block of Bois d' Arc Pl.	3.67
2/6/2019	9	1000 Block of International Dr.	3.53
2/6/2019	49	100 Block of Commerce St.	3.67
2/6/2019	91	2700 Block of Wind Rock Dr.	3.66
2/6/2019	45	15200 Block of Cruiser St.	2.82
2/6/2019	42	700 Block of Orleans Dr.	3.50
2/6/2019	21	900 Block of Lum Ave.	3.28
2/6/2019	32	4900 Block of Hakel Dr.	3.45
2/7/2019	59	3600 Block of Capri Dr.	3.26
2/7/2019	30	3100 Block of Brawner Pkwy.	3.31
2/7/2019	56	200 Block of Amistad St.	3.32
2/7/2019	90	11700 Block of Haven Dr.	3.68
2/7/2019	98	15800 Block of Almeria Ave.	3.00
2/7/2019	82	2100 Block of Whispering Oak Dr.	3.16
2/7/2019	79	900 Block of Egyptian Dr.	3.05
2/7/2019	7	600 Block of Carmel Pkwy.	2.98

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/7/2019	4	14200 Block of Playa del Rey	3.41
2/7/2019	3	3000 Block of S Fork Dr.	3.51
2/7/2019	23	5500 Block of Wooldridge Rd.	3.32
2/7/2019	29	1600 Block of La Joya St.	3.19
2/7/2019	52	200 Block of Junior Beck Dr.	3.50
2/7/2019	13	1500 Block of 6th St.	3.33
2/7/2019	65	700 Block of Westchester Dr.	3.51
2/7/2019	86	14800 Block of Santa Gertrudis Dr.	3.24
2/8/2019	96	14900 Block of Windward Dr.	3.07
2/8/2019	8	1100 Block of Cornerstone Dr.	3.24
2/8/2019	70	1600 Block of E Manor Dr.	3.37
2/8/2019	15	6100 Block of Parkway Dr.	3.48
2/8/2019	73	5600 Block of King Trl.	3.57
2/8/2019	61	200 Block of Saratoga Blvd.	3.63
2/8/2019	26	200 Block of Eastgate Dr.	3.44
2/8/2019	87	5200 Block of Northwest Trl.	3.50
2/9/2019	98	15800 Block of Almeria Ave.	2.89
2/9/2019	38	7500 Block of Annemasse St.	3.33
2/9/2019	25	4100 Block of Bascule Dr.	3.44
2/9/2019	93	11000 Block of Annville Rd.	3.98
2/10/2019	97	13900 Block of Skysail St.	3.49
2/10/2019	8	1100 Block of Cornerstone Dr.	3.42
2/10/2019	26	200 Block of Eastgate Dr.	3.53
2/10/2019	86	14800 Block of Santa Gertrudis Dr.	3.23
2/11/2019	83	4100 Block of Summit Dr.	2.66
2/11/2019	40	9500 Block of Quetzal St.	2.79
2/11/2019	76	1100 Block of Harbor Lights Dr.	2.82

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/11/2019	85	300 Block of Glenmore St.	2.79
2/11/2019	77	5000 Block of Cape Ann Dr.	2.93
2/11/2019	94	15200 Block of Caravel Dr.	3.00
2/11/2019	24	2300 Block of Rodd Field Rd.	3.19
2/11/2019	39	5900 Block of Long Creek Dr.	2.98
2/11/2019	55	500 Block of Belden St.	3.69
2/11/2019	18	900 Block of Nueces Bay Blvd.	4.11
2/11/2019	1	4800 Block of Neptune St.	3.96
2/11/2019	62	5800 Block of Hampshire Rd.	3.93
2/11/2019	16	4200 Block of Wildcat Dr.	3.95
2/11/2019	98	15800 Block of Almeria Ave.	2.71
2/11/2019	74	7900 Block of Impala Dr.	2.98
2/11/2019	78	7600 Block of Timber Crest Dr.	3.09
2/11/2019	69	4000 Block of Donaho Dr.	3.79
2/11/2019	66	600 Block of Southern St.	3.58
2/11/2019	64	4000 Block of Hidalgo St.	3.68
2/11/2019	63	2300 Block of Summers St.	3.85
2/11/2019	91	2700 Block of Wind Rock Dr.	3.31
2/12/2019	96	14900 Block of Windward Dr.	3.00
2/12/2019	38	7500 Block of Annemasse St.	3.38
2/12/2019	80	7000 Block of Arapahoe St.	3.57
2/12/2019	35	4700 Block of Congressional Dr.	3.59
2/12/2019	58	4800 Block of French Dr.	3.38
2/12/2019	19	1300 Block of Horne Rd.	3.63
2/12/2019	92	300 Block of Wildwood Dr.	3.92
2/13/2019	83	4100 Block of Summit Dr.	2.54
2/13/2019	40	9500 Block of Quetzal St.	2.94

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/13/2019	76	1100 Block of Harbor Lights Dr.	3.02
2/13/2019	85	300 Block of Glenmore St.	2.63
2/13/2019	77	5000 Block of Cape Ann Dr.	2.99
2/13/2019	97	13900 Block of Skysail St.	3.62
2/13/2019	43	200 Block of Caribbean Dr.	2.85
2/13/2019	37	6500 Block of Brockhampton St.	3.33
2/13/2019	34	4300 Block of Harry St.	2.95
2/13/2019	10	3100 Block of Saratoga Blvd.	3.21
2/13/2019	57	1400 Block of Arlington Dr.	3.57
2/13/2019	46	8900 Block of McNorton Rd.	3.75
2/13/2019	94	15200 Block of Caravel Dr.	3.04
2/13/2019	41	1600 Block of Amber Dr.	2.93
2/13/2019	75	2900 Block of Oso Pkwy.	3.47
2/13/2019	81	6600 Block of Meadowheights Dr.	3.54
2/13/2019	5	4600 Block of Evelyn St.	3.29
2/13/2019	67	500 Block of S Carancahua St.	3.55
2/13/2019	53	9100 Block of Stock Dr.	3.20
2/13/2019	88	4200 Block of Western Dr.	4.18
2/14/2019	4	14200 Block of Playa del Rey	3.33
2/14/2019	84	3600 Block of Flour Bluff Dr.	3.24
2/14/2019	99	3900 Block of Elvis Dr.	3.59
2/14/2019	22	6700 Block of Weber Rd.	3.82
2/14/2019	20	3900 Block of Cott St.	3.72
2/14/2019	6	1200 Block of 10th St.	3.21
2/14/2019	27	2800 Block of S Port Ave.	3.91
2/14/2019	89	3800 Block of Castle Ridge Dr.	3.40
2/14/2019	45	15200 Block of Cruiser St.	3.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/14/2019	42	700 Block of Orleans Dr.	2.94
2/14/2019	21	900 Block of Lum Ave.	3.14
2/14/2019	32	4900 Block of Haket Dr.	3.48
2/14/2019	28	1700 Block of Bois d' Arc Pl.	3.83
2/14/2019	9	1000 Block of International Dr.	3.61
2/14/2019	49	100 Block of Commerce St.	3.32
2/14/2019	91	2700 Block of Wind Rock Dr.	3.61
2/15/2019	98	15800 Block of Almeria Ave.	2.71
2/15/2019	82	2100 Block of Whispering Oak Dr.	3.09
2/15/2019	79	900 Block of Egyptian Dr.	3.26
2/15/2019	7	600 Block of Carmel Pkwy.	2.76
2/15/2019	59	3600 Block of Capri Dr.	3.43
2/15/2019	30	3100 Block of Brawner Pkwy.	3.03
2/15/2019	56	200 Block of Amistad St.	3.47
2/15/2019	90	11700 Block of Haven Dr.	3.62
2/16/2019	98	15800 Block of Almeria Ave.	2.76
2/16/2019	38	7500 Block of Annemasse St.	3.28
2/16/2019	25	4100 Block of Bascule Dr.	3.61
2/16/2019	93	11000 Block of Annville Rd.	4.01
2/17/2019	97	13900 Block of Skysail St.	3.33
2/17/2019	8	1100 Block of Cornerstone Dr.	3.22
2/17/2019	26	200 Block of Eastgate Dr.	3.32
2/17/2019	86	14800 Block of Santa Gertrudis Dr.	3.12
2/18/2019	54	3700 Block of Seagull Blvd.	3.40
2/18/2019	12	2200 Block of Buford Ave.	3.60
2/18/2019	51	200 Block of Gibson Ln.	3.66
2/18/2019	93	11000 Block of Annville Rd.	3.87

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/18/2019	97	13900 Block of Skysail St.	3.68
2/18/2019	11	500 Block of Military Dr.	2.88
2/18/2019	60	1300 Block of Calle San Marcos	3.22
2/18/2019	31	4300 Block of Cedar St.	3.39
2/18/2019	83	4100 Block of Summit Dr.	2.53
2/18/2019	40	9500 Block of Quetzal St.	2.80
2/18/2019	76	1100 Block of Harbor Lights Dr.	2.90
2/18/2019	85	300 Block of Glenmore St.	2.71
2/18/2019	77	5000 Block of Cape Ann Dr.	2.75
2/19/2019	45	15200 Block of Cruiser St.	2.78
2/19/2019	36	1300 Block of Sandstone Dr.	3.00
2/19/2019	71	5500 Block of Fox Run Dr.	3.29
2/19/2019	68	5300 Block of Alejandro St.	3.18
2/19/2019	14	900 Block of Rosedale Dr.	3.14
2/19/2019	50	5500 Block of IH 37 Access Rd.	4.06
2/19/2019	47	8100 Block of Barrogate Dr.	4.11
2/19/2019	90	11700 Block of Haven Dr.	3.76
2/20/2019	33	3900 Block of Ocean Dr.	3.12
2/20/2019	25	4100 Block of Bascule Dr.	3.74
2/20/2019	48	1200 Block of Southern Minerals Rd.	3.96
2/20/2019	44	9600 Block of Wilkins Dr.	3.77
2/20/2019	95	15800 Block of El Socorro Loop	2.79
2/20/2019	72	7700 Block of Starnberg Lake Dr.	3.26
2/20/2019	2	5800 Block of St. Andrews Dr.	3.23
2/20/2019	83	4100 Block of Summit Dr.	2.38
2/20/2019	40	9500 Block of Quetzal St.	2.76
2/20/2019	76	1100 Block of Harbor Lights Dr.	2.76

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/20/2019	85	300 Block of Glenmore St.	2.63
2/20/2019	77	5000 Block of Cape Ann Dr.	2.97
2/21/2019	96	14900 Block of Windward Dr.	3.29
2/21/2019	8	1100 Block of Cornerstone Dr.	3.57
2/21/2019	70	1600 Block of E Manor Dr.	3.56
2/21/2019	15	6100 Block of Parkway Dr.	3.62
2/21/2019	73	5600 Block of King Trl.	3.52
2/21/2019	61	200 Block of Saratoga Blvd.	3.71
2/21/2019	26	200 Block of Eastgate Dr.	3.52
2/21/2019	87	5200 Block of Northwest Trl.	3.68
2/21/2019	4	14200 Block of Playa del Rey	3.46
2/21/2019	3	3000 Block of S Fork Dr.	3.44
2/21/2019	23	5500 Block of Wooldridge Rd.	3.47
2/21/2019	29	1600 Block of La Joya St.	3.59
2/21/2019	52	200 Block of Junior Beck Dr.	3.40
2/21/2019	13	1500 Block of 6th St.	3.46
2/21/2019	65	700 Block of Westchester Dr.	3.56
2/21/2019	86	14800 Block of Santa Gertrudis Dr.	3.34
2/22/2019	94	15200 Block of Caravel Dr.	2.84
2/22/2019	24	2300 Block of Rodd Field Rd.	3.46
2/22/2019	39	5900 Block of Long Creek Dr.	3.26
2/22/2019	55	500 Block of Belden St.	3.59
2/22/2019	18	900 Block of Nueces Bay Blvd.	3.83
2/22/2019	1	4800 Block of Neptune St.	3.76
2/22/2019	62	5800 Block of Hampshire Rd.	3.84
2/22/2019	16	4200 Block of Wildcat Dr.	3.90
2/23/2019	98	15800 Block of Almeria Ave.	2.83

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/23/2019	38	7500 Block of Annemasse St.	3.28
2/23/2019	25	4100 Block of Bascule Dr.	3.53
2/23/2019	93	11000 Block of Annaville Rd.	3.76
2/24/2019	97	13900 Block of Skysail St.	3.38
2/24/2019	8	1100 Block of Cornerstone Dr.	3.32
2/24/2019	26	200 Block of Eastgate Dr.	3.48
2/24/2019	86	14800 Block of Santa Gertrudis Dr.	3.31
2/25/2019	83	4100 Block of Summit Dr.	2.82
2/25/2019	40	9500 Block of Quetzal St.	2.91
2/25/2019	76	1100 Block of Harbor Lights Dr.	2.95
2/25/2019	85	300 Block of Glenmore St.	2.62
2/25/2019	77	5000 Block of Cape Ann Dr.	2.87
2/25/2019	98	15800 Block of Almeria Ave.	3.17
2/25/2019	74	7900 Block of Impala Dr.	3.16
2/25/2019	78	7600 Block of Timber Crest Dr.	3.22
2/25/2019	69	4000 Block of Donaho Dr.	3.57
2/25/2019	66	600 Block of Southern St.	3.63
2/25/2019	64	4000 Block of Hidalgo St.	3.77
2/25/2019	63	2300 Block of Summers St.	3.71
2/25/2019	91	2700 Block of Wind Rock Dr.	3.74
2/25/2019	96	14900 Block of Windward Dr.	3.14
2/25/2019	38	7500 Block of Annemasse St.	3.17
2/25/2019	80	7000 Block of Arapahoe St.	3.30
2/25/2019	35	4700 Block of Congressional Dr.	3.33
2/25/2019	58	4800 Block of French Dr.	3.32
2/25/2019	19	1300 Block of Horne Rd.	3.56
2/25/2019	92	300 Block of Wildwood Dr.	4.17

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/26/2019	97	13900 Block of Skysail St.	3.29
2/26/2019	43	200 Block of Caribbean Dr.	3.08
2/26/2019	37	6500 Block of Brockhampton St.	3.05
2/26/2019	34	4300 Block of Harry St.	3.65
2/26/2019	10	3100 Block of Saratoga Blvd.	3.44
2/26/2019	57	1400 Block of Arlington Dr.	3.72
2/26/2019	46	8900 Block of McNorton Rd.	4.04
2/27/2019	83	4100 Block of Summit Dr.	2.50
2/27/2019	40	9500 Block of Quetzal St.	2.76
2/27/2019	76	1100 Block of Harbor Lights Dr.	3.01
2/27/2019	85	300 Block of Glenmore St.	2.95
2/27/2019	77	5000 Block of Cape Ann Dr.	2.92
2/27/2019	94	15200 Block of Caravel Dr.	2.96
2/27/2019	41	1600 Block of Amber Dr.	3.06
2/27/2019	75	2900 Block of Oso Pkwy.	3.12
2/27/2019	81	6600 Block of Meadowheights Dr.	3.59
2/27/2019	5	4600 Block of Evelyn St.	3.45
2/27/2019	67	500 Block of S Carancahua St.	3.75
2/27/2019	53	9100 Block of Stock Dr.	3.36
2/27/2019	88	4200 Block of Western Dr.	4.15
2/27/2019	36	1300 Block of Sandstone Dr.	3.45
2/27/2019	14	900 Block of Rosedale Dr.	3.47
2/27/2019	61	200 Block of Saratoga Blvd.	3.81
2/27/2019	50	5500 Block of IH 37 Access Rd.	3.75
2/27/2019	43	200 Block of Caribbean Dr.	3.08
2/27/2019	37	6500 Block of Brockhampton St.	3.29
2/27/2019	34	4300 Block of Harry St.	3.15

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/27/2019	10	3100 Block of Saratoga Blvd.	3.51
2/27/2019	57	1400 Block of Arlington Dr.	3.80
2/27/2019	46	8900 Block of McNorton Rd.	3.84
2/28/2019	95	15800 Block of El Socorro Loop	2.51
2/28/2019	33	3900 Block of Ocean Dr.	3.22
2/28/2019	53	9100 Block of Stock Dr.	3.21
2/28/2019	87	5200 Block of Northwest Trl.	3.64

March

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/1/2019	59	3600 Block of Capri Dr.	3.25
3/1/2019	58	4800 Block of French Dr.	3.11
3/1/2019	98	15800 Block of Almeria Ave.	2.85
3/1/2019	95	15800 Block of El Socorro Loop	2.80
3/1/2019	96	14900 Block of Windward Dr.	3.47
3/1/2019	38	7500 Block of Annemasse St.	3.38
3/1/2019	80	7000 Block of Arapahoe St.	3.15
3/1/2019	35	4700 Block of Congressional Dr.	2.92
3/1/2019	58	4800 Block of French Dr.	3.16
3/1/2019	19	1300 Block of Horne Rd.	3.52
3/1/2019	92	300 Block of Wildwood Dr.	3.90
3/2/2019	98	15800 Block of Almeria Ave.	2.83
3/2/2019	38	7500 Block of Annemasse St.	3.43
3/2/2019	25	4100 Block of Bascule Dr.	3.48
3/2/2019	93	11000 Block of Annaville Rd.	4.02
3/3/2019	97	13900 Block of Skysail St.	3.44

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/3/2019	8	1100 Block of Cornerstone Dr.	3.21
3/3/2019	26	200 Block of Eastgate Dr.	3.61
3/3/2019	86	14800 Block of Santa Gertrudis Dr.	3.12
3/4/2019	83	4100 Block of Summit Dr.	2.49
3/4/2019	40	9500 Block of Quetzal St.	2.68
3/4/2019	76	1100 Block of Harbor Lights Dr.	2.78
3/4/2019	85	300 Block of Glenmore St.	2.67
3/4/2019	77	5000 Block of Cape Ann Dr.	2.69
3/4/2019	4	14200 Block of Playa del Rey	3.30
3/4/2019	3	3000 Block of S Fork Dr.	3.24
3/4/2019	23	5500 Block of Wooldridge Rd.	3.31
3/4/2019	29	1600 Block of La Joya St.	3.32
3/4/2019	52	200 Block of Junior Beck Dr.	3.69
3/4/2019	13	1500 Block of 6th St.	3.46
3/4/2019	65	700 Block of Westchester Dr.	3.69
3/4/2019	86	14800 Block of Santa Gertrudis Dr.	3.29
3/5/2019	96	14900 Block of Windward Dr.	3.18
3/5/2019	8	1100 Block of Cornerstone Dr.	3.12
3/5/2019	70	1600 Block of E Manor Dr.	3.41
3/5/2019	15	6100 Block of Parkway Dr.	3.35
3/5/2019	73	5600 Block of King Trl.	3.51
3/5/2019	61	200 Block of Saratoga Blvd.	3.85
3/5/2019	26	200 Block of Eastgate Dr.	3.42
3/5/2019	87	5200 Block of Northwest Trl.	3.70
3/6/2019	94	15200 Block of Caravel Dr.	2.87
3/6/2019	24	2300 Block of Rodd Field Rd.	3.35
3/6/2019	39	5900 Block of Long Creek Dr.	3.12

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/6/2019	55	500 Block of Belden St.	3.34
3/6/2019	18	900 Block of Nueces Bay Blvd.	3.86
3/6/2019	1	4800 Block of Neptune St.	3.75
3/6/2019	62	5800 Block of Hampshire Rd.	3.68
3/6/2019	16	4200 Block of Wildcat Dr.	4.10
3/6/2019	83	4100 Block of Summit Dr.	2.58
3/6/2019	40	9500 Block of Quetzal St.	2.90
3/6/2019	76	1100 Block of Harbor Lights Dr.	2.90
3/6/2019	85	300 Block of Glenmore St.	2.62
3/6/2019	77	5000 Block of Cape Ann Dr.	2.89
3/7/2019	98	15800 Block of Almeria Ave.	3.00
3/7/2019	74	7900 Block of Impala Dr.	3.04
3/7/2019	78	7600 Block of Timber Crest Dr.	3.42
3/7/2019	69	4000 Block of Donaho Dr.	3.48
3/7/2019	66	600 Block of Southern St.	3.82
3/7/2019	64	4000 Block of Hidalgo St.	3.86
3/7/2019	63	2300 Block of Summers St.	3.81
3/7/2019	91	2700 Block of Wind Rock Dr.	3.57
3/8/2019	97	13900 Block of Skysail St.	3.32
3/8/2019	43	200 Block of Caribbean Dr.	2.96
3/8/2019	37	6500 Block of Brockhampton St.	3.23
3/8/2019	34	4300 Block of Harry St.	3.23
3/8/2019	10	3100 Block of Saratoga Blvd.	3.29
3/8/2019	57	1400 Block of Arlington Dr.	3.57
3/8/2019	46	8900 Block of McNorton Rd.	3.77
3/9/2019	98	15800 Block of Almeria Ave.	2.87
3/9/2019	38	7500 Block of Annemasse St.	3.20

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/9/2019	25	4100 Block of Bascule Dr.	3.47
3/9/2019	93	11000 Block of Annville Rd.	3.87
3/10/2019	97	13900 Block of Skysail St.	3.49
3/10/2019	8	1100 Block of Cornerstone Dr.	3.37
3/10/2019	26	200 Block of Eastgate Dr.	3.37
3/10/2019	86	14800 Block of Santa Gertrudis Dr.	2.95
3/11/2019	83	4100 Block of Summit Dr.	2.55
3/11/2019	40	9500 Block of Quetzal St.	2.90
3/11/2019	76	1100 Block of Harbor Lights Dr.	2.94
3/11/2019	85	300 Block of Glenmore St.	2.90
3/11/2019	77	5000 Block of Cape Ann Dr.	2.92
3/11/2019	94	15200 Block of Caravel Dr.	3.16
3/11/2019	41	1600 Block of Amber Dr.	3.28
3/11/2019	75	2900 Block of Oso Pkwy.	3.49
3/11/2019	81	6600 Block of Meadowheights Dr.	3.28
3/11/2019	5	4600 Block of Evelyn St.	3.33
3/11/2019	67	500 Block of S Carancahua St.	3.57
3/11/2019	53	9100 Block of Stock Dr.	3.10
3/11/2019	88	4200 Block of Western Dr.	3.91
3/12/2019	4	14200 Block of Playa del Rey	3.30
3/12/2019	84	3600 Block of Flour Bluff Dr.	3.31
3/12/2019	99	3900 Block of Elvis Dr.	3.56
3/12/2019	22	6700 Block of Weber Rd.	3.48
3/12/2019	20	3900 Block of Cott St.	3.61
3/12/2019	6	1200 Block of 10th St.	3.27
3/12/2019	27	2800 Block of S Port Ave.	3.76
3/12/2019	89	3800 Block of Castle Ridge Dr.	3.36

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/13/2019	83	4100 Block of Summit Dr.	2.23
3/13/2019	40	9500 Block of Quetzal St.	3.02
3/13/2019	76	1100 Block of Harbor Lights Dr.	3.02
3/13/2019	85	300 Block of Glenmore St.	2.88
3/13/2019	77	5000 Block of Cape Ann Dr.	2.95
3/13/2019	22	6700 Block of Weber Rd.	3.78
3/13/2019	45	15200 Block of Cruiser St.	3.34
3/13/2019	42	700 Block of Orleans Dr.	3.07
3/13/2019	21	900 Block of Lum Ave.	3.21
3/13/2019	32	4900 Block of Hakel Dr.	3.39
3/13/2019	28	1700 Block of Bois d' Arc Pl.	3.70
3/13/2019	9	1000 Block of International Dr.	3.49
3/13/2019	49	100 Block of Commerce St.	3.74
3/13/2019	91	2700 Block of Wind Rock Dr.	3.84
3/13/2019	65	700 Block of Westchester Dr.	3.50
3/13/2019	98	15800 Block of Almeria Ave.	3.04
3/13/2019	82	2100 Block of Whispering Oak Dr.	3.16
3/13/2019	79	900 Block of Egyptian Dr.	3.11
3/13/2019	7	600 Block of Carmel Pkwy.	3.13
3/13/2019	59	3600 Block of Capri Dr.	3.32
3/13/2019	30	3100 Block of Brawner Pkwy.	3.04
3/13/2019	56	200 Block of Amistad St.	3.21
3/13/2019	90	11700 Block of Haven Dr.	3.76
3/13/2019	13	1500 Block of 6th St.	3.57
3/14/2019	45	15200 Block of Cruiser St.	3.07
3/14/2019	36	1300 Block of Sandstone Dr.	3.16
3/14/2019	71	5500 Block of Fox Run Dr.	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/14/2019	68	5300 Block of Alejandro St.	3.48
3/14/2019	14	900 Block of Rosedale Dr.	3.30
3/14/2019	50	5500 Block of IH 37 Access Rd.	3.80
3/14/2019	47	8100 Block of Barrogate Dr.	3.93
3/14/2019	90	11700 Block of Haven Dr.	3.73
3/14/2019	97	13900 Block of Skysail St.	3.21
3/14/2019	11	500 Block of Military Dr.	2.96
3/14/2019	60	1300 Block of Calle San Marcos	3.32
3/14/2019	31	4300 Block of Cedar St.	3.30
3/14/2019	54	3700 Block of Seagull Blvd.	3.45
3/14/2019	12	2200 Block of Buford Ave.	3.59
3/14/2019	51	200 Block of Gibson Ln.	3.65
3/14/2019	93	11000 Block of Annville Rd.	3.92
3/15/2019	95	15800 Block of El Socorro Loop	2.78
3/15/2019	95	15800 Block of El Socorro Loop	2.84
3/15/2019	72	7700 Block of Starnberg Lake Dr.	3.52
3/15/2019	2	5800 Block of St. Andrews Dr.	3.22
3/15/2019	33	3900 Block of Ocean Dr.	3.30
3/15/2019	25	4100 Block of Bascule Dr.	3.56
3/15/2019	48	1200 Block of Southern Minerals Rd.	4.07
3/15/2019	44	9600 Block of Wilkins Dr.	3.86
3/16/2019	98	15800 Block of Almeria Ave.	2.80
3/16/2019	38	7500 Block of Annemasse St.	3.28
3/16/2019	25	4100 Block of Bascule Dr.	3.82
3/16/2019	93	11000 Block of Annville Rd.	4.18
3/17/2019	97	13900 Block of Skysail St.	3.36
3/17/2019	8	1100 Block of Cornerstone Dr.	3.35

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/17/2019	26	200 Block of Eastgate Dr.	3.57
3/17/2019	86	14800 Block of Santa Gertrudis Dr.	3.49
3/18/2019	83	4100 Block of Summit Dr.	2.72
3/18/2019	40	9500 Block of Quetzal St.	3.00
3/18/2019	76	1100 Block of Harbor Lights Dr.	3.13
3/18/2019	85	300 Block of Glenmore St.	3.03
3/18/2019	77	5000 Block of Cape Ann Dr.	3.02
3/18/2019	96	14900 Block of Windward Dr.	2.81
3/18/2019	38	7500 Block of Annemasse St.	3.34
3/18/2019	80	7000 Block of Arapahoe St.	3.49
3/18/2019	35	4700 Block of Congressional Dr.	3.56
3/18/2019	58	4800 Block of French Dr.	3.18
3/18/2019	19	1300 Block of Horne Rd.	3.42
3/18/2019	92	300 Block of Wildwood Dr.	3.93
3/19/2019	34	4300 Block of Harry St.	3.11
3/19/2019	10	3100 Block of Saratoga Blvd.	3.23
3/19/2019	57	1400 Block of Arlington Dr.	3.34
3/19/2019	46	8900 Block of McNorton Rd.	3.67
3/19/2019	97	13900 Block of Skysail St.	3.21
3/19/2019	43	200 Block of Caribbean Dr.	2.85
3/19/2019	37	6500 Block of Brockhampton St.	2.95
3/19/2019	58	4800 Block of French Dr.	3.20
3/19/2019	95	15800 Block of El Socorro Loop	2.70
3/19/2019	59	3600 Block of Capri Dr.	3.33
3/19/2019	98	15800 Block of Almeria Ave.	2.80
3/20/2019	83	4100 Block of Summit Dr.	2.68
3/20/2019	40	9500 Block of Quetzal St.	2.83

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/20/2019	76	1100 Block of Harbor Lights Dr.	2.86
3/20/2019	85	300 Block of Glenmore St.	2.82
3/20/2019	77	5000 Block of Cape Ann Dr.	2.90
3/20/2019	94	15200 Block of Caravel Dr.	3.07
3/20/2019	41	1600 Block of Amber Dr.	3.00
3/20/2019	75	2900 Block of Oso Pkwy.	3.01
3/20/2019	81	6600 Block of Meadowheights Dr.	3.44
3/20/2019	5	4600 Block of Evelyn St.	3.22
3/20/2019	67	500 Block of S Carancahua St.	3.47
3/20/2019	53	9100 Block of Stock Dr.	3.17
3/20/2019	88	4200 Block of Western Dr.	3.70
3/21/2019	4	14200 Block of Playa del Rey	3.15
3/21/2019	3	3000 Block of S Fork Dr.	3.13
3/21/2019	23	5500 Block of Wooldridge Rd.	3.17
3/21/2019	29	1600 Block of La Joya St.	3.12
3/21/2019	52	200 Block of Junior Beck Dr.	3.37
3/21/2019	13	1500 Block of 6th St.	3.10
3/21/2019	65	700 Block of Westchester Dr.	3.28
3/21/2019	86	14800 Block of Santa Gertrudis Dr.	3.01
3/21/2019	96	14900 Block of Windward Dr.	2.87
3/21/2019	8	1100 Block of Cornerstone Dr.	3.24
3/21/2019	70	1600 Block of E Manor Dr.	3.48
3/21/2019	15	6100 Block of Parkway Dr.	3.50
3/21/2019	73	5600 Block of King Trl.	3.35
3/21/2019	61	200 Block of Saratoga Blvd.	3.50
3/21/2019	26	200 Block of Eastgate Dr.	3.30
3/21/2019	87	5200 Block of Northwest Trl.	3.66

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/22/2019	65	700 Block of Westchester Dr.	3.29
3/22/2019	65	700 Block of Westchester Dr.	3.56
3/22/2019	65	700 Block of Westchester Dr.	3.72
3/22/2019	94	15200 Block of Caravel Dr.	3.12
3/22/2019	24	2300 Block of Rodd Field Rd.	3.24
3/22/2019	39	5900 Block of Long Creek Dr.	3.25
3/22/2019	55	500 Block of Belden St.	3.52
3/22/2019	18	900 Block of Nueces Bay Blvd.	3.69
3/22/2019	1	4800 Block of Neptune St.	3.41
3/22/2019	62	5800 Block of Hampshire Rd.	3.61
3/22/2019	16	4200 Block of Wildcat Dr.	3.69
3/23/2019	98	15800 Block of Almeria Ave.	3.03
3/23/2019	38	7500 Block of Annemasse St.	3.08
3/23/2019	25	4100 Block of Bascule Dr.	3.30
3/23/2019	93	11000 Block of Annville Rd.	3.59
3/24/2019	97	13900 Block of Skysail St.	3.05
3/24/2019	8	1100 Block of Cornerstone Dr.	3.03
3/24/2019	26	200 Block of Eastgate Dr.	3.00
3/24/2019	86	14800 Block of Santa Gertrudis Dr.	3.00
3/25/2019	83	4100 Block of Summit Dr.	2.35
3/25/2019	40	9500 Block of Quetzal St.	2.71
3/25/2019	76	1100 Block of Harbor Lights Dr.	2.72
3/25/2019	85	300 Block of Glenmore St.	2.68
3/25/2019	77	5000 Block of Cape Ann Dr.	2.58
3/25/2019	98	15800 Block of Almeria Ave.	2.65
3/25/2019	74	7900 Block of Impala Dr.	3.00
3/25/2019	78	7600 Block of Timber Crest Dr.	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/25/2019	69	4000 Block of Donaho Dr.	3.30
3/25/2019	66	600 Block of Southern St.	3.42
3/25/2019	64	4000 Block of Hidalgo St.	3.58
3/25/2019	91	2700 Block of Wind Rock Dr.	3.48
3/25/2019	4	14200 Block of Playa del Rey	2.92
3/25/2019	84	3600 Block of Flour Bluff Dr.	3.07
3/25/2019	99	3900 Block of Elvis Dr.	3.20
3/25/2019	22	6700 Block of Weber Rd.	3.50
3/25/2019	20	3900 Block of Cott St.	3.48
3/25/2019	6	1200 Block of 10th St.	2.96
3/25/2019	27	2800 Block of S Port Ave.	3.62
3/25/2019	89	3800 Block of Castle Ridge Dr.	3.45
3/26/2019	45	15200 Block of Cruiser St.	2.79
3/26/2019	42	700 Block of Orleans Dr.	3.33
3/26/2019	21	900 Block of Lum Ave.	3.22
3/26/2019	32	4900 Block of Hakel Dr.	3.48
3/26/2019	28	1700 Block of Bois d' Arc Pl.	3.54
3/26/2019	9	1000 Block of International Dr.	3.38
3/26/2019	49	100 Block of Commerce St.	3.44
3/26/2019	91	2700 Block of Wind Rock Dr.	3.59
3/27/2019	83	4100 Block of Summit Dr.	2.23
3/27/2019	40	9500 Block of Quetzal St.	2.87
3/27/2019	76	1100 Block of Harbor Lights Dr.	3.04
3/27/2019	85	300 Block of Glenmore St.	2.90
3/27/2019	77	5000 Block of Cape Ann Dr.	3.00
3/27/2019	97	13900 Block of Skysail St.	3.29
3/27/2019	11	500 Block of Military Dr.	2.91

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/27/2019	60	1300 Block of Calle San Marcos	3.15
3/27/2019	31	4300 Block of Cedar St.	3.03
3/27/2019	54	3700 Block of Seagull Blvd.	3.22
3/27/2019	12	2200 Block of Buford Ave.	3.56
3/27/2019	51	200 Block of Gibson Ln.	3.52
3/27/2019	93	11000 Block of Annville Rd.	3.90
3/27/2019	98	15800 Block of Almeria Ave.	2.73
3/27/2019	82	2100 Block of Whispering Oak Dr.	3.06
3/27/2019	79	900 Block of Egyptian Dr.	3.05
3/27/2019	7	600 Block of Carmel Pkwy.	2.97
3/27/2019	59	3600 Block of Capri Dr.	3.04
3/27/2019	30	3100 Block of Brawner Pkwy.	2.88
3/27/2019	56	200 Block of Amistad St.	3.06
3/27/2019	90	11700 Block of Haven Dr.	3.39
3/28/2019	95	15800 Block of El Socorro Loop	3.01
3/28/2019	72	7700 Block of Starnberg Lake Dr.	3.31
3/28/2019	2	5800 Block of St. Andrews Dr.	3.23
3/28/2019	33	3900 Block of Ocean Dr.	3.23
3/28/2019	28	1700 Block of Bois d' Arc Pl.	3.48
3/28/2019	25	4100 Block of Bascule Dr.	3.41
3/28/2019	48	1200 Block of Southern Minerals Rd.	3.66
3/28/2019	44	9600 Block of Wilkins Dr.	3.53
3/28/2019	45	15200 Block of Cruiser St.	3.17
3/28/2019	36	1300 Block of Sandstone Dr.	2.88
3/28/2019	71	5500 Block of Fox Run Dr.	3.16
3/28/2019	68	5300 Block of Alejandro St.	3.13
3/28/2019	14	900 Block of Rosedale Dr.	3.29

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/28/2019	50	5500 Block of IH 37 Access Rd.	3.63
3/28/2019	47	8100 Block of Barrogate Dr.	3.61
3/28/2019	90	11700 Block of Haven Dr.	3.57
3/28/2019	90	11700 Block of Haven Dr.	3.39
3/29/2019	96	14900 Block of Windward Dr.	2.86
3/29/2019	71	5500 Block of Fox Run Dr.	3.17
3/29/2019	91	2700 Block of Wind Rock Dr.	3.48
3/29/2019	12	2200 Block of Buford Ave.	3.55
3/30/2019	98	15800 Block of Almeria Ave.	2.77
3/30/2019	38	7500 Block of Annemasse St.	3.22
3/30/2019	25	4100 Block of Bascule Dr.	3.43
3/30/2019	93	11000 Block of Annville Rd.	3.79
3/31/2019	97	13900 Block of Skysail St.	3.10
3/31/2019	8	1100 Block of Cornerstone Dr.	3.06
3/31/2019	26	200 Block of Eastgate Dr.	3.21
3/31/2019	86	14800 Block of Santa Gertrudis Dr.	3.18

April

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/1/2019	4	14200 Block of Playa del Rey	2.96
4/1/2019	84	3600 Block of Flour Bluff Dr.	2.95
4/1/2019	99	3900 Block of Elvis Dr.	3.06
4/1/2019	22	6700 Block of Weber Rd.	3.11
4/1/2019	20	3900 Block of Cott St.	3.15
4/1/2019	6	1200 Block of 10th St.	3.04
4/1/2019	27	2800 Block of S Port Ave.	3.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/1/2019	89	3800 Block of Castle Ridge Dr.	3.17
4/1/2019	83	4100 Block of Summit Dr.	2.54
4/1/2019	40	9500 Block of Quetzal St.	2.70
4/1/2019	76	1100 Block of Harbor Lights Dr.	2.73
4/1/2019	85	300 Block of Glenmore St.	2.55
4/1/2019	77	5000 Block of Cape Ann Dr.	2.75
4/2/2019	28	1700 Block of Bois d' Arc Pl.	3.02
4/2/2019	9	1000 Block of International Dr.	2.79
4/2/2019	49	100 Block of Commerce St.	3.17
4/2/2019	91	2700 Block of Wind Rock Dr.	3.10
4/2/2019	45	15200 Block of Cruiser St.	3.03
4/2/2019	42	700 Block of Orleans Dr.	2.92
4/2/2019	21	900 Block of Lum Ave.	3.10
4/2/2019	32	4900 Block of Hakel Dr.	3.01
4/3/2019	98	15800 Block of Almeria Ave.	2.68
4/3/2019	82	2100 Block of Whispering Oak Dr.	3.01
4/3/2019	79	900 Block of Egyptian Dr.	2.62
4/3/2019	7	600 Block of Carmel Pkwy.	2.67
4/3/2019	59	3600 Block of Capri Dr.	2.61
4/3/2019	30	3100 Block of Brawner Pkwy.	2.70
4/3/2019	56	200 Block of Amistad St.	2.72
4/3/2019	90	11700 Block of Haven Dr.	3.16
4/3/2019	83	4100 Block of Summit Dr.	2.48
4/3/2019	40	9500 Block of Quetzal St.	2.84
4/3/2019	76	1100 Block of Harbor Lights Dr.	2.61
4/3/2019	85	300 Block of Glenmore St.	2.61
4/3/2019	77	5000 Block of Cape Ann Dr.	2.50

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/3/2019	59	3600 Block of Capri Dr.	2.61
4/3/2019	98	15800 Block of Almeria Ave.	2.74
4/3/2019	58	4800 Block of French Dr.	2.67
4/3/2019	95	15800 Block of El Socorro Loop	2.51
4/4/2019	45	15200 Block of Cruiser St.	2.58
4/4/2019	36	1300 Block of Sandstone Dr.	2.42
4/4/2019	71	5500 Block of Fox Run Dr.	2.38
4/4/2019	68	5300 Block of Alejandro St.	2.74
4/4/2019	14	900 Block of Rosedale Dr.	2.90
4/4/2019	50	5500 Block of IH 37 Access Rd.	3.53
4/4/2019	47	8100 Block of Barrogate Dr.	3.56
4/4/2019	90	11700 Block of Haven Dr.	3.45
4/4/2019	97	13900 Block of Skysail St.	2.63
4/4/2019	11	500 Block of Military Dr.	2.42
4/4/2019	60	1300 Block of Calle San Marcos	2.58
4/4/2019	31	4300 Block of Cedar St.	2.60
4/4/2019	54	3700 Block of Seagull Blvd.	2.94
4/4/2019	12	2200 Block of Buford Ave.	3.40
4/4/2019	51	200 Block of Gibson Ln.	3.49
4/4/2019	93	11000 Block of Annville Rd.	3.68
4/5/2019	95	15800 Block of El Socorro Loop	2.53
4/5/2019	72	7700 Block of Starnberg Lake Dr.	2.88
4/5/2019	2	5800 Block of St. Andrews Dr.	3.14
4/5/2019	33	3900 Block of Ocean Dr.	2.75
4/5/2019	25	4100 Block of Bascule Dr.	3.37
4/5/2019	48	1200 Block of Southern Minerals Rd.	3.73
4/5/2019	44	9600 Block of Wilkins Dr.	3.27

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/6/2019	98	15800 Block of Almeria Ave.	2.36
4/6/2019	38	7500 Block of Annemasse St.	3.12
4/6/2019	25	4100 Block of Bascule Dr.	3.18
4/6/2019	93	11000 Block of Annaville Rd.	3.99
4/7/2019	97	13900 Block of Skysail St.	3.12
4/7/2019	8	1100 Block of Cornerstone Dr.	3.16
4/7/2019	26	200 Block of Eastgate Dr.	3.17
4/7/2019	86	14800 Block of Santa Gertrudis Dr.	3.15
4/8/2019	83	4100 Block of Summit Dr.	2.08
4/8/2019	40	9500 Block of Quetzal St.	2.75
4/8/2019	76	1100 Block of Harbor Lights Dr.	2.82
4/8/2019	85	300 Block of Glenmore St.	2.67
4/8/2019	77	5000 Block of Cape Ann Dr.	2.84
4/8/2019	4	14200 Block of Playa del Rey	3.17
4/8/2019	3	3000 Block of S Fork Dr.	3.15
4/8/2019	23	5500 Block of Wooldridge Rd.	3.11
4/8/2019	29	1600 Block of La Joya St.	3.20
4/8/2019	52	200 Block of Junior Beck Dr.	3.02
4/8/2019	13	1500 Block of 6th St.	3.02
4/8/2019	65	700 Block of Westchester Dr.	3.16
4/8/2019	86	14800 Block of Santa Gertrudis Dr.	3.28
4/9/2019	96	14900 Block of Windward Dr.	3.09
4/9/2019	8	1100 Block of Cornerstone Dr.	3.04
4/9/2019	70	1600 Block of E Manor Dr.	3.17
4/9/2019	15	6100 Block of Parkway Dr.	3.14
4/9/2019	73	5600 Block of King Trl.	3.41
4/9/2019	61	200 Block of Saratoga Blvd.	3.48

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/9/2019	26	200 Block of Eastgate Dr.	3.31
4/9/2019	87	5200 Block of Northwest Trl.	3.36
4/10/2019	83	4100 Block of Summit Dr.	2.34
4/10/2019	40	9500 Block of Quetzal St.	2.79
4/10/2019	76	1100 Block of Harbor Lights Dr.	2.90
4/10/2019	85	300 Block of Glenmore St.	2.72
4/10/2019	77	5000 Block of Cape Ann Dr.	2.65
4/10/2019	94	15200 Block of Caravel Dr.	2.84
4/10/2019	24	2300 Block of Rodd Field Rd.	3.40
4/10/2019	39	5900 Block of Long Creek Dr.	3.02
4/10/2019	55	500 Block of Belden St.	3.41
4/10/2019	18	900 Block of Nueces Bay Blvd.	3.74
4/10/2019	1	4800 Block of Neptune St.	3.55
4/10/2019	62	5800 Block of Hampshire Rd.	3.66
4/10/2019	16	4200 Block of Wildcat Dr.	3.45
4/10/2019	98	15800 Block of Almeria Ave.	2.59
4/10/2019	74	7900 Block of Impala Dr.	3.20
4/10/2019	78	7600 Block of Timber Crest Dr.	3.38
4/10/2019	69	4000 Block of Donaho Dr.	3.45
4/10/2019	66	600 Block of Southern St.	3.44
4/10/2019	64	4000 Block of Hidalgo St.	3.31
4/10/2019	91	2700 Block of Wind Rock Dr.	3.61
4/11/2019	96	14900 Block of Windward Dr.	3.33
4/11/2019	38	7500 Block of Annemasse St.	3.32
4/11/2019	80	7000 Block of Arapahoe St.	3.13
4/11/2019	35	4700 Block of Congressional Dr.	3.24
4/11/2019	58	4800 Block of French Dr.	3.07

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/11/2019	19	1300 Block of Horne Rd.	3.33
4/11/2019	92	300 Block of Wildwood Dr.	3.98
4/11/2019	97	13900 Block of Skysail St.	3.25
4/11/2019	43	200 Block of Caribbean Dr.	2.93
4/11/2019	37	6500 Block of Brockhampton St.	3.30
4/11/2019	34	4300 Block of Harry St.	2.82
4/11/2019	10	3100 Block of Saratoga Blvd.	3.03
4/11/2019	57	1400 Block of Arlington Dr.	3.27
4/11/2019	46	8900 Block of McNorton Rd.	3.81
4/12/2019	94	15200 Block of Caravel Dr.	2.99
4/12/2019	41	1600 Block of Amber Dr.	3.07
4/12/2019	75	2900 Block of Oso Pkwy.	2.98
4/12/2019	81	6600 Block of Meadowheights Dr.	3.10
4/12/2019	5	4600 Block of Evelyn St.	2.97
4/12/2019	67	500 Block of S Carancahua St.	3.54
4/12/2019	53	9100 Block of Stock Dr.	3.11
4/12/2019	88	4200 Block of Western Dr.	4.02
4/13/2019	98	15800 Block of Almeria Ave.	2.92
4/13/2019	38	7500 Block of Annemasse St.	3.25
4/13/2019	25	4100 Block of Bascule Dr.	3.62
4/13/2019	93	11000 Block of Annville Rd.	3.87
4/14/2019	97	13900 Block of Skysail St.	3.23
4/14/2019	8	1100 Block of Cornerstone Dr.	3.33
4/14/2019	26	200 Block of Eastgate Dr.	3.38
4/14/2019	86	14800 Block of Santa Gertrudis Dr.	3.28
4/15/2019	83	4100 Block of Summit Dr.	2.43
4/15/2019	40	9500 Block of Quetzal St.	2.87

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/15/2019	76	1100 Block of Harbor Lights Dr.	3.02
4/15/2019	85	300 Block of Glenmore St.	2.83
4/15/2019	77	5000 Block of Cape Ann Dr.	2.92
4/15/2019	97	13900 Block of Skysail St.	3.41
4/15/2019	11	500 Block of Military Dr.	2.96
4/15/2019	60	1300 Block of Calle San Marcos	3.22
4/15/2019	31	4300 Block of Cedar St.	3.14
4/15/2019	54	3700 Block of Seagull Blvd.	3.27
4/15/2019	12	2200 Block of Buford Ave.	3.43
4/15/2019	51	200 Block of Gibson Ln.	3.41
4/15/2019	93	11000 Block of Annville Rd.	3.86
4/16/2019	14	900 Block of Rosedale Dr.	3.12
4/16/2019	50	5500 Block of IH 37 Access Rd.	3.61
4/16/2019	47	8100 Block of Barrogate Dr.	3.67
4/16/2019	90	11700 Block of Haven Dr.	3.44
4/16/2019	45	15200 Block of Cruiser St.	3.23
4/16/2019	36	1300 Block of Sandstone Dr.	2.80
4/16/2019	71	5500 Block of Fox Run Dr.	2.81
4/16/2019	68	5300 Block of Alejandro St.	3.12
4/17/2019	95	15800 Block of El Socorro Loop	2.75
4/17/2019	72	7700 Block of Starnberg Lake Dr.	3.05
4/17/2019	2	5800 Block of St. Andrews Dr.	2.89
4/17/2019	45	15200 Block of Cruiser St.	2.90
4/17/2019	42	700 Block of Orleans Dr.	2.96
4/17/2019	21	900 Block of Lum Ave.	3.05
4/17/2019	32	4900 Block of Hakei Dr.	3.26
4/17/2019	28	1700 Block of Bois d' Arc Pl.	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/17/2019	9	1000 Block of International Dr.	3.17
4/17/2019	33	3900 Block of Ocean Dr.	3.00
4/17/2019	25	4100 Block of Bascule Dr.	3.16
4/17/2019	48	1200 Block of Southern Minerals Rd.	3.61
4/17/2019	44	9600 Block of Wilkins Dr.	3.72
4/17/2019	83	4100 Block of Summit Dr.	2.74
4/17/2019	40	9500 Block of Quetzal St.	2.69
4/17/2019	76	1100 Block of Harbor Lights Dr.	2.78
4/17/2019	85	300 Block of Glenmore St.	2.73
4/17/2019	77	5000 Block of Cape Ann Dr.	2.79
4/18/2019	45	15200 Block of Cruiser St.	2.96
4/18/2019	42	700 Block of Orleans Dr.	2.77
4/18/2019	21	900 Block of Lum Ave.	2.99
4/18/2019	32	4900 Block of Hakel Dr.	3.37
4/18/2019	28	1700 Block of Bois d' Arc Pl.	3.49
4/18/2019	9	1000 Block of International Dr.	3.48
4/18/2019	49	100 Block of Commerce St.	3.41
4/18/2019	91	2700 Block of Wind Rock Dr.	3.59
4/18/2019	4	14200 Block of Playa del Rey	2.91
4/18/2019	84	3600 Block of Flour Bluff Dr.	3.18
4/18/2019	99	3900 Block of Elvis Dr.	3.30
4/18/2019	22	6700 Block of Weber Rd.	3.41
4/18/2019	20	3900 Block of Cott St.	3.37
4/18/2019	6	1200 Block of 10th St.	3.16
4/18/2019	27	2800 Block of S Port Ave.	3.49
4/18/2019	89	3800 Block of Castle Ridge Dr.	3.42
4/19/2019	98	15800 Block of Almeria Ave.	2.65

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/19/2019	82	2100 Block of Whispering Oak Dr.	3.05
4/19/2019	79	900 Block of Egyptian Dr.	2.99
4/19/2019	7	600 Block of Carmel Pkwy.	2.91
4/19/2019	59	3600 Block of Capri Dr.	3.03
4/19/2019	30	3100 Block of Brawner Pkwy.	2.87
4/19/2019	56	200 Block of Amistad St.	2.95
4/19/2019	90	11700 Block of Haven Dr.	3.36
4/20/2019	98	15800 Block of Almeria Ave.	2.68
4/20/2019	38	7500 Block of Annemasse St.	3.10
4/20/2019	25	4100 Block of Bascule Dr.	3.49
4/20/2019	93	11000 Block of Annville Rd.	4.13
4/21/2019	97	13900 Block of Skysail St.	3.04
4/21/2019	8	1100 Block of Cornerstone Dr.	3.25
4/21/2019	26	200 Block of Eastgate Dr.	3.38
4/21/2019	86	14800 Block of Santa Gertrudis Dr.	3.47
4/22/2019	83	4100 Block of Summit Dr.	2.62
4/22/2019	40	9500 Block of Quetzal St.	2.90
4/22/2019	76	1100 Block of Harbor Lights Dr.	2.94
4/22/2019	85	300 Block of Glenmore St.	2.86
4/22/2019	77	5000 Block of Cape Ann Dr.	2.80
4/22/2019	4	14200 Block of Playa del Rey	3.40
4/22/2019	3	3000 Block of S Fork Dr.	3.73
4/22/2019	23	5500 Block of Wooldridge Rd.	3.40
4/22/2019	29	1600 Block of La Joya St.	3.46
4/22/2019	52	200 Block of Junior Beck Dr.	3.42
4/22/2019	13	1500 Block of 6th St.	3.37
4/22/2019	65	700 Block of Westchester Dr.	3.47

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/22/2019	86	14800 Block of Santa Gertrudis Dr.	3.28
4/23/2019	96	14900 Block of Windward Dr.	3.23
4/23/2019	8	1100 Block of Cornerstone Dr.	3.24
4/23/2019	70	1600 Block of E Manor Dr.	3.14
4/23/2019	15	6100 Block of Parkway Dr.	3.06
4/23/2019	73	5600 Block of King Trl.	3.28
4/23/2019	61	200 Block of Saratoga Blvd.	3.44
4/23/2019	26	200 Block of Eastgate Dr.	3.19
4/23/2019	87	5200 Block of Northwest Trl.	3.19
4/24/2019	83	4100 Block of Summit Dr.	2.83
4/24/2019	40	9500 Block of Quetzal St.	2.85
4/24/2019	76	1100 Block of Harbor Lights Dr.	2.83
4/24/2019	85	300 Block of Glenmore St.	2.72
4/24/2019	77	5000 Block of Cape Ann Dr.	2.91
4/24/2019	94	15200 Block of Caravel Dr.	3.15
4/24/2019	24	2300 Block of Rodd Field Rd.	3.26
4/24/2019	39	5900 Block of Long Creek Dr.	3.03
4/24/2019	55	500 Block of Belden St.	3.22
4/24/2019	18	900 Block of Nueces Bay Blvd.	3.42
4/24/2019	1	4800 Block of Neptune St.	3.19
4/24/2019	62	5800 Block of Hampshire Rd.	3.40
4/24/2019	16	4200 Block of Wildcat Dr.	3.27
4/24/2019	98	15800 Block of Almeria Ave.	3.11
4/24/2019	74	7900 Block of Impala Dr.	3.03
4/24/2019	78	7600 Block of Timber Crest Dr.	3.21
4/24/2019	69	4000 Block of Donaho Dr.	3.17
4/24/2019	66	600 Block of Southern St.	3.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/24/2019	64	4000 Block of Hidalgo St.	3.35
4/24/2019	91	2700 Block of Wind Rock Dr.	3.36
4/25/2019	96	14900 Block of Windward Dr.	3.06
4/25/2019	38	7500 Block of Annemasse St.	2.95
4/25/2019	80	7000 Block of Arapahoe St.	2.91
4/25/2019	35	4700 Block of Congressional Dr.	2.93
4/25/2019	58	4800 Block of French Dr.	2.87
4/25/2019	19	1300 Block of Horne Rd.	2.96
4/25/2019	92	300 Block of Wildwood Dr.	3.45
4/26/2019	4	14200 Block of Playa del Rey	2.93
4/26/2019	97	13900 Block of Skysail St.	3.09
4/26/2019	45	15200 Block of Cruiser St.	3.03
4/26/2019	43	200 Block of Caribbean Dr.	2.79
4/26/2019	37	6500 Block of Brockhampton St.	2.89
4/26/2019	34	4300 Block of Harry St.	2.91
4/26/2019	10	3100 Block of Saratoga Blvd.	2.78
4/26/2019	57	1400 Block of Arlington Dr.	3.05
4/26/2019	46	8900 Block of McNorton Rd.	3.42
4/27/2019	98	15800 Block of Almeria Ave.	2.64
4/27/2019	38	7500 Block of Annemasse St.	2.82
4/27/2019	25	4100 Block of Bascule Dr.	2.94
4/27/2019	93	11000 Block of Annville Rd.	3.77
4/28/2019	97	13900 Block of Skysail St.	2.93
4/28/2019	8	1100 Block of Cornerstone Dr.	3.05
4/28/2019	26	200 Block of Eastgate Dr.	3.32
4/28/2019	86	14800 Block of Santa Gertrudis Dr.	3.14
4/29/2019	83	4100 Block of Summit Dr.	2.48

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/29/2019	40	9500 Block of Quetzal St.	2.67
4/29/2019	76	1100 Block of Harbor Lights Dr.	2.76
4/29/2019	85	300 Block of Glenmore St.	2.70
4/29/2019	77	5000 Block of Cape Ann Dr.	2.57
4/29/2019	94	15200 Block of Caravel Dr.	2.83
4/29/2019	41	1600 Block of Amber Dr.	2.82
4/29/2019	75	2900 Block of Oso Pkwy.	3.03
4/29/2019	81	6600 Block of Meadowheights Dr.	3.04
4/29/2019	5	4600 Block of Evelyn St.	2.97
4/29/2019	67	500 Block of S Carancahua St.	3.28
4/29/2019	53	9100 Block of Stock Dr.	2.97
4/29/2019	88	4200 Block of Western Dr.	3.83
4/29/2019	89	3800 Block of Castle Ridge Dr.	3.19
4/30/2019	4	14200 Block of Playa del Rey	2.95
4/30/2019	58	4800 Block of French Dr.	3.11
4/30/2019	29	1600 Block of La Joya St.	3.19
4/30/2019	88	4200 Block of Western Dr.	3.68

May

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/1/2019	83	4100 Block of Summit Dr.	2.42
5/1/2019	40	9500 Block of Quetzal St.	2.73
5/1/2019	76	1100 Block of Harbor Lights Dr.	2.75
5/1/2019	85	300 Block of Glenmore St.	2.64
5/1/2019	77	5000 Block of Cape Ann Dr.	2.60
5/1/2019	97	13900 Block of Skysail St.	3.24

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/1/2019	43	200 Block of Caribbean Dr.	2.85
5/1/2019	37	6500 Block of Brockhampton St.	2.86
5/1/2019	34	4300 Block of Harry St.	2.89
5/1/2019	10	3100 Block of Saratoga Blvd.	2.94
5/1/2019	57	1400 Block of Arlington Dr.	3.31
5/1/2019	46	8900 Block of McNorton Rd.	3.60
5/1/2019	94	15200 Block of Caravel Dr.	2.96
5/1/2019	41	1600 Block of Amber Dr.	3.02
5/1/2019	75	2900 Block of Oso Pkwy.	3.07
5/1/2019	81	6600 Block of Meadowheights Dr.	2.83
5/1/2019	5	4600 Block of Evelyn St.	2.94
5/1/2019	67	500 Block of S Carancahua St.	3.36
5/1/2019	53	9100 Block of Stock Dr.	2.99
5/1/2019	88	4200 Block of Western Dr.	3.82
5/2/2019	58	4800 Block of French Dr.	2.93
5/2/2019	95	15800 Block of El Socorro Loop	2.51
5/2/2019	59	3600 Block of Capri Dr.	2.96
5/2/2019	98	15800 Block of Almeria Ave.	2.92
5/2/2019	4	14200 Block of Playa del Rey	3.04
5/2/2019	84	3600 Block of Flour Bluff Dr.	3.00
5/2/2019	99	3900 Block of Elvis Dr.	3.05
5/2/2019	22	6700 Block of Weber Rd.	3.08
5/2/2019	20	3900 Block of Cott St.	3.24
5/2/2019	6	1200 Block of 10th St.	3.04
5/2/2019	27	2800 Block of S Port Ave.	3.37
5/2/2019	89	3800 Block of Castle Ridge Dr.	3.09
5/3/2019	45	15200 Block of Cruiser St.	3.12

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/3/2019	42	700 Block of Orleans Dr.	2.80
5/3/2019	21	900 Block of Lum Ave.	2.79
5/3/2019	32	4900 Block of Hakei Dr.	3.11
5/3/2019	28	1700 Block of Bois d' Arc Pl.	3.34
5/3/2019	9	1000 Block of International Dr.	3.11
5/3/2019	49	100 Block of Commerce St.	3.30
5/3/2019	91	2700 Block of Wind Rock Dr.	3.48
5/4/2019	98	15800 Block of Almeria Ave.	2.58
5/4/2019	38	7500 Block of Annemasse St.	2.80
5/4/2019	25	4100 Block of Bascule Dr.	3.11
5/4/2019	93	11000 Block of Annville Rd.	3.54
5/5/2019	97	13900 Block of Skysail St.	2.99
5/5/2019	8	1100 Block of Cornerstone Dr.	2.79
5/5/2019	26	200 Block of Eastgate Dr.	2.90
5/5/2019	86	14800 Block of Santa Gertrudis Dr.	2.96
5/6/2019	4	14200 Block of Playa del Rey	2.87
5/6/2019	3	3000 Block of S Fork Dr.	3.09
5/6/2019	23	5500 Block of Wooldridge Rd.	2.79
5/6/2019	29	1600 Block of La Joya St.	2.89
5/6/2019	52	200 Block of Junior Beck Dr.	3.04
5/6/2019	13	1500 Block of 6th St.	2.84
5/6/2019	65	700 Block of Westchester Dr.	2.92
5/6/2019	86	14800 Block of Santa Gertrudis Dr.	2.77
5/6/2019	83	4100 Block of Summit Dr.	2.42
5/6/2019	40	9500 Block of Quetzal St.	2.49
5/6/2019	76	1100 Block of Harbor Lights Dr.	2.56
5/6/2019	85	300 Block of Glenmore St.	2.52

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/6/2019	77	5000 Block of Cape Ann Dr.	2.58
5/7/2019	96	14900 Block of Windward Dr.	2.90
5/7/2019	8	1100 Block of Cornerstone Dr.	2.77
5/7/2019	70	1600 Block of E Manor Dr.	2.52
5/7/2019	15	6100 Block of Parkway Dr.	2.55
5/7/2019	73	5600 Block of King Trl.	2.93
5/7/2019	61	200 Block of Saratoga Blvd.	3.09
5/7/2019	26	200 Block of Eastgate Dr.	2.80
5/7/2019	87	5200 Block of Northwest Trl.	3.07
5/8/2019	18	900 Block of Nueces Bay Blvd.	3.48
5/8/2019	1	4800 Block of Neptune St.	3.32
5/8/2019	62	5800 Block of Hampshire Rd.	3.29
5/8/2019	16	4200 Block of Wildcat Dr.	3.33
5/8/2019	94	15200 Block of Caravel Dr.	2.64
5/8/2019	24	2300 Block of Rodd Field Rd.	2.80
5/8/2019	39	5900 Block of Long Creek Dr.	2.35
5/8/2019	55	500 Block of Belden St.	3.13
5/8/2019	83	4100 Block of Summit Dr.	2.24
5/8/2019	40	9500 Block of Quetzal St.	2.34
5/8/2019	76	1100 Block of Harbor Lights Dr.	2.35
5/8/2019	85	300 Block of Glenmore St.	2.29
5/8/2019	77	5000 Block of Cape Ann Dr.	2.40
5/9/2019	66	600 Block of Southern St.	3.31
5/9/2019	64	4000 Block of Hidalgo St.	3.56
5/9/2019	91	2700 Block of Wind Rock Dr.	3.68
5/9/2019	98	15800 Block of Almeria Ave.	2.51
5/9/2019	74	7900 Block of Impala Dr.	2.71

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/9/2019	78	7600 Block of Timber Crest Dr.	2.82
5/9/2019	69	4000 Block of Donaho Dr.	3.45
5/10/2019	98	15800 Block of Almeria Ave.	2.45
5/10/2019	82	2100 Block of Whispering Oak Dr.	2.69
5/10/2019	79	900 Block of Egyptian Dr.	2.94
5/10/2019	7	600 Block of Carmel Pkwy.	2.65
5/10/2019	59	3600 Block of Capri Dr.	3.18
5/10/2019	30	3100 Block of Brawner Pkwy.	2.96
5/10/2019	56	200 Block of Amistad St.	3.14
5/10/2019	90	11700 Block of Haven Dr.	3.74
5/11/2019	98	15800 Block of Almeria Ave.	2.45
5/11/2019	38	7500 Block of Annemasse St.	3.32
5/11/2019	25	4100 Block of Bascule Dr.	3.44
5/11/2019	93	11000 Block of Annville Rd.	3.95
5/12/2019	97	13900 Block of Skysail St.	3.14
5/12/2019	8	1100 Block of Cornerstone Dr.	3.33
5/12/2019	26	200 Block of Eastgate Dr.	3.34
5/12/2019	86	14800 Block of Santa Gertrudis Dr.	2.82
5/13/2019	83	4100 Block of Summit Dr.	2.54
5/13/2019	40	9500 Block of Quetzal St.	2.76
5/13/2019	76	1100 Block of Harbor Lights Dr.	2.68
5/13/2019	85	300 Block of Glenmore St.	2.67
5/13/2019	77	5000 Block of Cape Ann Dr.	2.86
5/13/2019	97	13900 Block of Skysail St.	3.36
5/13/2019	11	500 Block of Military Dr.	2.59
5/13/2019	60	1300 Block of Calle San Marcos	2.93
5/13/2019	31	4300 Block of Cedar St.	2.68

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/13/2019	54	3700 Block of Seagull Blvd.	3.10
5/13/2019	12	2200 Block of Buford Ave.	3.41
5/13/2019	51	200 Block of Gibson Ln.	3.46
5/13/2019	93	11000 Block of Annville Rd.	3.96
5/14/2019	45	15200 Block of Cruiser St.	3.30
5/14/2019	36	1300 Block of Sandstone Dr.	2.84
5/14/2019	71	5500 Block of Fox Run Dr.	2.89
5/14/2019	68	5300 Block of Alejandro St.	3.01
5/14/2019	14	900 Block of Rosedale Dr.	2.99
5/14/2019	50	5500 Block of IH 37 Access Rd.	3.50
5/14/2019	47	8100 Block of Barrogate Dr.	3.60
5/14/2019	90	11700 Block of Haven Dr.	3.37
5/15/2019	83	4100 Block of Summit Dr.	2.49
5/15/2019	40	9500 Block of Quetzal St.	2.67
5/15/2019	76	1100 Block of Harbor Lights Dr.	2.68
5/15/2019	85	300 Block of Glenmore St.	2.61
5/15/2019	77	5000 Block of Cape Ann Dr.	2.65
5/15/2019	4	14200 Block of Playa del Rey	3.13
5/15/2019	3	3000 Block of S Fork Dr.	3.04
5/15/2019	23	5500 Block of Wooldridge Rd.	2.81
5/15/2019	29	1600 Block of La Joya St.	3.09
5/15/2019	52	200 Block of Junior Beck Dr.	3.32
5/15/2019	13	1500 Block of 6th St.	2.89
5/15/2019	65	700 Block of Westchester Dr.	3.15
5/15/2019	86	14800 Block of Santa Gertrudis Dr.	3.09
5/15/2019	95	15800 Block of El Socorro Loop	2.78
5/15/2019	72	7700 Block of Starnberg Lake Dr.	2.99

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/15/2019	2	5800 Block of St. Andrews Dr.	2.94
5/15/2019	33	3900 Block of Ocean Dr.	2.68
5/15/2019	25	4100 Block of Bascule Dr.	3.31
5/15/2019	48	1200 Block of Southern Minerals Rd.	3.79
5/15/2019	44	9600 Block of Wilkins Dr.	3.82
5/15/2019	47	8100 Block of Barrogate Dr.	3.63
5/16/2019	45	15200 Block of Cruiser St.	3.10
5/16/2019	42	700 Block of Orleans Dr.	2.82
5/16/2019	21	900 Block of Lum Ave.	2.74
5/16/2019	32	4900 Block of Hakel Dr.	3.23
5/16/2019	28	1700 Block of Bois d' Arc Pl.	3.34
5/16/2019	9	1000 Block of International Dr.	3.25
5/16/2019	96	14900 Block of Windward Dr.	2.95
5/16/2019	8	1100 Block of Cornerstone Dr.	2.93
5/16/2019	70	1600 Block of E Manor Dr.	3.19
5/16/2019	15	6100 Block of Parkway Dr.	3.21
5/16/2019	73	5600 Block of King Trl.	3.18
5/16/2019	61	200 Block of Saratoga Blvd.	3.47
5/16/2019	26	200 Block of Eastgate Dr.	3.10
5/16/2019	87	5200 Block of Northwest Trl.	3.41
5/17/2019	94	15200 Block of Caravel Dr.	3.02
5/17/2019	24	2300 Block of Rodd Field Rd.	3.09
5/17/2019	39	5900 Block of Long Creek Dr.	3.02
5/17/2019	55	500 Block of Belden St.	3.39
5/17/2019	18	900 Block of Nueces Bay Blvd.	3.63
5/17/2019	1	4800 Block of Neptune St.	3.55
5/17/2019	62	5800 Block of Hampshire Rd.	3.57

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/17/2019	16	4200 Block of Wildcat Dr.	3.60
5/18/2019	98	15800 Block of Almeria Ave.	2.43
5/18/2019	38	7500 Block of Annemasse St.	3.30
5/18/2019	25	4100 Block of Bascule Dr.	3.23
5/18/2019	93	11000 Block of Annaville Rd.	3.72
5/19/2019	97	13900 Block of Skysail St.	3.19
5/19/2019	8	1100 Block of Cornerstone Dr.	3.03
5/19/2019	26	200 Block of Eastgate Dr.	3.23
5/19/2019	86	14800 Block of Santa Gertrudis Dr.	3.03
5/20/2019	58	4800 Block of French Dr.	3.11
5/20/2019	19	1300 Block of Horne Rd.	3.47
5/20/2019	92	300 Block of Wildwood Dr.	4.07
5/20/2019	96	14900 Block of Windward Dr.	2.77
5/20/2019	38	7500 Block of Annemasse St.	2.97
5/20/2019	80	7000 Block of Arapahoe St.	3.28
5/20/2019	35	4700 Block of Congressional Dr.	3.43
5/20/2019	83	4100 Block of Summit Dr.	2.59
5/20/2019	40	9500 Block of Quetzal St.	2.73
5/20/2019	76	1100 Block of Harbor Lights Dr.	2.94
5/20/2019	85	300 Block of Glenmore St.	2.80
5/20/2019	77	5000 Block of Cape Ann Dr.	2.79
5/21/2019	97	13900 Block of Skysail St.	3.18
5/21/2019	43	200 Block of Caribbean Dr.	2.90
5/21/2019	37	6500 Block of Brockhampton St.	3.00
5/21/2019	34	4300 Block of Harry St.	3.18
5/21/2019	10	3100 Block of Saratoga Blvd.	2.99
5/21/2019	57	1400 Block of Arlington Dr.	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/21/2019	46	8900 Block of McNorton Rd.	3.74
5/22/2019	83	4100 Block of Summit Dr.	2.72
5/22/2019	40	9500 Block of Quetzal St.	2.98
5/22/2019	76	1100 Block of Harbor Lights Dr.	3.01
5/22/2019	85	300 Block of Glenmore St.	2.90
5/22/2019	77	5000 Block of Cape Ann Dr.	2.94
5/22/2019	94	15200 Block of Caravel Dr.	3.11
5/22/2019	41	1600 Block of Amber Dr.	3.04
5/22/2019	75	2900 Block of Oso Pkwy.	3.04
5/22/2019	81	6600 Block of Meadowheights Dr.	3.08
5/22/2019	5	4600 Block of Evelyn St.	3.10
5/22/2019	67	500 Block of S Carancahua St.	3.23
5/22/2019	53	9100 Block of Stock Dr.	3.08
5/22/2019	88	4200 Block of Western Dr.	3.84
5/23/2019	98	15800 Block of Almeria Ave.	2.86
5/23/2019	74	7900 Block of Impala Dr.	3.13
5/23/2019	78	7600 Block of Timber Crest Dr.	3.16
5/23/2019	69	4000 Block of Donaho Dr.	3.27
5/23/2019	66	600 Block of Southern St.	3.33
5/23/2019	64	4000 Block of Hidalgo St.	3.34
5/23/2019	91	2700 Block of Wind Rock Dr.	3.55
5/24/2019	4	14200 Block of Playa del Rey	3.09
5/24/2019	84	3600 Block of Flour Bluff Dr.	2.87
5/24/2019	99	3900 Block of Elvis Dr.	3.20
5/24/2019	22	6700 Block of Weber Rd.	3.23
5/24/2019	20	3900 Block of Cott St.	2.92
5/24/2019	6	1200 Block of 10th St.	3.02

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/24/2019	27	2800 Block of S Port Ave.	3.64
5/24/2019	89	3800 Block of Castle Ridge Dr.	3.33
5/25/2019	98	15800 Block of Almeria Ave.	3.13
5/25/2019	38	7500 Block of Annemasse St.	3.31
5/25/2019	25	4100 Block of Bascule Dr.	3.44
5/25/2019	93	11000 Block of Annaville Rd.	3.96
5/26/2019	97	13900 Block of Skysail St.	3.52
5/26/2019	8	1100 Block of Cornerstone Dr.	3.32
5/26/2019	26	200 Block of Eastgate Dr.	3.22
5/26/2019	86	14800 Block of Santa Gertrudis Dr.	3.16
5/27/2019	83	4100 Block of Summit Dr.	2.85
5/27/2019	40	9500 Block of Quetzal St.	2.76
5/27/2019	76	1100 Block of Harbor Lights Dr.	2.82
5/27/2019	85	300 Block of Glenmore St.	2.76
5/27/2019	77	5000 Block of Cape Ann Dr.	2.78
5/27/2019	96	14900 Block of Windward Dr.	3.25
5/27/2019	38	7500 Block of Annemasse St.	3.03
5/27/2019	80	7000 Block of Arapahoe St.	2.90
5/27/2019	35	4700 Block of Congressional Dr.	3.02
5/27/2019	58	4800 Block of French Dr.	2.80
5/27/2019	19	1300 Block of Horne Rd.	3.15
5/27/2019	92	300 Block of Wildwood Dr.	3.76
5/28/2019	98	15800 Block of Almeria Ave.	2.91
5/28/2019	82	2100 Block of Whispering Oak Dr.	2.80
5/28/2019	79	900 Block of Egyptian Dr.	2.91
5/28/2019	7	600 Block of Carmel Pkwy.	2.96
5/28/2019	59	3600 Block of Capri Dr.	3.15

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/28/2019	30	3100 Block of Brawner Pkwy.	3.05
5/28/2019	56	200 Block of Amistad St.	3.25
5/28/2019	90	11700 Block of Haven Dr.	3.63
5/29/2019	83	4100 Block of Summit Dr.	2.63
5/29/2019	40	9500 Block of Quetzal St.	2.78
5/29/2019	76	1100 Block of Harbor Lights Dr.	2.86
5/29/2019	85	300 Block of Glenmore St.	2.84
5/29/2019	77	5000 Block of Cape Ann Dr.	2.70
5/29/2019	97	13900 Block of Skysail St.	3.25
5/29/2019	11	500 Block of Military Dr.	2.51
5/29/2019	60	1300 Block of Calle San Marcos	3.20
5/29/2019	31	4300 Block of Cedar St.	3.20
5/29/2019	54	3700 Block of Seagull Blvd.	3.17
5/29/2019	12	2200 Block of Buford Ave.	3.30
5/29/2019	51	200 Block of Gibson Ln.	3.31
5/29/2019	93	11000 Block of Annville Rd.	3.83
5/29/2019	45	15200 Block of Cruiser St.	3.24
5/29/2019	36	1300 Block of Sandstone Dr.	3.07
5/29/2019	71	5500 Block of Fox Run Dr.	3.32
5/29/2019	68	5300 Block of Alejandro St.	3.19
5/29/2019	14	900 Block of Rosedale Dr.	3.03
5/29/2019	50	5500 Block of IH 37 Access Rd.	3.58
5/29/2019	47	8100 Block of Barrogate Dr.	3.61
5/29/2019	90	11700 Block of Haven Dr.	3.48
5/29/2019	67	500 Block of S Carancahua St.	3.10
5/30/2019	45	15200 Block of Cruiser St.	3.20
5/30/2019	42	700 Block of Orleans Dr.	3.06

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/30/2019	21	900 Block of Lum Ave.	3.02
5/30/2019	32	4900 Block of Haket Dr.	3.26
5/30/2019	28	1700 Block of Bois d' Arc Pl.	3.34
5/30/2019	9	1000 Block of International Dr.	3.31
5/30/2019	49	100 Block of Commerce St.	3.25
5/30/2019	91	2700 Block of Wind Rock Dr.	3.36
5/30/2019	95	15800 Block of El Socorro Loop	2.71
5/30/2019	72	7700 Block of Starnberg Lake Dr.	3.26
5/30/2019	2	5800 Block of St. Andrews Dr.	2.95
5/30/2019	33	3900 Block of Ocean Dr.	3.05
5/30/2019	25	4100 Block of Bascule Dr.	3.41
5/30/2019	48	1200 Block of Southern Minerals Rd.	3.59
5/30/2019	44	9600 Block of Wilkins Dr.	3.66
5/31/2019	4	14200 Block of Playa del Rey	3.03
5/31/2019	58	4800 Block of French Dr.	2.97
5/31/2019	29	1600 Block of La Joya St.	3.09
5/31/2019	88	4200 Block of Western Dr.	3.96
5/31/2019	21	900 Block of Lum Ave.	3.09

June

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/1/2019	98	15800 Block of Almeria Ave.	2.83
6/1/2019	38	7500 Block of Annemasse St.	3.13
6/1/2019	25	4100 Block of Bascule Dr.	3.38
6/1/2019	93	11000 Block of Annville Rd.	4.00
6/2/2019	97	13900 Block of Skysail St.	3.41

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/2/2019	8	1100 Block of Cornerstone Dr.	3.10
6/2/2019	26	200 Block of Eastgate Dr.	3.27
6/2/2019	86	14800 Block of Santa Gertrudis Dr.	3.36
6/3/2019	83	4100 Block of Summit Dr.	2.69
6/3/2019	40	9500 Block of Quetzal St.	2.74
6/3/2019	76	1100 Block of Harbor Lights Dr.	2.92
6/3/2019	85	300 Block of Glenmore St.	2.71
6/3/2019	77	5000 Block of Cape Ann Dr.	2.83
6/3/2019	4	14200 Block of Playa del Rey	3.20
6/3/2019	84	3600 Block of Flour Bluff Dr.	3.10
6/3/2019	99	3900 Block of Elvis Dr.	3.38
6/3/2019	22	6700 Block of Weber Rd.	3.42
6/3/2019	20	3900 Block of Cott St.	3.06
6/3/2019	6	1200 Block of 10th St.	3.02
6/3/2019	27	2800 Block of S Port Ave.	3.52
6/3/2019	89	3800 Block of Castle Ridge Dr.	3.51
6/4/2019	45	15200 Block of Cruiser St.	3.30
6/4/2019	42	700 Block of Orleans Dr.	3.04
6/4/2019	21	900 Block of Lum Ave.	3.07
6/4/2019	32	4900 Block of Hakel Dr.	3.33
6/4/2019	28	1700 Block of Bois d' Arc Pl.	3.65
6/4/2019	9	1000 Block of International Dr.	3.63
6/4/2019	49	100 Block of Commerce St.	3.57
6/4/2019	91	2700 Block of Wind Rock Dr.	3.62
6/5/2019	83	4100 Block of Summit Dr.	2.62
6/5/2019	40	9500 Block of Quetzal St.	2.93
6/5/2019	76	1100 Block of Harbor Lights Dr.	3.04

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/5/2019	85	300 Block of Glenmore St.	2.86
6/5/2019	77	5000 Block of Cape Ann Dr.	3.05
6/5/2019	98	15800 Block of Almeria Ave.	3.36
6/5/2019	82	2100 Block of Whispering Oak Dr.	3.10
6/5/2019	79	900 Block of Egyptian Dr.	3.16
6/5/2019	7	600 Block of Carmel Pkwy.	3.05
6/5/2019	59	3600 Block of Capri Dr.	3.28
6/5/2019	30	3100 Block of Brawner Pkwy.	3.14
6/5/2019	56	200 Block of Amistad St.	3.20
6/5/2019	90	11700 Block of Haven Dr.	3.78
6/6/2019	58	4800 Block of French Dr.	3.26
6/6/2019	95	15800 Block of El Socorro Loop	2.86
6/6/2019	59	3600 Block of Capri Dr.	3.26
6/6/2019	98	15800 Block of Almeria Ave.	3.46
6/6/2019	97	13900 Block of Skysail St.	3.51
6/6/2019	11	500 Block of Military Dr.	2.79
6/6/2019	60	1300 Block of Calle San Marcos	3.09
6/6/2019	31	4300 Block of Cedar St.	2.93
6/6/2019	54	3700 Block of Seagull Blvd.	3.16
6/6/2019	12	2200 Block of Buford Ave.	3.57
6/6/2019	51	200 Block of Gibson Ln.	3.50
6/6/2019	93	11000 Block of Annville Rd.	3.86
6/6/2019	45	15200 Block of Cruiser St.	3.24
6/6/2019	36	1300 Block of Sandstone Dr.	3.01
6/6/2019	71	5500 Block of Fox Run Dr.	3.35
6/6/2019	68	5300 Block of Alejandro St.	3.41
6/6/2019	14	900 Block of Rosedale Dr.	3.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/6/2019	50	5500 Block of IH 37 Access Rd.	3.81
6/6/2019	47	8100 Block of Barrogate Dr.	3.83
6/6/2019	90	11700 Block of Haven Dr.	3.68
6/7/2019	95	15800 Block of El Socorro Loop	2.67
6/7/2019	72	7700 Block of Starnberg Lake Dr.	3.37
6/7/2019	2	5800 Block of St. Andrews Dr.	2.95
6/7/2019	33	3900 Block of Ocean Dr.	3.20
6/7/2019	25	4100 Block of Bascule Dr.	3.32
6/7/2019	48	1200 Block of Southern Minerals Rd.	3.80
6/7/2019	44	9600 Block of Wilkins Dr.	3.47
6/8/2019	98	15800 Block of Almeria Ave.	3.16
6/8/2019	38	7500 Block of Annemasse St.	3.40
6/8/2019	25	4100 Block of Bascule Dr.	3.43
6/8/2019	93	11000 Block of Annville Rd.	4.08
6/9/2019	97	13900 Block of Skysail St.	3.64
6/9/2019	8	1100 Block of Cornerstone Dr.	3.45
6/9/2019	26	200 Block of Eastgate Dr.	3.38
6/9/2019	86	14800 Block of Santa Gertrudis Dr.	3.10
6/10/2019	83	4100 Block of Summit Dr.	2.94
6/10/2019	40	9500 Block of Quetzal St.	2.95
6/10/2019	76	1100 Block of Harbor Lights Dr.	3.01
6/10/2019	85	300 Block of Glenmore St.	2.88
6/10/2019	77	5000 Block of Cape Ann Dr.	2.81
6/10/2019	4	14200 Block of Playa del Rey	3.56
6/10/2019	3	3000 Block of S Fork Dr.	3.43
6/10/2019	23	5500 Block of Wooldridge Rd.	3.34
6/10/2019	29	1600 Block of La Joya St.	3.35

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/10/2019	52	200 Block of Junior Beck Dr.	3.29
6/10/2019	13	1500 Block of 6th St.	3.25
6/10/2019	65	700 Block of Westchester Dr.	3.18
6/10/2019	86	14800 Block of Santa Gertrudis Dr.	3.42
6/11/2019	96	14900 Block of Windward Dr.	3.43
6/11/2019	8	1100 Block of Cornerstone Dr.	3.17
6/11/2019	70	1600 Block of E Manor Dr.	3.18
6/11/2019	15	6100 Block of Parkway Dr.	3.28
6/11/2019	73	5600 Block of King Trl.	3.33
6/11/2019	61	200 Block of Saratoga Blvd.	3.59
6/11/2019	26	200 Block of Eastgate Dr.	3.43
6/11/2019	87	5200 Block of Northwest Trl.	3.47
6/12/2019	83	4100 Block of Summit Dr.	2.84
6/12/2019	40	9500 Block of Quetzal St.	2.87
6/12/2019	76	1100 Block of Harbor Lights Dr.	2.89
6/12/2019	85	300 Block of Glenmore St.	2.70
6/12/2019	77	5000 Block of Cape Ann Dr.	2.95
6/12/2019	94	15200 Block of Caravel Dr.	3.23
6/12/2019	24	2300 Block of Rodd Field Rd.	3.17
6/12/2019	39	5900 Block of Long Creek Dr.	3.16
6/12/2019	55	500 Block of Belden St.	3.33
6/12/2019	18	900 Block of Nueces Bay Blvd.	3.67
6/12/2019	1	4800 Block of Neptune St.	3.29
6/12/2019	62	5800 Block of Hampshire Rd.	3.52
6/12/2019	16	4200 Block of Wildcat Dr.	3.32
6/12/2019	98	15800 Block of Almeria Ave.	2.99
6/12/2019	74	7900 Block of Impala Dr.	3.20

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/12/2019	78	7600 Block of Timber Crest Dr.	3.15
6/12/2019	69	4000 Block of Donaho Dr.	3.18
6/12/2019	66	600 Block of Southern St.	3.16
6/12/2019	64	4000 Block of Hidalgo St.	3.34
6/12/2019	91	2700 Block of Wind Rock Dr.	3.43
6/13/2019	97	13900 Block of Skysail St.	3.29
6/13/2019	43	200 Block of Caribbean Dr.	3.02
6/13/2019	37	6500 Block of Brockhampton St.	2.97
6/13/2019	34	4300 Block of Harry St.	3.01
6/13/2019	10	3100 Block of Saratoga Blvd.	2.93
6/13/2019	57	1400 Block of Arlington Dr.	3.27
6/13/2019	46	8900 Block of McNorton Rd.	3.56
6/13/2019	96	14900 Block of Windward Dr.	3.01
6/13/2019	38	7500 Block of Annemasse St.	3.19
6/13/2019	80	7000 Block of Arapahoe St.	3.32
6/13/2019	35	4700 Block of Congressional Dr.	2.97
6/13/2019	58	4800 Block of French Dr.	3.03
6/13/2019	19	1300 Block of Horne Rd.	3.36
6/13/2019	92	300 Block of Wildwood Dr.	3.83
6/14/2019	94	15200 Block of Caravel Dr.	3.08
6/14/2019	41	1600 Block of Amber Dr.	3.04
6/14/2019	75	2900 Block of Oso Pkwy.	3.15
6/14/2019	81	6600 Block of Meadowheights Dr.	3.19
6/14/2019	5	4600 Block of Evelyn St.	3.09
6/14/2019	67	500 Block of S Carancahua St.	3.17
6/14/2019	53	9100 Block of Stock Dr.	3.07
6/14/2019	88	4200 Block of Western Dr.	3.64

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/15/2019	98	15800 Block of Almeria Ave.	2.89
6/15/2019	38	7500 Block of Annemasse St.	2.96
6/15/2019	25	4100 Block of Bascule Dr.	3.42
6/15/2019	93	11000 Block of Annville Rd.	3.86
6/16/2019	97	13900 Block of Skysail St.	3.36
6/16/2019	8	1100 Block of Cornerstone Dr.	3.48
6/16/2019	26	200 Block of Eastgate Dr.	3.25
6/16/2019	86	14800 Block of Santa Gertrudis Dr.	2.83
6/17/2019	54	3700 Block of Seagull Blvd.	3.06
6/17/2019	12	2200 Block of Buford Ave.	3.50
6/17/2019	51	200 Block of Gibson Ln.	3.48
6/17/2019	93	11000 Block of Annville Rd.	3.94
6/17/2019	97	13900 Block of Skysail St.	3.57
6/17/2019	11	500 Block of Military Dr.	2.71
6/17/2019	60	1300 Block of Calle San Marcos	2.87
6/17/2019	31	4300 Block of Cedar St.	2.90
6/17/2019	83	4100 Block of Summit Dr.	2.62
6/17/2019	40	9500 Block of Quetzal St.	2.71
6/17/2019	76	1100 Block of Harbor Lights Dr.	2.80
6/17/2019	85	300 Block of Glenmore St.	2.65
6/17/2019	77	5000 Block of Cape Ann Dr.	2.72
6/18/2019	14	900 Block of Rosedale Dr.	3.30
6/18/2019	50	5500 Block of IH 37 Access Rd.	3.45
6/18/2019	47	8100 Block of Barrogate Dr.	3.76
6/18/2019	90	11700 Block of Haven Dr.	3.37
6/18/2019	45	15200 Block of Cruiser St.	3.66
6/18/2019	36	1300 Block of Sandstone Dr.	2.93

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/18/2019	71	5500 Block of Fox Run Dr.	3.08
6/18/2019	68	5300 Block of Alejandro St.	3.24
6/19/2019	33	3900 Block of Ocean Dr.	3.21
6/19/2019	25	4100 Block of Bascule Dr.	3.39
6/19/2019	48	1200 Block of Southern Minerals Rd.	3.77
6/19/2019	44	9600 Block of Wilkins Dr.	3.19
6/19/2019	95	15800 Block of El Socorro Loop	3.16
6/19/2019	72	7700 Block of Starnberg Lake Dr.	3.43
6/19/2019	2	5800 Block of St. Andrews Dr.	3.08
6/19/2019	83	4100 Block of Summit Dr.	2.66
6/19/2019	40	9500 Block of Quetzal St.	2.83
6/19/2019	76	1100 Block of Harbor Lights Dr.	2.74
6/19/2019	85	300 Block of Glenmore St.	2.83
6/19/2019	77	5000 Block of Cape Ann Dr.	2.86
6/19/2019	4	14200 Block of Playa del Rey	3.49
6/19/2019	84	3600 Block of Flour Bluff Dr.	3.18
6/19/2019	99	3900 Block of Elvis Dr.	3.45
6/19/2019	22	6700 Block of Weber Rd.	3.53
6/19/2019	20	3900 Block of Cott St.	3.33
6/19/2019	6	1200 Block of 10th St.	3.15
6/19/2019	27	2800 Block of S Port Ave.	3.53
6/19/2019	89	3800 Block of Castle Ridge Dr.	3.38
6/20/2019	45	15200 Block of Cruiser St.	3.54
6/20/2019	42	700 Block of Orleans Dr.	3.16
6/20/2019	21	900 Block of Lum Ave.	3.21
6/20/2019	32	4900 Block of Hakei Dr.	3.38
6/20/2019	28	1700 Block of Bois d' Arc Pl.	3.41

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/20/2019	9	1000 Block of International Dr.	3.34
6/20/2019	49	100 Block of Commerce St.	3.53
6/20/2019	91	2700 Block of Wind Rock Dr.	3.55
6/20/2019	98	15800 Block of Almeria Ave.	3.40
6/20/2019	82	2100 Block of Whispering Oak Dr.	3.26
6/20/2019	79	900 Block of Egyptian Dr.	3.21
6/20/2019	7	600 Block of Carmel Pkwy.	3.16
6/20/2019	59	3600 Block of Capri Dr.	3.39
6/20/2019	30	3100 Block of Brawner Pkwy.	3.12
6/20/2019	56	200 Block of Amistad St.	3.18
6/20/2019	90	11700 Block of Haven Dr.	3.63
6/21/2019	58	4800 Block of French Dr.	3.20
6/21/2019	95	15800 Block of El Socorro Loop	2.67
6/21/2019	59	3600 Block of Capri Dr.	3.23
6/21/2019	98	15800 Block of Almeria Ave.	2.84
6/21/2019	4	14200 Block of Playa del Rey	3.44
6/21/2019	3	3000 Block of S Fork Dr.	3.67
6/21/2019	23	5500 Block of Wooldridge Rd.	3.34
6/21/2019	29	1600 Block of La Joya St.	3.54
6/21/2019	52	200 Block of Junior Beck Dr.	3.49
6/21/2019	13	1500 Block of 6th St.	3.48
6/21/2019	65	700 Block of Westchester Dr.	3.10
6/21/2019	86	14800 Block of Santa Gertrudis Dr.	3.44
6/22/2019	98	15800 Block of Almeria Ave.	2.87
6/22/2019	38	7500 Block of Annemasse St.	3.42
6/22/2019	25	4100 Block of Bascule Dr.	3.42
6/22/2019	93	11000 Block of Annaville Rd.	3.93

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/23/2019	97	13900 Block of Skysail St.	3.28
6/23/2019	8	1100 Block of Cornerstone Dr.	3.35
6/23/2019	26	200 Block of Eastgate Dr.	3.43
6/23/2019	86	14800 Block of Santa Gertrudis Dr.	2.92
6/24/2019	83	4100 Block of Summit Dr.	2.97
6/24/2019	40	9500 Block of Quetzal St.	2.84
6/24/2019	76	1100 Block of Harbor Lights Dr.	2.98
6/24/2019	85	300 Block of Glenmore St.	2.76
6/24/2019	77	5000 Block of Cape Ann Dr.	3.01
6/24/2019	96	14900 Block of Windward Dr.	3.36
6/24/2019	8	1100 Block of Cornerstone Dr.	3.32
6/24/2019	70	1600 Block of E Manor Dr.	3.13
6/24/2019	15	6100 Block of Parkway Dr.	3.25
6/24/2019	73	5600 Block of King Trl.	3.77
6/24/2019	61	200 Block of Saratoga Blvd.	3.63
6/24/2019	26	200 Block of Eastgate Dr.	3.46
6/24/2019	87	5200 Block of Northwest Trl.	3.70
6/24/2019	28	1700 Block of Bois d' Arc Pl.	3.56
6/25/2019	94	15200 Block of Caravel Dr.	3.27
6/25/2019	24	2300 Block of Rodd Field Rd.	3.66
6/25/2019	39	5900 Block of Long Creek Dr.	3.17
6/25/2019	55	500 Block of Belden St.	3.53
6/25/2019	18	900 Block of Nueces Bay Blvd.	3.79
6/25/2019	1	4800 Block of Neptune St.	3.72
6/25/2019	62	5800 Block of Hampshire Rd.	3.65
6/25/2019	16	4200 Block of Wildcat Dr.	3.71
6/26/2019	83	4100 Block of Summit Dr.	2.59

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/26/2019	83	4100 Block of Summit Dr.	2.85
6/26/2019	40	9500 Block of Quetzal St.	2.89
6/26/2019	76	1100 Block of Harbor Lights Dr.	2.99
6/26/2019	85	300 Block of Glenmore St.	2.92
6/26/2019	77	5000 Block of Cape Ann Dr.	2.96
6/26/2019	98	15800 Block of Almeria Ave.	2.92
6/26/2019	74	7900 Block of Impala Dr.	3.32
6/26/2019	78	7600 Block of Timber Crest Dr.	3.42
6/26/2019	69	4000 Block of Donaho Dr.	3.49
6/26/2019	66	600 Block of Southern St.	3.51
6/26/2019	64	4000 Block of Hidalgo St.	3.55
6/26/2019	91	2700 Block of Wind Rock Dr.	3.63
6/26/2019	26	200 Block of Eastgate Dr.	3.17
6/26/2019	96	14900 Block of Windward Dr.	3.32
6/26/2019	38	7500 Block of Annemasse St.	3.40
6/26/2019	80	7000 Block of Arapahoe St.	3.05
6/26/2019	35	4700 Block of Congressional Dr.	3.26
6/26/2019	58	4800 Block of French Dr.	3.29
6/26/2019	19	1300 Block of Horne Rd.	3.41
6/26/2019	92	300 Block of Wildwood Dr.	3.81
6/26/2019	28	1700 Block of Bois d' Arc Pl.	3.59
6/27/2019	97	13900 Block of Skysail St.	3.40
6/27/2019	43	200 Block of Caribbean Dr.	3.15
6/27/2019	37	6500 Block of Brockhampton St.	3.19
6/27/2019	34	4300 Block of Harry St.	3.19
6/27/2019	10	3100 Block of Saratoga Blvd.	3.22
6/27/2019	57	1400 Block of Arlington Dr.	3.48

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/27/2019	46	8900 Block of McNorton Rd.	3.69
6/27/2019	94	15200 Block of Caravel Dr.	3.28
6/27/2019	41	1600 Block of Amber Dr.	3.20
6/27/2019	75	2900 Block of Oso Pkwy.	3.27
6/27/2019	81	6600 Block of Meadowheights Dr.	3.39
6/27/2019	5	4600 Block of Evelyn St.	3.18
6/27/2019	67	500 Block of S Carancahua St.	3.36
6/27/2019	53	9100 Block of Stock Dr.	3.10
6/27/2019	88	4200 Block of Western Dr.	3.98
6/27/2019	92	300 Block of Wildwood Dr.	3.83
6/27/2019	92	300 Block of Wildwood Dr.	3.93
6/27/2019	92	300 Block of Wildwood Dr.	3.92
6/28/2019	4	14200 Block of Playa del Rey	3.21
6/28/2019	21	900 Block of Lum Ave.	3.06
6/28/2019	29	1600 Block of La Joya St.	3.22
6/28/2019	88	4200 Block of Western Dr.	4.14
6/29/2019	98	15800 Block of Almeria Ave.	2.85
6/29/2019	38	7500 Block of Annemasse St.	3.33
6/29/2019	25	4100 Block of Bascule Dr.	3.58
6/29/2019	93	11000 Block of Annville Rd.	4.21
6/30/2019	97	13900 Block of Skysail St.	3.56
6/30/2019	8	1100 Block of Cornerstone Dr.	3.32
6/30/2019	26	200 Block of Eastgate Dr.	3.37
6/30/2019	86	14800 Block of Santa Gertrudis Dr.	3.47

July

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/1/2019	94	15200 Block of Caravel Dr.	3.27
7/1/2019	41	1600 Block of Amber Dr.	3.21
7/1/2019	75	2900 Block of Oso Pkwy.	3.36
7/1/2019	81	6600 Block of Meadowheights Dr.	3.06
7/1/2019	5	4600 Block of Evelyn St.	3.09
7/1/2019	67	500 Block of S Carancahua St.	3.37
7/1/2019	53	9100 Block of Stock Dr.	3.04
7/1/2019	88	4200 Block of Western Dr.	3.86
7/1/2019	83	4100 Block of Summit Dr.	2.70
7/1/2019	40	9500 Block of Quetzal St.	2.88
7/1/2019	76	1100 Block of Harbor Lights Dr.	2.92
7/1/2019	85	300 Block of Glenmore St.	2.85
7/1/2019	77	5000 Block of Cape Ann Dr.	2.87
7/2/2019	4	14200 Block of Playa del Rey	3.31
7/2/2019	84	3600 Block of Flour Bluff Dr.	3.22
7/2/2019	99	3900 Block of Elvis Dr.	3.40
7/2/2019	22	6700 Block of Weber Rd.	3.36
7/2/2019	20	3900 Block of Cott St.	3.12
7/2/2019	6	1200 Block of 10th St.	3.07
7/2/2019	27	2800 Block of S Port Ave.	3.43
7/2/2019	89	3800 Block of Castle Ridge Dr.	3.22
7/3/2019	58	4800 Block of French Dr.	3.05
7/3/2019	95	15800 Block of El Socorro Loop	2.83
7/3/2019	59	3600 Block of Capri Dr.	3.00

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/3/2019	98	15800 Block of Almeria Ave.	2.73
7/3/2019	45	15200 Block of Cruiser St.	2.94
7/3/2019	42	700 Block of Orleans Dr.	2.96
7/3/2019	21	900 Block of Lum Ave.	3.10
7/3/2019	32	4900 Block of Hakei Dr.	3.13
7/3/2019	28	1700 Block of Bois d' Arc Pl.	3.27
7/3/2019	9	1000 Block of International Dr.	3.19
7/3/2019	49	100 Block of Commerce St.	3.21
7/3/2019	91	2700 Block of Wind Rock Dr.	3.34
7/3/2019	83	4100 Block of Summit Dr.	2.75
7/3/2019	40	9500 Block of Quetzal St.	2.95
7/3/2019	76	1100 Block of Harbor Lights Dr.	2.78
7/3/2019	85	300 Block of Glenmore St.	2.71
7/3/2019	77	5000 Block of Cape Ann Dr.	2.78
7/4/2019	45	15200 Block of Cruiser St.	2.81
7/4/2019	36	1300 Block of Sandstone Dr.	2.66
7/4/2019	71	5500 Block of Fox Run Dr.	2.80
7/4/2019	68	5300 Block of Alejandro St.	3.18
7/4/2019	14	900 Block of Rosedale Dr.	2.76
7/4/2019	50	5500 Block of IH 37 Access Rd.	3.40
7/4/2019	47	8100 Block of Barrogate Dr.	3.64
7/4/2019	90	11700 Block of Haven Dr.	3.33
7/5/2019	97	13900 Block of Skysail St.	3.20
7/5/2019	11	500 Block of Military Dr.	2.68
7/5/2019	60	1300 Block of Calle San Marcos	2.89
7/5/2019	31	4300 Block of Cedar St.	2.99
7/5/2019	54	3700 Block of Seagull Blvd.	3.10

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/5/2019	12	2200 Block of Buford Ave.	3.38
7/5/2019	51	200 Block of Gibson Ln.	3.37
7/5/2019	93	11000 Block of Annville Rd.	3.81
7/6/2019	98	15800 Block of Almeria Ave.	3.02
7/6/2019	38	7500 Block of Annemasse St.	3.06
7/6/2019	25	4100 Block of Bascule Dr.	3.41
7/6/2019	93	11000 Block of Annville Rd.	3.84
7/7/2019	97	13900 Block of Skysail St.	3.36
7/7/2019	8	1100 Block of Cornerstone Dr.	3.03
7/7/2019	26	200 Block of Eastgate Dr.	3.39
7/7/2019	86	14800 Block of Santa Gertrudis Dr.	3.25
7/8/2019	52	200 Block of Junior Beck Dr.	3.49
7/8/2019	13	1500 Block of 6th St.	3.27
7/8/2019	65	700 Block of Westchester Dr.	3.22
7/8/2019	86	14800 Block of Santa Gertrudis Dr.	3.55
7/8/2019	4	14200 Block of Playa del Rey	3.65
7/8/2019	3	3000 Block of S Fork Dr.	3.28
7/8/2019	23	5500 Block of Wooldridge Rd.	3.25
7/8/2019	29	1600 Block of La Joya St.	3.34
7/8/2019	83	4100 Block of Summit Dr.	2.71
7/8/2019	40	9500 Block of Quetzal St.	2.92
7/8/2019	76	1100 Block of Harbor Lights Dr.	2.96
7/8/2019	85	300 Block of Glenmore St.	2.84
7/8/2019	77	5000 Block of Cape Ann Dr.	2.92
7/9/2019	96	14900 Block of Windward Dr.	3.49
7/9/2019	8	1100 Block of Cornerstone Dr.	3.56
7/9/2019	70	1600 Block of E Manor Dr.	3.33

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/9/2019	15	6100 Block of Parkway Dr.	3.26
7/9/2019	73	5600 Block of King Trl.	3.78
7/9/2019	61	200 Block of Saratoga Blvd.	3.74
7/9/2019	26	200 Block of Eastgate Dr.	3.42
7/9/2019	87	5200 Block of Northwest Trl.	3.56
7/10/2019	94	15200 Block of Caravel Dr.	3.36
7/10/2019	24	2300 Block of Rodd Field Rd.	3.60
7/10/2019	39	5900 Block of Long Creek Dr.	3.16
7/10/2019	55	500 Block of Belden St.	3.36
7/10/2019	18	900 Block of Nueces Bay Blvd.	3.75
7/10/2019	1	4800 Block of Neptune St.	3.60
7/10/2019	62	5800 Block of Hampshire Rd.	3.61
7/10/2019	16	4200 Block of Wildcat Dr.	3.73
7/10/2019	83	4100 Block of Summit Dr.	2.73
7/10/2019	40	9500 Block of Quetzal St.	2.82
7/10/2019	76	1100 Block of Harbor Lights Dr.	3.04
7/10/2019	85	300 Block of Glenmore St.	2.89
7/10/2019	77	5000 Block of Cape Ann Dr.	3.02
7/10/2019	96	14900 Block of Windward Dr.	3.43
7/10/2019	38	7500 Block of Annemasse St.	3.41
7/10/2019	80	7000 Block of Arapahoe St.	3.22
7/10/2019	35	4700 Block of Congressional Dr.	3.25
7/10/2019	58	4800 Block of French Dr.	3.22
7/10/2019	19	1300 Block of Horne Rd.	3.35
7/10/2019	92	300 Block of Wildwood Dr.	3.72
7/11/2019	98	15800 Block of Almeria Ave.	3.04
7/11/2019	78	7600 Block of Timber Crest Dr.	3.58

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/11/2019	69	4000 Block of Donaho Dr.	3.48
7/11/2019	66	600 Block of Southern St.	3.27
7/11/2019	64	4000 Block of Hidalgo St.	3.64
7/11/2019	91	2700 Block of Wind Rock Dr.	3.71
7/12/2019	97	13900 Block of Skysail St.	3.67
7/12/2019	43	200 Block of Caribbean Dr.	3.36
7/12/2019	37	6500 Block of Brockhampton St.	3.39
7/12/2019	34	4300 Block of Harry St.	3.20
7/12/2019	10	3100 Block of Saratoga Blvd.	3.09
7/12/2019	57	1400 Block of Arlington Dr.	3.33
7/12/2019	46	8900 Block of McNorton Rd.	3.63
7/13/2019	98	15800 Block of Almeria Ave.	3.32
7/13/2019	38	7500 Block of Annemasse St.	3.48
7/13/2019	25	4100 Block of Bascule Dr.	3.26
7/13/2019	93	11000 Block of Annville Rd.	4.14
7/14/2019	97	13900 Block of Skysail St.	3.61
7/14/2019	8	1100 Block of Cornerstone Dr.	3.73
7/14/2019	26	200 Block of Eastgate Dr.	3.54
7/14/2019	86	14800 Block of Santa Gertrudis Dr.	3.51
7/15/2019	83	4100 Block of Summit Dr.	3.01
7/15/2019	40	9500 Block of Quetzal St.	2.94
7/15/2019	76	1100 Block of Harbor Lights Dr.	3.05
7/15/2019	85	300 Block of Glenmore St.	2.91
7/15/2019	77	5000 Block of Cape Ann Dr.	3.10
7/15/2019	98	15800 Block of Almeria Ave.	3.00
7/15/2019	82	2100 Block of Whispering Oak Dr.	3.52
7/15/2019	79	900 Block of Egyptian Dr.	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/15/2019	7	600 Block of Carmel Pkwy.	3.22
7/15/2019	59	3600 Block of Capri Dr.	3.33
7/15/2019	30	3100 Block of Brawner Pkwy.	3.21
7/15/2019	56	200 Block of Amistad St.	3.26
7/15/2019	90	11700 Block of Haven Dr.	3.57
7/16/2019	95	15800 Block of El Socorro Loop	2.98
7/16/2019	72	7700 Block of Starnberg Lake Dr.	3.61
7/16/2019	2	5800 Block of St. Andrews Dr.	3.23
7/16/2019	33	3900 Block of Ocean Dr.	3.17
7/16/2019	25	4100 Block of Bascule Dr.	3.49
7/16/2019	48	1200 Block of Southern Minerals Rd.	3.85
7/16/2019	44	9600 Block of Wilkins Dr.	3.55
7/17/2019	74	7900 Block of Impala Dr.	3.69
7/17/2019	83	4100 Block of Summit Dr.	2.99
7/17/2019	40	9500 Block of Quetzal St.	2.95
7/17/2019	76	1100 Block of Harbor Lights Dr.	3.06
7/17/2019	85	300 Block of Glenmore St.	2.94
7/17/2019	77	5000 Block of Cape Ann Dr.	3.03
7/17/2019	4	14200 Block of Playa del Rey	3.61
7/17/2019	3	3000 Block of S Fork Dr.	3.79
7/17/2019	23	5500 Block of Wooldridge Rd.	3.31
7/17/2019	29	1600 Block of La Joya St.	3.46
7/17/2019	52	200 Block of Junior Beck Dr.	3.61
7/17/2019	13	1500 Block of 6th St.	3.59
7/17/2019	65	700 Block of Westchester Dr.	3.54
7/17/2019	86	14800 Block of Santa Gertrudis Dr.	3.59
7/17/2019	96	14900 Block of Windward Dr.	3.62

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/17/2019	8	1100 Block of Cornerstone Dr.	3.63
7/17/2019	70	1600 Block of E Manor Dr.	3.41
7/17/2019	15	6100 Block of Parkway Dr.	3.38
7/17/2019	73	5600 Block of King Trl.	3.72
7/17/2019	61	200 Block of Saratoga Blvd.	3.90
7/17/2019	26	200 Block of Eastgate Dr.	3.55
7/17/2019	87	5200 Block of Northwest Trl.	3.62
7/18/2019	94	15200 Block of Caravel Dr.	3.45
7/18/2019	24	2300 Block of Rodd Field Rd.	3.65
7/18/2019	39	5900 Block of Long Creek Dr.	3.48
7/18/2019	55	500 Block of Belden St.	3.65
7/18/2019	18	900 Block of Nueces Bay Blvd.	3.84
7/18/2019	1	4800 Block of Neptune St.	3.69
7/18/2019	62	5800 Block of Hampshire Rd.	3.70
7/18/2019	16	4200 Block of Wildcat Dr.	3.95
7/19/2019	98	15800 Block of Almeria Ave.	3.06
7/19/2019	74	7900 Block of Impala Dr.	3.72
7/19/2019	78	7600 Block of Timber Crest Dr.	3.83
7/19/2019	69	4000 Block of Donaho Dr.	3.62
7/19/2019	66	600 Block of Southern St.	3.60
7/19/2019	64	4000 Block of Hidalgo St.	3.62
7/19/2019	91	2700 Block of Wind Rock Dr.	3.61
7/20/2019	98	15800 Block of Almeria Ave.	3.62
7/20/2019	38	7500 Block of Annemasse St.	3.85
7/20/2019	25	4100 Block of Bascule Dr.	3.66
7/20/2019	93	11000 Block of Annville Rd.	4.03
7/21/2019	97	13900 Block of Skysail St.	3.87

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/21/2019	8	1100 Block of Cornerstone Dr.	3.72
7/21/2019	26	200 Block of Eastgate Dr.	3.57
7/21/2019	86	14800 Block of Santa Gertrudis Dr.	3.57
7/22/2019	83	4100 Block of Summit Dr.	3.27
7/22/2019	40	9500 Block of Quetzal St.	3.14
7/22/2019	76	1100 Block of Harbor Lights Dr.	3.14
7/22/2019	85	300 Block of Glenmore St.	3.04
7/22/2019	77	5000 Block of Cape Ann Dr.	3.16
7/22/2019	96	14900 Block of Windward Dr.	3.68
7/22/2019	38	7500 Block of Annemasse St.	3.77
7/22/2019	80	7000 Block of Arapahoe St.	3.35
7/22/2019	35	4700 Block of Congressional Dr.	3.46
7/22/2019	58	4800 Block of French Dr.	3.29
7/22/2019	19	1300 Block of Horne Rd.	3.49
7/22/2019	92	300 Block of Wildwood Dr.	3.88
7/23/2019	94	15200 Block of Caravel Dr.	3.35
7/23/2019	41	1600 Block of Amber Dr.	3.74
7/23/2019	75	2900 Block of Oso Pkwy.	3.88
7/23/2019	81	6600 Block of Meadowheights Dr.	3.70
7/23/2019	5	4600 Block of Evelyn St.	3.40
7/23/2019	67	500 Block of S Carancahua St.	3.75
7/23/2019	53	9100 Block of Stock Dr.	3.47
7/23/2019	88	4200 Block of Western Dr.	4.14
7/23/2019	97	13900 Block of Skysail St.	3.73
7/23/2019	43	200 Block of Caribbean Dr.	3.57
7/23/2019	37	6500 Block of Brockhampton St.	3.87
7/23/2019	34	4300 Block of Harry St.	3.45

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/23/2019	10	3100 Block of Saratoga Blvd.	3.40
7/23/2019	57	1400 Block of Arlington Dr.	3.65
7/23/2019	46	8900 Block of McNorton Rd.	3.83
7/24/2019	83	4100 Block of Summit Dr.	3.13
7/24/2019	40	9500 Block of Quetzal St.	3.11
7/24/2019	76	1100 Block of Harbor Lights Dr.	3.16
7/24/2019	85	300 Block of Glenmore St.	3.01
7/24/2019	77	5000 Block of Cape Ann Dr.	3.23
7/24/2019	4	14200 Block of Playa del Rey	3.47
7/24/2019	84	3600 Block of Flour Bluff Dr.	3.50
7/24/2019	99	3900 Block of Elvis Dr.	3.54
7/24/2019	22	6700 Block of Weber Rd.	3.29
7/24/2019	20	3900 Block of Cott St.	3.44
7/24/2019	6	1200 Block of 10th St.	3.40
7/24/2019	27	2800 Block of S Port Ave.	3.43
7/24/2019	89	3800 Block of Castle Ridge Dr.	3.52
7/25/2019	45	15200 Block of Cruiser St.	3.06
7/25/2019	42	700 Block of Orleans Dr.	3.47
7/25/2019	21	900 Block of Lum Ave.	3.16
7/25/2019	32	4900 Block of Hakel Dr.	3.44
7/25/2019	28	1700 Block of Bois d' Arc Pl.	3.56
7/25/2019	9	1000 Block of International Dr.	3.52
7/25/2019	49	100 Block of Commerce St.	3.52
7/25/2019	91	2700 Block of Wind Rock Dr.	3.93
7/26/2019	98	15800 Block of Almeria Ave.	3.02
7/26/2019	82	2100 Block of Whispering Oak Dr.	3.66
7/26/2019	79	900 Block of Egyptian Dr.	3.20

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/26/2019	7	600 Block of Carmel Pkwy.	3.46
7/26/2019	7	600 Block of Carmel Pkwy.	3.27
7/26/2019	59	3600 Block of Capri Dr.	3.10
7/26/2019	30	3100 Block of Brawner Pkwy.	3.47
7/26/2019	56	200 Block of Amistad St.	3.45
7/26/2019	90	11700 Block of Haven Dr.	3.98
7/27/2019	98	15800 Block of Almeria Ave.	3.60
7/27/2019	38	7500 Block of Annemasse St.	3.64
7/27/2019	25	4100 Block of Bascule Dr.	3.72
7/27/2019	93	11000 Block of Annville Rd.	4.21
7/28/2019	97	13900 Block of Skysail St.	3.52
7/28/2019	8	1100 Block of Cornerstone Dr.	3.52
7/28/2019	26	200 Block of Eastgate Dr.	3.64
7/28/2019	86	14800 Block of Santa Gertrudis Dr.	3.25
7/29/2019	45	15200 Block of Cruiser St.	3.52
7/29/2019	36	1300 Block of Sandstone Dr.	3.31
7/29/2019	71	5500 Block of Fox Run Dr.	3.44
7/29/2019	68	5300 Block of Alejandro St.	3.37
7/29/2019	14	900 Block of Rosedale Dr.	3.40
7/29/2019	50	5500 Block of IH 37 Access Rd.	3.73
7/29/2019	47	8100 Block of Barrogate Dr.	3.93
7/29/2019	90	11700 Block of Haven Dr.	3.63
7/29/2019	97	13900 Block of Skysail St.	3.59
7/29/2019	11	500 Block of Military Dr.	3.13
7/29/2019	60	1300 Block of Calle San Marcos	3.42
7/29/2019	31	4300 Block of Cedar St.	3.42
7/29/2019	54	3700 Block of Seagull Blvd.	3.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/29/2019	12	2200 Block of Buford Ave.	3.77
7/29/2019	51	200 Block of Gibson Ln.	3.68
7/29/2019	93	11000 Block of Annville Rd.	4.11
7/29/2019	83	4100 Block of Summit Dr.	3.09
7/29/2019	40	9500 Block of Quetzal St.	3.20
7/29/2019	76	1100 Block of Harbor Lights Dr.	3.27
7/29/2019	85	300 Block of Glenmore St.	3.11
7/29/2019	77	5000 Block of Cape Ann Dr.	3.29
7/29/2019	74	7900 Block of Impala Dr.	3.47
7/29/2019	21	900 Block of Lum Ave.	3.47
7/29/2019	32	4900 Block of Hakel Dr.	3.58
7/29/2019	28	1700 Block of Bois d' Arc Pl.	3.60
7/30/2019	95	15800 Block of El Socorro Loop	2.97
7/30/2019	72	7700 Block of Starnberg Lake Dr.	3.83
7/30/2019	2	5800 Block of St. Andrews Dr.	3.36
7/30/2019	33	3900 Block of Ocean Dr.	3.36
7/30/2019	25	4100 Block of Bascule Dr.	3.62
7/30/2019	48	1200 Block of Southern Minerals Rd.	3.82
7/30/2019	44	9600 Block of Wilkins Dr.	3.47
7/31/2019	4	14200 Block of Playa del Rey	3.50
7/31/2019	58	4800 Block of French Dr.	3.32
7/31/2019	29	1600 Block of La Joya St.	3.40
7/31/2019	88	4200 Block of Western Dr.	3.88
7/31/2019	83	4100 Block of Summit Dr.	3.08
7/31/2019	40	9500 Block of Quetzal St.	3.15
7/31/2019	76	1100 Block of Harbor Lights Dr.	3.23
7/31/2019	85	300 Block of Glenmore St.	3.07

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/31/2019	77	5000 Block of Cape Ann Dr.	3.17

August

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/1/2019	97	13900 Block of Skysail St.	3.43
8/1/2019	43	200 Block of Caribbean Dr.	3.39
8/1/2019	37	6500 Block of Brockhampton St.	3.59
8/1/2019	34	4300 Block of Harry St.	3.34
8/1/2019	10	3100 Block of Saratoga Blvd.	3.11
8/1/2019	57	1400 Block of Arlington Dr.	3.20
8/1/2019	46	8900 Block of McNorton Rd.	3.61
8/1/2019	96	14900 Block of Windward Dr.	3.25
8/1/2019	38	7500 Block of Annemasse St.	3.55
8/1/2019	80	7000 Block of Arapahoe St.	3.29
8/1/2019	35	4700 Block of Congressional Dr.	3.42
8/1/2019	58	4800 Block of French Dr.	3.10
8/1/2019	19	1300 Block of Horne Rd.	3.47
8/1/2019	92	300 Block of Wildwood Dr.	3.64
8/1/2019	58	4800 Block of French Dr.	3.22
8/1/2019	95	15800 Block of El Socorro Loop	3.02
8/1/2019	59	3600 Block of Capri Dr.	3.31
8/1/2019	98	15800 Block of Almeria Ave.	3.06
8/2/2019	94	15200 Block of Caravel Dr.	3.25
8/2/2019	41	1600 Block of Amber Dr.	3.36
8/2/2019	75	2900 Block of Oso Pkwy.	3.60
8/2/2019	81	6600 Block of Meadowheights Dr.	3.58

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/2/2019	5	4600 Block of Evelyn St.	3.15
8/2/2019	67	500 Block of S Carancahua St.	3.37
8/2/2019	53	9100 Block of Stock Dr.	3.07
8/2/2019	88	4200 Block of Western Dr.	3.85
8/3/2019	98	15800 Block of Almeria Ave.	2.99
8/3/2019	38	7500 Block of Annemasse St.	3.57
8/3/2019	25	4100 Block of Bascule Dr.	3.28
8/3/2019	93	11000 Block of Annville Rd.	3.90
8/4/2019	97	13900 Block of Skysail St.	3.31
8/4/2019	8	1100 Block of Cornerstone Dr.	3.64
8/4/2019	26	200 Block of Eastgate Dr.	3.12
8/4/2019	86	14800 Block of Santa Gertrudis Dr.	3.12
8/5/2019	4	14200 Block of Playa del Rey	3.28
8/5/2019	84	3600 Block of Flour Bluff Dr.	3.52
8/5/2019	99	3900 Block of Elvis Dr.	3.70
8/5/2019	22	6700 Block of Weber Rd.	3.06
8/5/2019	20	3900 Block of Cott St.	2.93
8/5/2019	6	1200 Block of 10th St.	3.26
8/5/2019	27	2800 Block of S Port Ave.	1.89
8/5/2019	89	3800 Block of Castle Ridge Dr.	3.20
8/5/2019	83	4100 Block of Summit Dr.	2.99
8/5/2019	40	9500 Block of Quetzal St.	3.02
8/5/2019	76	1100 Block of Harbor Lights Dr.	3.00
8/5/2019	85	300 Block of Glenmore St.	2.93
8/5/2019	77	5000 Block of Cape Ann Dr.	2.95
8/5/2019	27	2800 Block of S Port Ave.	2.43
8/6/2019	28	1700 Block of Bois d' Arc Pl.	3.31

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/6/2019	9	1000 Block of International Dr.	3.20
8/6/2019	49	100 Block of Commerce St.	3.68
8/6/2019	91	2700 Block of Wind Rock Dr.	3.47
8/6/2019	45	15200 Block of Cruiser St.	3.19
8/6/2019	42	700 Block of Orleans Dr.	2.97
8/6/2019	21	900 Block of Lum Ave.	2.90
8/6/2019	32	4900 Block of Hakel Dr.	3.27
8/7/2019	83	4100 Block of Summit Dr.	2.71
8/7/2019	40	9500 Block of Quetzal St.	3.49
8/7/2019	76	1100 Block of Harbor Lights Dr.	3.00
8/7/2019	85	300 Block of Glenmore St.	2.75
8/7/2019	77	5000 Block of Cape Ann Dr.	2.90
8/7/2019	98	15800 Block of Almeria Ave.	2.94
8/7/2019	82	2100 Block of Whispering Oak Dr.	3.55
8/7/2019	79	900 Block of Egyptian Dr.	3.26
8/7/2019	7	600 Block of Carmel Pkwy.	3.17
8/7/2019	59	3600 Block of Capri Dr.	3.31
8/7/2019	30	3100 Block of Brawner Pkwy.	2.75
8/7/2019	56	200 Block of Amistad St.	3.34
8/7/2019	90	11700 Block of Haven Dr.	3.56
8/8/2019	45	15200 Block of Cruiser St.	3.44
8/8/2019	36	1300 Block of Sandstone Dr.	3.24
8/8/2019	71	5500 Block of Fox Run Dr.	3.39
8/8/2019	68	5300 Block of Alejandro St.	3.59
8/8/2019	14	900 Block of Rosedale Dr.	3.37
8/8/2019	14	900 Block of Rosedale Dr.	3.47
8/8/2019	50	5500 Block of IH 37 Access Rd.	3.51

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/8/2019	47	8100 Block of Barrogate Dr.	3.70
8/8/2019	90	11700 Block of Haven Dr.	3.61
8/8/2019	97	13900 Block of Skysail St.	3.44
8/8/2019	11	500 Block of Military Dr.	3.13
8/8/2019	60	1300 Block of Calle San Marcos	3.56
8/8/2019	54	3700 Block of Seagull Blvd.	3.22
8/8/2019	12	2200 Block of Buford Ave.	3.63
8/8/2019	51	200 Block of Gibson Ln.	3.46
8/8/2019	93	11000 Block of Annville Rd.	3.82
8/9/2019	95	15800 Block of El Socorro Loop	3.14
8/9/2019	72	7700 Block of Starnberg Lake Dr.	3.69
8/9/2019	2	5800 Block of St. Andrews Dr.	3.10
8/9/2019	33	3900 Block of Ocean Dr.	3.14
8/9/2019	25	4100 Block of Bascule Dr.	3.31
8/9/2019	48	1200 Block of Southern Minerals Rd.	3.44
8/9/2019	44	9600 Block of Wilkins Dr.	3.06
8/10/2019	98	15800 Block of Almeria Ave.	2.93
8/10/2019	38	7500 Block of Annemasse St.	3.77
8/10/2019	25	4100 Block of Bascule Dr.	3.37
8/10/2019	93	11000 Block of Annville Rd.	3.70
8/11/2019	97	13900 Block of Skysail St.	3.34
8/11/2019	8	1100 Block of Cornerstone Dr.	3.52
8/11/2019	26	200 Block of Eastgate Dr.	3.35
8/11/2019	86	14800 Block of Santa Gertrudis Dr.	3.23
8/12/2019	83	4100 Block of Summit Dr.	2.83
8/12/2019	40	9500 Block of Quetzal St.	2.97
8/12/2019	76	1100 Block of Harbor Lights Dr.	3.80

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/12/2019	85	300 Block of Glenmore St.	2.82
8/12/2019	77	5000 Block of Cape Ann Dr.	2.91
8/12/2019	4	14200 Block of Playa del Rey	3.33
8/12/2019	3	3000 Block of S Fork Dr.	3.87
8/12/2019	23	5500 Block of Wooldridge Rd.	3.49
8/12/2019	29	1600 Block of La Joya St.	3.48
8/12/2019	52	200 Block of Junior Beck Dr.	3.64
8/12/2019	13	1500 Block of 6th St.	3.33
8/12/2019	65	700 Block of Westchester Dr.	3.56
8/12/2019	86	14800 Block of Santa Gertrudis Dr.	3.56
8/13/2019	96	14900 Block of Windward Dr.	3.46
8/13/2019	8	1100 Block of Cornerstone Dr.	3.75
8/13/2019	70	1600 Block of E Manor Dr.	3.42
8/13/2019	15	6100 Block of Parkway Dr.	3.69
8/13/2019	73	5600 Block of King Trl.	3.94
8/13/2019	61	200 Block of Saratoga Blvd.	3.56
8/13/2019	26	200 Block of Eastgate Dr.	3.41
8/13/2019	87	5200 Block of Northwest Trl.	3.77
8/13/2019	31	4300 Block of Cedar St.	3.35
8/14/2019	83	4100 Block of Summit Dr.	3.07
8/14/2019	40	9500 Block of Quetzal St.	3.18
8/14/2019	76	1100 Block of Harbor Lights Dr.	3.38
8/14/2019	85	300 Block of Glenmore St.	3.05
8/14/2019	77	5000 Block of Cape Ann Dr.	3.11
8/14/2019	94	15200 Block of Caravel Dr.	3.39
8/14/2019	24	2300 Block of Rodd Field Rd.	3.87
8/14/2019	39	5900 Block of Long Creek Dr.	3.43

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/14/2019	55	500 Block of Belden St.	3.47
8/14/2019	18	900 Block of Nueces Bay Blvd.	3.74
8/14/2019	1	4800 Block of Neptune St.	3.57
8/14/2019	62	5800 Block of Hampshire Rd.	3.64
8/14/2019	16	4200 Block of Wildcat Dr.	3.74
8/14/2019	98	15800 Block of Almeria Ave.	3.28
8/14/2019	74	7900 Block of Impala Dr.	3.54
8/14/2019	78	7600 Block of Timber Crest Dr.	3.84
8/14/2019	69	4000 Block of Donaho Dr.	3.20
8/14/2019	66	600 Block of Southern St.	3.29
8/14/2019	64	4000 Block of Hidalgo St.	3.69
8/14/2019	91	2700 Block of Wind Rock Dr.	3.46
8/15/2019	96	14900 Block of Windward Dr.	3.02
8/15/2019	38	7500 Block of Annemasse St.	3.80
8/15/2019	80	7000 Block of Arapahoe St.	3.76
8/15/2019	35	4700 Block of Congressional Dr.	3.42
8/15/2019	58	4800 Block of French Dr.	3.36
8/15/2019	19	1300 Block of Horne Rd.	3.57
8/15/2019	92	300 Block of Wildwood Dr.	3.89
8/16/2019	97	13900 Block of Skysail St.	3.63
8/16/2019	43	200 Block of Caribbean Dr.	3.81
8/16/2019	37	6500 Block of Brockhampton St.	3.78
8/16/2019	34	4300 Block of Harry St.	3.41
8/16/2019	10	3100 Block of Saratoga Blvd.	3.38
8/16/2019	57	1400 Block of Arlington Dr.	3.33
8/16/2019	46	8900 Block of McNorton Rd.	3.69
8/17/2019	98	15800 Block of Almeria Ave.	3.23

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/17/2019	38	7500 Block of Annemasse St.	3.92
8/17/2019	25	4100 Block of Bascule Dr.	3.59
8/17/2019	93	11000 Block of Annaville Rd.	4.05
8/18/2019	97	13900 Block of Skysail St.	3.48
8/18/2019	8	1100 Block of Cornerstone Dr.	3.74
8/18/2019	26	200 Block of Eastgate Dr.	3.41
8/18/2019	86	14800 Block of Santa Gertrudis Dr.	3.46
8/19/2019	54	3700 Block of Seagull Blvd.	3.20
8/19/2019	12	2200 Block of Buford Ave.	3.43
8/19/2019	51	200 Block of Gibson Ln.	3.36
8/19/2019	93	11000 Block of Annaville Rd.	3.64
8/19/2019	97	13900 Block of Skysail St.	3.51
8/19/2019	11	500 Block of Military Dr.	3.49
8/19/2019	60	1300 Block of Calle San Marcos	3.29
8/19/2019	31	4300 Block of Cedar St.	3.10
8/19/2019	83	4100 Block of Summit Dr.	2.96
8/19/2019	40	9500 Block of Quetzal St.	3.09
8/19/2019	76	1100 Block of Harbor Lights Dr.	3.52
8/19/2019	85	300 Block of Glenmore St.	2.87
8/19/2019	77	5000 Block of Cape Ann Dr.	3.11
8/20/2019	14	900 Block of Rosedale Dr.	2.79
8/20/2019	50	5500 Block of IH 37 Access Rd.	3.21
8/20/2019	47	8100 Block of Barrogate Dr.	3.50
8/20/2019	90	11700 Block of Haven Dr.	3.15
8/20/2019	45	15200 Block of Cruiser St.	3.29
8/20/2019	36	1300 Block of Sandstone Dr.	2.97
8/20/2019	71	5500 Block of Fox Run Dr.	3.08

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/20/2019	68	5300 Block of Alejandro St.	3.02
8/21/2019	83	4100 Block of Summit Dr.	2.75
8/21/2019	40	9500 Block of Quetzal St.	2.79
8/21/2019	76	1100 Block of Harbor Lights Dr.	3.30
8/21/2019	85	300 Block of Glenmore St.	2.65
8/21/2019	77	5000 Block of Cape Ann Dr.	2.64
8/21/2019	95	15800 Block of El Socorro Loop	2.82
8/21/2019	72	7700 Block of Starnberg Lake Dr.	3.61
8/21/2019	2	5800 Block of St. Andrews Dr.	2.69
8/21/2019	33	3900 Block of Ocean Dr.	3.09
8/21/2019	25	4100 Block of Bascule Dr.	3.34
8/21/2019	48	1200 Block of Southern Minerals Rd.	3.74
8/21/2019	44	9600 Block of Wilkins Dr.	3.61
8/21/2019	27	2800 Block of S Port Ave.	3.46
8/22/2019	4	14200 Block of Playa del Rey	3.20
8/22/2019	84	3600 Block of Flour Bluff Dr.	3.26
8/22/2019	99	3900 Block of Elvis Dr.	3.64
8/22/2019	22	6700 Block of Weber Rd.	3.17
8/22/2019	20	3900 Block of Cott St.	3.43
8/22/2019	6	1200 Block of 10th St.	3.23
8/22/2019	27	2800 Block of S Port Ave.	3.46
8/22/2019	89	3800 Block of Castle Ridge Dr.	3.34
8/22/2019	94	15200 Block of Caravel Dr.	3.05
8/22/2019	41	1600 Block of Amber Dr.	3.34
8/22/2019	75	2900 Block of Oso Pkwy.	3.47
8/22/2019	81	6600 Block of Meadowheights Dr.	3.45
8/22/2019	5	4600 Block of Evelyn St.	3.15

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/22/2019	67	500 Block of S Carancahua St.	3.43
8/22/2019	53	9100 Block of Stock Dr.	3.23
8/22/2019	88	4200 Block of Western Dr.	3.97
8/23/2019	45	15200 Block of Cruiser St.	3.18
8/23/2019	42	700 Block of Orleans Dr.	3.14
8/23/2019	21	900 Block of Lum Ave.	3.08
8/23/2019	32	4900 Block of Haket Dr.	3.56
8/23/2019	28	1700 Block of Bois d' Arc Pl.	3.40
8/23/2019	9	1000 Block of International Dr.	3.24
8/23/2019	49	100 Block of Commerce St.	3.50
8/23/2019	91	2700 Block of Wind Rock Dr.	3.40
8/24/2019	98	15800 Block of Almeria Ave.	3.15
8/24/2019	38	7500 Block of Annemasse St.	3.42
8/24/2019	25	4100 Block of Bascule Dr.	3.45
8/24/2019	93	11000 Block of Annville Rd.	3.87
8/25/2019	97	13900 Block of Skysail St.	3.48
8/25/2019	8	1100 Block of Cornerstone Dr.	3.41
8/25/2019	26	200 Block of Eastgate Dr.	3.23
8/25/2019	86	14800 Block of Santa Gertrudis Dr.	3.13
8/26/2019	83	4100 Block of Summit Dr.	2.66
8/26/2019	40	9500 Block of Quetzal St.	3.24
8/26/2019	76	1100 Block of Harbor Lights Dr.	3.38
8/26/2019	85	300 Block of Glenmore St.	2.81
8/26/2019	77	5000 Block of Cape Ann Dr.	2.86
8/26/2019	98	15800 Block of Almeria Ave.	3.09
8/26/2019	82	2100 Block of Whispering Oak Dr.	3.32
8/26/2019	79	900 Block of Egyptian Dr.	2.93

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/26/2019	7	600 Block of Carmel Pkwy.	2.87
8/26/2019	59	3600 Block of Capri Dr.	3.01
8/26/2019	30	3100 Block of Brawner Pkwy.	3.16
8/26/2019	56	200 Block of Amistad St.	3.14
8/26/2019	90	11700 Block of Haven Dr.	3.48
8/27/2019	4	14200 Block of Playa del Rey	3.14
8/27/2019	3	3000 Block of S Fork Dr.	3.50
8/27/2019	23	5500 Block of Wooldridge Rd.	3.26
8/27/2019	29	1600 Block of La Joya St.	3.06
8/27/2019	52	200 Block of Junior Beck Dr.	3.20
8/27/2019	13	1500 Block of 6th St.	3.01
8/27/2019	65	700 Block of Westchester Dr.	3.14
8/27/2019	86	14800 Block of Santa Gertrudis Dr.	3.00
8/28/2019	96	14900 Block of Windward Dr.	2.95
8/28/2019	8	1100 Block of Cornerstone Dr.	3.00
8/28/2019	70	1600 Block of E Manor Dr.	2.83
8/28/2019	15	6100 Block of Parkway Dr.	2.89
8/28/2019	73	5600 Block of King Trl.	3.26
8/28/2019	61	200 Block of Saratoga Blvd.	3.33
8/28/2019	26	200 Block of Eastgate Dr.	2.99
8/28/2019	87	5200 Block of Northwest Trl.	3.36
8/28/2019	94	15200 Block of Caravel Dr.	2.68
8/28/2019	24	2300 Block of Rodd Field Rd.	3.15
8/28/2019	39	5900 Block of Long Creek Dr.	2.89
8/28/2019	55	500 Block of Belden St.	3.01
8/28/2019	18	900 Block of Nueces Bay Blvd.	3.27
8/28/2019	1	4800 Block of Neptune St.	3.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/28/2019	62	5800 Block of Hampshire Rd.	3.15
8/28/2019	16	4200 Block of Wildcat Dr.	3.60
8/28/2019	83	4100 Block of Summit Dr.	2.73
8/28/2019	40	9500 Block of Quetzal St.	2.90
8/28/2019	76	1100 Block of Harbor Lights Dr.	2.77
8/28/2019	85	300 Block of Glenmore St.	2.62
8/28/2019	77	5000 Block of Cape Ann Dr.	2.66
8/29/2019	98	15800 Block of Almeria Ave.	2.58
8/29/2019	74	7900 Block of Impala Dr.	3.26
8/29/2019	78	7600 Block of Timber Crest Dr.	3.38
8/29/2019	69	4000 Block of Donaho Dr.	3.39
8/29/2019	66	600 Block of Southern St.	3.49
8/29/2019	64	4000 Block of Hidalgo St.	3.48
8/29/2019	91	2700 Block of Wind Rock Dr.	3.52
8/30/2019	4	14200 Block of Playa del Rey	2.98
8/30/2019	58	4800 Block of French Dr.	3.21
8/30/2019	29	1600 Block of La Joya St.	3.25
8/30/2019	88	4200 Block of Western Dr.	4.04
8/31/2019	98	15800 Block of Almeria Ave.	2.79
8/31/2019	38	7500 Block of Annemasse St.	3.92
8/31/2019	25	4100 Block of Bascule Dr.	3.70
8/31/2019	93	11000 Block of Annville Rd.	3.84

September

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/1/2019	97	13900 Block of Skysail St.	3.55
9/1/2019	8	1100 Block of Cornerstone Dr.	3.54
9/1/2019	26	200 Block of Eastgate Dr.	3.39
9/1/2019	86	14800 Block of Santa Gertrudis Dr.	3.14
9/2/2019	4	14200 Block of Playa del Rey	3.26
9/2/2019	84	3600 Block of Flour Bluff Dr.	3.51
9/2/2019	99	3900 Block of Elvis Dr.	3.71
9/2/2019	22	6700 Block of Weber Rd.	3.15
9/2/2019	20	3900 Block of Cott St.	3.29
9/2/2019	6	1200 Block of 10th St.	3.03
9/2/2019	27	2800 Block of S Port Ave.	3.42
9/2/2019	89	3800 Block of Castle Ridge Dr.	3.28
9/2/2019	83	4100 Block of Summit Dr.	3.04
9/2/2019	40	9500 Block of Quetzal St.	3.17
9/2/2019	76	1100 Block of Harbor Lights Dr.	3.28
9/2/2019	85	300 Block of Glenmore St.	2.78
9/2/2019	77	5000 Block of Cape Ann Dr.	2.84
9/3/2019	45	15200 Block of Cruiser St.	3.23
9/3/2019	42	700 Block of Orleans Dr.	3.18
9/3/2019	21	900 Block of Lum Ave.	3.18
9/3/2019	32	4900 Block of Hakel Dr.	3.52
9/3/2019	28	1700 Block of Bois d' Arc Pl.	3.46
9/3/2019	9	1000 Block of International Dr.	3.47
9/3/2019	49	100 Block of Commerce St.	3.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/3/2019	91	2700 Block of Wind Rock Dr.	3.61
9/4/2019	83	4100 Block of Summit Dr.	2.86
9/4/2019	40	9500 Block of Quetzal St.	3.00
9/4/2019	76	1100 Block of Harbor Lights Dr.	3.14
9/4/2019	85	300 Block of Glenmore St.	3.06
9/4/2019	77	5000 Block of Cape Ann Dr.	3.07
9/4/2019	98	15800 Block of Almeria Ave.	2.81
9/4/2019	82	2100 Block of Whispering Oak Dr.	3.18
9/4/2019	79	900 Block of Egyptian Dr.	3.16
9/4/2019	7	600 Block of Carmel Pkwy.	3.17
9/4/2019	30	3100 Block of Brawner Pkwy.	2.87
9/4/2019	59	3600 Block of Capri Dr.	3.28
9/4/2019	56	200 Block of Amistad St.	3.18
9/4/2019	90	11700 Block of Haven Dr.	3.40
9/4/2019	97	13900 Block of Skysail St.	3.18
9/4/2019	97	13900 Block of Skysail St.	3.32
9/4/2019	11	500 Block of Military Dr.	2.87
9/4/2019	60	1300 Block of Calle San Marcos	3.17
9/4/2019	31	4300 Block of Cedar St.	2.93
9/4/2019	54	3700 Block of Seagull Blvd.	3.22
9/4/2019	12	2200 Block of Buford Ave.	3.41
9/4/2019	51	200 Block of Gibson Ln.	3.43
9/4/2019	93	11000 Block of Annville Rd.	3.65
9/5/2019	45	15200 Block of Cruiser St.	3.22
9/5/2019	36	1300 Block of Sandstone Dr.	2.76
9/5/2019	71	5500 Block of Fox Run Dr.	2.92
9/5/2019	68	5300 Block of Alejandro St.	2.99

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/5/2019	14	900 Block of Rosedale Dr.	2.81
9/5/2019	50	5500 Block of IH 37 Access Rd.	3.24
9/5/2019	47	8100 Block of Barrogate Dr.	3.13
9/5/2019	90	11700 Block of Haven Dr.	3.12
9/5/2019	58	4800 Block of French Dr.	3.15
9/5/2019	95	15800 Block of El Socorro Loop	2.79
9/5/2019	59	3600 Block of Capri Dr.	3.03
9/5/2019	98	15800 Block of Almeria Ave.	3.19
9/6/2019	95	15800 Block of El Socorro Loop	2.91
9/6/2019	72	7700 Block of Starnberg Lake Dr.	3.02
9/6/2019	2	5800 Block of St. Andrews Dr.	2.92
9/6/2019	33	3900 Block of Ocean Dr.	2.89
9/6/2019	25	4100 Block of Bascule Dr.	2.95
9/6/2019	48	1200 Block of Southern Minerals Rd.	3.11
9/6/2019	44	9600 Block of Wilkins Dr.	2.83
9/7/2019	98	15800 Block of Almeria Ave.	2.76
9/7/2019	38	7500 Block of Annemasse St.	3.03
9/7/2019	25	4100 Block of Bascule Dr.	2.95
9/7/2019	93	11000 Block of Annville Rd.	3.30
9/8/2019	97	13900 Block of Skysail St.	2.91
9/8/2019	8	1100 Block of Cornerstone Dr.	2.89
9/8/2019	26	200 Block of Eastgate Dr.	2.91
9/8/2019	86	14800 Block of Santa Gertrudis Dr.	2.74
9/9/2019	83	4100 Block of Summit Dr.	2.42
9/9/2019	40	9500 Block of Quetzal St.	2.43
9/9/2019	76	1100 Block of Harbor Lights Dr.	2.62
9/9/2019	85	300 Block of Glenmore St.	2.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/9/2019	77	5000 Block of Cape Ann Dr.	2.45
9/9/2019	4	14200 Block of Playa del Rey	2.72
9/9/2019	3	3000 Block of S Fork Dr.	3.04
9/9/2019	23	5500 Block of Wooldridge Rd.	2.69
9/9/2019	29	1600 Block of La Joya St.	3.17
9/9/2019	52	200 Block of Junior Beck Dr.	3.51
9/9/2019	13	1500 Block of 6th St.	3.19
9/9/2019	65	700 Block of Westchester Dr.	3.20
9/9/2019	86	14800 Block of Santa Gertrudis Dr.	3.46
9/10/2019	73	5600 Block of King Trl.	4.06
9/10/2019	61	200 Block of Saratoga Blvd.	3.66
9/10/2019	26	200 Block of Eastgate Dr.	3.57
9/10/2019	87	5200 Block of Northwest Trl.	3.58
9/10/2019	96	14900 Block of Windward Dr.	2.44
9/10/2019	8	1100 Block of Cornerstone Dr.	3.39
9/10/2019	70	1600 Block of E Manor Dr.	2.99
9/10/2019	15	6100 Block of Parkway Dr.	2.94
9/11/2019	18	900 Block of Nueces Bay Blvd.	3.56
9/11/2019	1	4800 Block of Neptune St.	3.41
9/11/2019	62	5800 Block of Hampshire Rd.	3.56
9/11/2019	16	4200 Block of Wildcat Dr.	3.47
9/11/2019	83	4100 Block of Summit Dr.	2.26
9/11/2019	40	9500 Block of Quetzal St.	2.72
9/11/2019	76	1100 Block of Harbor Lights Dr.	2.98
9/11/2019	85	300 Block of Glenmore St.	2.74
9/11/2019	77	5000 Block of Cape Ann Dr.	2.82
9/11/2019	96	14900 Block of Windward Dr.	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/11/2019	38	7500 Block of Annemasse St.	3.40
9/11/2019	80	7000 Block of Arapahoe St.	3.34
9/11/2019	35	4700 Block of Congressional Dr.	3.12
9/11/2019	58	4800 Block of French Dr.	3.30
9/11/2019	19	1300 Block of Horne Rd.	3.33
9/11/2019	92	300 Block of Wildwood Dr.	3.71
9/11/2019	94	15200 Block of Caravel Dr.	2.94
9/11/2019	24	2300 Block of Rodd Field Rd.	3.52
9/11/2019	39	5900 Block of Long Creek Dr.	2.98
9/11/2019	55	500 Block of Belden St.	3.34
9/12/2019	97	13900 Block of Skysail St.	3.21
9/12/2019	43	200 Block of Caribbean Dr.	2.94
9/12/2019	37	6500 Block of Brockhampton St.	3.33
9/12/2019	34	4300 Block of Harry St.	3.05
9/12/2019	10	3100 Block of Saratoga Blvd.	3.01
9/12/2019	57	1400 Block of Arlington Dr.	3.02
9/12/2019	46	8900 Block of McNorton Rd.	3.58
9/12/2019	98	15800 Block of Almeria Ave.	2.65
9/12/2019	74	7900 Block of Impala Dr.	3.29
9/12/2019	78	7600 Block of Timber Crest Dr.	3.44
9/12/2019	69	4000 Block of Donaho Dr.	3.12
9/12/2019	66	600 Block of Southern St.	3.33
9/12/2019	64	4000 Block of Hidalgo St.	3.58
9/12/2019	91	2700 Block of Wind Rock Dr.	3.62
9/13/2019	94	15200 Block of Caravel Dr.	3.05
9/13/2019	41	1600 Block of Amber Dr.	2.98
9/13/2019	75	2900 Block of Oso Pkwy.	3.17

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/13/2019	81	6600 Block of Meadowheights Dr.	3.06
9/13/2019	5	4600 Block of Evelyn St.	3.01
9/13/2019	67	500 Block of S Carancahua St.	3.08
9/13/2019	53	9100 Block of Stock Dr.	2.95
9/13/2019	88	4200 Block of Western Dr.	3.83
9/14/2019	98	15800 Block of Almeria Ave.	2.51
9/14/2019	38	7500 Block of Annemasse St.	2.93
9/14/2019	25	4100 Block of Bascule Dr.	3.28
9/14/2019	93	11000 Block of Annville Rd.	3.73
9/15/2019	97	13900 Block of Skysail St.	2.99
9/15/2019	8	1100 Block of Cornerstone Dr.	2.92
9/15/2019	26	200 Block of Eastgate Dr.	3.31
9/15/2019	86	14800 Block of Santa Gertrudis Dr.	2.72
9/16/2019	83	4100 Block of Summit Dr.	2.55
9/16/2019	40	9500 Block of Quetzal St.	2.68
9/16/2019	76	1100 Block of Harbor Lights Dr.	2.80
9/16/2019	85	300 Block of Glenmore St.	2.59
9/16/2019	77	5000 Block of Cape Ann Dr.	2.68
9/16/2019	4	14200 Block of Playa del Rey	2.81
9/16/2019	84	3600 Block of Flour Bluff Dr.	3.02
9/16/2019	99	3900 Block of Elvis Dr.	3.29
9/16/2019	22	6700 Block of Weber Rd.	3.45
9/16/2019	20	3900 Block of Cott St.	3.32
9/16/2019	6	1200 Block of 10th St.	3.06
9/16/2019	27	2800 Block of S Port Ave.	3.59
9/16/2019	89	3800 Block of Castle Ridge Dr.	3.42
9/16/2019	45	15200 Block of Cruiser St.	2.86

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/16/2019	42	700 Block of Orleans Dr.	2.99
9/16/2019	21	900 Block of Lum Ave.	3.07
9/16/2019	32	4900 Block of Haket Dr.	3.49
9/16/2019	28	1700 Block of Bois d' Arc Pl.	3.66
9/16/2019	9	1000 Block of International Dr.	3.55
9/16/2019	49	100 Block of Commerce St.	3.58
9/16/2019	91	2700 Block of Wind Rock Dr.	3.73
9/17/2019	4	14200 Block of Playa del Rey	2.84
9/17/2019	3	3000 Block of S Fork Dr.	3.65
9/17/2019	23	5500 Block of Wooldridge Rd.	3.09
9/17/2019	29	1600 Block of La Joya St.	3.52
9/17/2019	52	200 Block of Junior Beck Dr.	3.60
9/17/2019	13	1500 Block of 6th St.	3.30
9/17/2019	65	700 Block of Westchester Dr.	3.58
9/17/2019	86	14800 Block of Santa Gertrudis Dr.	3.27
9/18/2019	94	15200 Block of Caravel Dr.	2.85
9/18/2019	24	2300 Block of Rodd Field Rd.	3.21
9/18/2019	39	5900 Block of Long Creek Dr.	3.29
9/18/2019	55	500 Block of Belden St.	3.36
9/18/2019	18	900 Block of Nueces Bay Blvd.	3.60
9/18/2019	1	4800 Block of Neptune St.	3.40
9/18/2019	62	5800 Block of Hampshire Rd.	3.57
9/18/2019	16	4200 Block of Wildcat Dr.	3.63
9/18/2019	96	14900 Block of Windward Dr.	3.00
9/18/2019	8	1100 Block of Cornerstone Dr.	3.56
9/18/2019	70	1600 Block of E Manor Dr.	3.27
9/18/2019	15	6100 Block of Parkway Dr.	2.98

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/18/2019	73	5600 Block of King Trl.	3.82
9/18/2019	61	200 Block of Saratoga Blvd.	3.61
9/18/2019	26	200 Block of Eastgate Dr.	3.37
9/18/2019	87	5200 Block of Northwest Trl.	3.56
9/18/2019	83	4100 Block of Summit Dr.	2.52
9/18/2019	40	9500 Block of Quetzal St.	2.96
9/18/2019	76	1100 Block of Harbor Lights Dr.	3.05
9/18/2019	85	300 Block of Glenmore St.	2.82
9/18/2019	77	5000 Block of Cape Ann Dr.	2.90
9/19/2019	97	13900 Block of Skysail St.	3.48
9/19/2019	11	500 Block of Military Dr.	2.91
9/19/2019	51	200 Block of Gibson Ln.	3.58
9/19/2019	93	11000 Block of Annville Rd.	3.94
9/19/2019	45	15200 Block of Cruiser St.	3.43
9/19/2019	36	1300 Block of Sandstone Dr.	2.97
9/19/2019	71	5500 Block of Fox Run Dr.	3.02
9/19/2019	68	5300 Block of Alejandro St.	3.19
9/19/2019	98	15800 Block of Almeria Ave.	3.00
9/19/2019	74	7900 Block of Impala Dr.	3.07
9/19/2019	78	7600 Block of Timber Crest Dr.	3.46
9/19/2019	69	4000 Block of Donaho Dr.	3.00
9/19/2019	66	600 Block of Southern St.	3.27
9/19/2019	64	4000 Block of Hidalgo St.	3.32
9/19/2019	91	2700 Block of Wind Rock Dr.	3.40
9/19/2019	57	1400 Block of Arlington Dr.	2.98
9/20/2019	98	15800 Block of Almeria Ave.	2.82
9/20/2019	82	2100 Block of Whispering Oak Dr.	3.12

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/20/2019	79	900 Block of Egyptian Dr.	3.04
9/20/2019	7	600 Block of Carmel Pkwy.	3.04
9/20/2019	59	3600 Block of Capri Dr.	3.13
9/20/2019	30	3100 Block of Brawner Pkwy.	3.18
9/20/2019	56	200 Block of Amistad St.	3.19
9/20/2019	90	11700 Block of Haven Dr.	3.44
9/21/2019	98	15800 Block of Almeria Ave.	2.70
9/21/2019	38	7500 Block of Annemasse St.	3.15
9/21/2019	25	4100 Block of Bascule Dr.	3.56
9/21/2019	93	11000 Block of Annville Rd.	3.96
9/22/2019	97	13900 Block of Skysail St.	2.93
9/22/2019	8	1100 Block of Cornerstone Dr.	3.27
9/22/2019	26	200 Block of Eastgate Dr.	3.65
9/22/2019	86	14800 Block of Santa Gertrudis Dr.	2.79
9/23/2019	83	4100 Block of Summit Dr.	2.48
9/23/2019	40	9500 Block of Quetzal St.	2.88
9/23/2019	76	1100 Block of Harbor Lights Dr.	2.97
9/23/2019	85	300 Block of Glenmore St.	2.92
9/23/2019	77	5000 Block of Cape Ann Dr.	3.02
9/23/2019	96	14900 Block of Windward Dr.	2.62
9/23/2019	38	7500 Block of Annemasse St.	3.16
9/23/2019	80	7000 Block of Arapahoe St.	3.33
9/23/2019	35	4700 Block of Congressional Dr.	3.08
9/23/2019	58	4800 Block of French Dr.	3.44
9/23/2019	19	1300 Block of Horne Rd.	3.52
9/23/2019	92	300 Block of Wildwood Dr.	4.05
9/24/2019	97	13900 Block of Skysail St.	3.34

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/24/2019	43	200 Block of Caribbean Dr.	3.09
9/24/2019	37	6500 Block of Brockhampton St.	3.49
9/24/2019	34	4300 Block of Harry St.	3.39
9/24/2019	10	3100 Block of Saratoga Blvd.	3.17
9/24/2019	57	1400 Block of Arlington Dr.	3.31
9/24/2019	46	8900 Block of McNorton Rd.	3.81
9/25/2019	83	4100 Block of Summit Dr.	2.66
9/25/2019	40	9500 Block of Quetzal St.	3.04
9/25/2019	76	1100 Block of Harbor Lights Dr.	2.98
9/25/2019	85	300 Block of Glenmore St.	2.97
9/25/2019	77	5000 Block of Cape Ann Dr.	3.02
9/25/2019	97	13900 Block of Skysail St.	3.33
9/25/2019	11	500 Block of Military Dr.	2.74
9/25/2019	60	1300 Block of Calle San Marcos	3.03
9/25/2019	31	4300 Block of Cedar St.	3.04
9/25/2019	54	3700 Block of Seagull Blvd.	3.17
9/25/2019	12	2200 Block of Buford Ave.	3.29
9/25/2019	51	200 Block of Gibson Ln.	3.35
9/25/2019	93	11000 Block of Annville Rd.	3.96
9/25/2019	94	15200 Block of Caravel Dr.	3.18
9/25/2019	41	1600 Block of Amber Dr.	3.12
9/25/2019	75	2900 Block of Oso Pkwy.	3.06
9/25/2019	81	6600 Block of Meadowheights Dr.	3.15
9/25/2019	5	4600 Block of Evelyn St.	3.01
9/25/2019	67	500 Block of S Carancahua St.	3.16
9/25/2019	53	9100 Block of Stock Dr.	2.90
9/25/2019	88	4200 Block of Western Dr.	3.88

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/25/2019	10	3100 Block of Saratoga Blvd.	3.10
9/25/2019	10	3100 Block of Saratoga Blvd.	3.09
9/25/2019	10	3100 Block of Saratoga Blvd.	3.12
9/26/2019	45	15200 Block of Cruiser St.	3.37
9/26/2019	36	1300 Block of Sandstone Dr.	2.82
9/26/2019	71	5500 Block of Fox Run Dr.	2.93
9/26/2019	68	5300 Block of Alejandro St.	3.22
9/26/2019	50	5500 Block of IH 37 Access Rd.	3.89
9/26/2019	47	8100 Block of Barrogate Dr.	3.84
9/26/2019	90	11700 Block of Haven Dr.	3.51
9/27/2019	95	15800 Block of El Socorro Loop	2.79
9/27/2019	72	7700 Block of Starnberg Lake Dr.	3.32
9/27/2019	2	5800 Block of St. Andrews Dr.	3.09
9/27/2019	33	3900 Block of Ocean Dr.	3.05
9/27/2019	25	4100 Block of Bascule Dr.	3.15
9/27/2019	48	1200 Block of Southern Minerals Rd.	3.57
9/27/2019	44	9600 Block of Wilkins Dr.	3.33
9/27/2019	82	2100 Block of Whispering Oak Dr.	2.89
9/27/2019	59	3600 Block of Capri Dr.	2.91
9/27/2019	30	3100 Block of Brawner Pkwy.	3.02
9/27/2019	19	1300 Block of Horne Rd.	3.34
9/27/2019	92	300 Block of Wildwood Dr.	3.86
9/27/2019	34	4300 Block of Harry St.	2.96
9/27/2019	14	900 Block of Rosedale Dr.	3.08
9/28/2019	34	4300 Block of Harry St.	2.84
9/28/2019	34	4300 Block of Harry St.	2.84
9/28/2019	34	4300 Block of Harry St.	2.90

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/28/2019	98	15800 Block of Almeria Ave.	2.68
9/28/2019	38	7500 Block of Annemasse St.	3.18
9/28/2019	25	4100 Block of Bascule Dr.	3.41
9/28/2019	93	11000 Block of Annaville Rd.	3.89
9/29/2019	97	13900 Block of Skysail St.	3.28
9/29/2019	8	1100 Block of Cornerstone Dr.	3.16
9/29/2019	26	200 Block of Eastgate Dr.	3.38
9/29/2019	86	14800 Block of Santa Gertrudis Dr.	3.19
9/30/2019	96	14900 Block of Windward Dr.	3.23
9/30/2019	43	200 Block of Caribbean Dr.	3.01
9/30/2019	53	9100 Block of Stock Dr.	3.16
9/30/2019	46	8900 Block of McNorton Rd.	3.41
9/30/2019	83	4100 Block of Summit Dr.	2.61
9/30/2019	40	9500 Block of Quetzal St.	2.75
9/30/2019	76	1100 Block of Harbor Lights Dr.	2.87
9/30/2019	85	300 Block of Glenmore St.	2.65
9/30/2019	77	5000 Block of Cape Ann Dr.	2.91

October

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/1/2019	4	14200 Block of Playa del Rey	3.19
10/1/2019	3	3000 Block of S Fork Dr.	3.21
10/1/2019	23	5500 Block of Wooldridge Rd.	3.02
10/1/2019	29	1600 Block of La Joya St.	3.08
10/1/2019	52	200 Block of Junior Beck Dr.	3.23
10/1/2019	13	1500 Block of 6th St.	3.22

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/1/2019	65	700 Block of Westchester Dr.	3.31
10/1/2019	86	14800 Block of Santa Gertrudis Dr.	2.98
10/2/2019	83	4100 Block of Summit Dr.	2.49
10/2/2019	40	9500 Block of Quetzal St.	2.71
10/2/2019	76	1100 Block of Harbor Lights Dr.	2.65
10/2/2019	85	300 Block of Glenmore St.	2.68
10/2/2019	77	5000 Block of Cape Ann Dr.	2.70
10/2/2019	96	14900 Block of Windward Dr.	3.13
10/2/2019	8	1100 Block of Cornerstone Dr.	2.66
10/2/2019	70	1600 Block of E Manor Dr.	2.93
10/2/2019	15	6100 Block of Parkway Dr.	2.86
10/2/2019	73	5600 Block of King Trl.	2.76
10/2/2019	61	200 Block of Saratoga Blvd.	3.14
10/2/2019	26	200 Block of Eastgate Dr.	2.93
10/2/2019	87	5200 Block of Northwest Trl.	2.93
10/2/2019	94	15200 Block of Caravel Dr.	2.93
10/2/2019	24	2300 Block of Rodd Field Rd.	2.91
10/2/2019	39	5900 Block of Long Creek Dr.	2.55
10/2/2019	55	500 Block of Belden St.	2.63
10/2/2019	18	900 Block of Nueces Bay Blvd.	3.14
10/2/2019	1	4800 Block of Neptune St.	3.33
10/2/2019	62	5800 Block of Hampshire Rd.	3.17
10/2/2019	16	4200 Block of Wildcat Dr.	3.38
10/3/2019	96	14900 Block of Windward Dr.	2.99
10/3/2019	38	7500 Block of Annemasse St.	2.95
10/3/2019	80	7000 Block of Arapahoe St.	3.36
10/3/2019	35	4700 Block of Congressional Dr.	2.80

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/3/2019	58	4800 Block of French Dr.	3.03
10/3/2019	19	1300 Block of Horne Rd.	3.40
10/3/2019	92	300 Block of Wildwood Dr.	3.82
10/3/2019	98	15800 Block of Almeria Ave.	2.77
10/3/2019	74	7900 Block of Impala Dr.	2.90
10/3/2019	78	7600 Block of Timber Crest Dr.	2.84
10/3/2019	69	4000 Block of Donaho Dr.	2.79
10/3/2019	66	600 Block of Southern St.	3.35
10/3/2019	64	4000 Block of Hidalgo St.	3.08
10/3/2019	91	2700 Block of Wind Rock Dr.	3.39
10/4/2019	97	13900 Block of Skysail St.	3.20
10/4/2019	43	200 Block of Caribbean Dr.	2.82
10/4/2019	37	6500 Block of Brockhampton St.	3.00
10/4/2019	34	4300 Block of Harry St.	3.07
10/4/2019	10	3100 Block of Saratoga Blvd.	2.92
10/4/2019	57	1400 Block of Arlington Dr.	2.91
10/4/2019	46	8900 Block of McNorton Rd.	3.36
10/5/2019	98	15800 Block of Almeria Ave.	3.18
10/5/2019	38	7500 Block of Annemasse St.	2.84
10/5/2019	25	4100 Block of Bascule Dr.	3.19
10/5/2019	93	11000 Block of Annville Rd.	3.69
10/6/2019	97	13900 Block of Skysail St.	3.39
10/6/2019	8	1100 Block of Cornerstone Dr.	2.92
10/6/2019	26	200 Block of Eastgate Dr.	3.14
10/6/2019	86	14800 Block of Santa Gertrudis Dr.	2.99
10/7/2019	83	4100 Block of Summit Dr.	2.37
10/7/2019	40	9500 Block of Quetzal St.	2.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/7/2019	76	1100 Block of Harbor Lights Dr.	2.46
10/7/2019	85	300 Block of Glenmore St.	2.43
10/7/2019	77	5000 Block of Cape Ann Dr.	2.50
10/7/2019	94	15200 Block of Caravel Dr.	3.07
10/7/2019	41	1600 Block of Amber Dr.	2.78
10/7/2019	75	2900 Block of Oso Pkwy.	2.79
10/7/2019	81	6600 Block of Meadowheights Dr.	2.90
10/7/2019	5	4600 Block of Evelyn St.	2.84
10/7/2019	67	500 Block of S Carancahua St.	3.23
10/7/2019	53	9100 Block of Stock Dr.	2.97
10/7/2019	88	4200 Block of Western Dr.	3.93
10/8/2019	4	14200 Block of Playa del Rey	3.10
10/8/2019	84	3600 Block of Flour Bluff Dr.	2.79
10/8/2019	99	3900 Block of Elvis Dr.	3.05
10/8/2019	22	6700 Block of Weber Rd.	3.35
10/8/2019	20	3900 Block of Cott St.	3.25
10/8/2019	6	1200 Block of 10th St.	2.92
10/8/2019	27	2800 Block of S Port Ave.	3.26
10/8/2019	89	3800 Block of Castle Ridge Dr.	3.32
10/9/2019	97	13900 Block of Skysail St.	3.09
10/9/2019	11	500 Block of Military Dr.	2.57
10/9/2019	60	1300 Block of Calle San Marcos	2.98
10/9/2019	31	4300 Block of Cedar St.	2.87
10/9/2019	54	3700 Block of Seagull Blvd.	2.99
10/9/2019	12	2200 Block of Buford Ave.	3.37
10/9/2019	51	200 Block of Gibson Ln.	3.42
10/9/2019	93	11000 Block of Annaville Rd.	3.89

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/9/2019	83	4100 Block of Summit Dr.	2.40
10/9/2019	40	9500 Block of Quetzal St.	2.79
10/9/2019	76	1100 Block of Harbor Lights Dr.	2.79
10/9/2019	85	300 Block of Glenmore St.	2.77
10/9/2019	77	5000 Block of Cape Ann Dr.	2.76
10/9/2019	45	15200 Block of Cruiser St.	3.43
10/9/2019	42	700 Block of Orleans Dr.	2.86
10/9/2019	21	900 Block of Lum Ave.	2.98
10/9/2019	32	4900 Block of Hakel Dr.	3.36
10/9/2019	28	1700 Block of Bois d' Arc Pl.	3.26
10/9/2019	9	1000 Block of International Dr.	3.28
10/9/2019	49	100 Block of Commerce St.	3.29
10/9/2019	91	2700 Block of Wind Rock Dr.	3.15
10/9/2019	75	2900 Block of Oso Pkwy.	2.90
10/10/2019	59	3600 Block of Capri Dr.	3.18
10/10/2019	30	3100 Block of Brawner Pkwy.	3.00
10/10/2019	56	200 Block of Amistad St.	3.17
10/10/2019	90	11700 Block of Haven Dr.	3.51
10/10/2019	98	15800 Block of Almeria Ave.	3.28
10/10/2019	82	2100 Block of Whispering Oak Dr.	2.96
10/10/2019	79	900 Block of Egyptian Dr.	2.93
10/10/2019	7	600 Block of Carmel Pkwy.	3.07
10/11/2019	45	15200 Block of Cruiser St.	3.48
10/11/2019	36	1300 Block of Sandstone Dr.	2.80
10/11/2019	71	5500 Block of Fox Run Dr.	3.00
10/11/2019	68	5300 Block of Alejandro St.	3.07
10/11/2019	14	900 Block of Rosedale Dr.	3.33

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/11/2019	50	5500 Block of IH 37 Access Rd.	3.55
10/11/2019	47	8100 Block of Barrogate Dr.	3.58
10/11/2019	90	11700 Block of Haven Dr.	3.40
10/12/2019	98	15800 Block of Almeria Ave.	2.73
10/12/2019	38	7500 Block of Annemasse St.	2.86
10/12/2019	25	4100 Block of Bascule Dr.	3.06
10/12/2019	93	11000 Block of Annaville Rd.	3.72
10/12/2019	50	5500 Block of IH 37 Access Rd.	3.52
10/12/2019	50	5500 Block of IH 37 Access Rd.	3.36
10/12/2019	50	5500 Block of IH 37 Access Rd.	3.26
10/13/2019	86	14800 Block of Santa Gertrudis Dr.	3.39
10/13/2019	26	200 Block of Eastgate Dr.	3.38
10/13/2019	8	1100 Block of Cornerstone Dr.	2.89
10/13/2019	97	13900 Block of Skysail St.	3.14
10/14/2019	83	4100 Block of Summit Dr.	2.42
10/14/2019	40	9500 Block of Quetzal St.	2.73
10/14/2019	76	1100 Block of Harbor Lights Dr.	2.92
10/14/2019	85	300 Block of Glenmore St.	2.64
10/14/2019	77	5000 Block of Cape Ann Dr.	2.84
10/14/2019	95	15800 Block of El Socorro Loop	2.47
10/14/2019	72	7700 Block of Starnberg Lake Dr.	3.15
10/14/2019	2	5800 Block of St. Andrews Dr.	2.92
10/14/2019	33	3900 Block of Ocean Dr.	3.00
10/14/2019	25	4100 Block of Bascule Dr.	3.33
10/14/2019	48	1200 Block of Southern Minerals Rd.	3.81
10/14/2019	44	9600 Block of Wilkins Dr.	3.79
10/14/2019	81	6600 Block of Meadowheights Dr.	3.19

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/15/2019	4	14200 Block of Playa del Rey	3.31
10/15/2019	3	3000 Block of S Fork Dr.	3.54
10/15/2019	23	5500 Block of Wooldridge Rd.	3.18
10/15/2019	29	1600 Block of La Joya St.	3.40
10/15/2019	52	200 Block of Junior Beck Dr.	3.45
10/15/2019	13	1500 Block of 6th St.	3.40
10/15/2019	65	700 Block of Westchester Dr.	3.50
10/15/2019	86	14800 Block of Santa Gertrudis Dr.	3.11
10/16/2019	83	4100 Block of Summit Dr.	2.45
10/16/2019	40	9500 Block of Quetzal St.	2.85
10/16/2019	76	1100 Block of Harbor Lights Dr.	2.95
10/16/2019	85	300 Block of Glenmore St.	2.73
10/16/2019	77	5000 Block of Cape Ann Dr.	2.87
10/16/2019	94	15200 Block of Caravel Dr.	3.11
10/16/2019	24	2300 Block of Rodd Field Rd.	3.29
10/16/2019	39	5900 Block of Long Creek Dr.	2.96
10/16/2019	55	500 Block of Belden St.	3.10
10/16/2019	18	900 Block of Nueces Bay Blvd.	3.09
10/16/2019	1	4800 Block of Neptune St.	3.37
10/16/2019	62	5800 Block of Hampshire Rd.	3.21
10/16/2019	16	4200 Block of Wildcat Dr.	3.68
10/16/2019	96	14900 Block of Windward Dr.	3.22
10/16/2019	8	1100 Block of Cornerstone Dr.	3.13
10/16/2019	70	1600 Block of E Manor Dr.	3.07
10/16/2019	15	6100 Block of Parkway Dr.	3.04
10/16/2019	73	5600 Block of King Trl.	3.22
10/16/2019	61	200 Block of Saratoga Blvd.	3.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/16/2019	26	200 Block of Eastgate Dr.	3.07
10/16/2019	87	5200 Block of Northwest Trl.	3.52
10/16/2019	43	200 Block of Caribbean Dr.	2.96
10/17/2019	98	15800 Block of Almeria Ave.	2.57
10/17/2019	74	7900 Block of Impala Dr.	3.00
10/17/2019	78	7600 Block of Timber Crest Dr.	2.93
10/17/2019	69	4000 Block of Donaho Dr.	3.35
10/17/2019	66	600 Block of Southern St.	3.35
10/17/2019	64	4000 Block of Hidalgo St.	3.43
10/17/2019	91	2700 Block of Wind Rock Dr.	3.27
10/18/2019	96	14900 Block of Windward Dr.	2.61
10/18/2019	38	7500 Block of Annemasse St.	3.11
10/18/2019	80	7000 Block of Arapahoe St.	3.33
10/18/2019	35	4700 Block of Congressional Dr.	3.18
10/18/2019	58	4800 Block of French Dr.	2.90
10/18/2019	19	1300 Block of Horne Rd.	3.38
10/18/2019	92	300 Block of Wildwood Dr.	4.05
10/19/2019	98	15800 Block of Almeria Ave.	2.57
10/19/2019	38	7500 Block of Annemasse St.	3.06
10/19/2019	25	4100 Block of Bascule Dr.	3.33
10/19/2019	93	11000 Block of Annville Rd.	3.88
10/20/2019	97	13900 Block of Skysail St.	3.16
10/20/2019	8	1100 Block of Cornerstone Dr.	3.02
10/20/2019	26	200 Block of Eastgate Dr.	3.24
10/20/2019	86	14800 Block of Santa Gertrudis Dr.	2.92
10/21/2019	97	13900 Block of Skysail St.	3.17
10/21/2019	11	500 Block of Military Dr.	2.33

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/21/2019	60	1300 Block of Calle San Marcos	2.68
10/21/2019	31	4300 Block of Cedar St.	2.83
10/21/2019	54	3700 Block of Seagull Blvd.	2.81
10/21/2019	12	2200 Block of Buford Ave.	3.46
10/21/2019	51	200 Block of Gibson Ln.	3.37
10/21/2019	93	11000 Block of Annville Rd.	3.77
10/21/2019	83	4100 Block of Summit Dr.	2.37
10/21/2019	40	9500 Block of Quetzal St.	2.88
10/21/2019	76	1100 Block of Harbor Lights Dr.	2.71
10/21/2019	85	300 Block of Glenmore St.	2.62
10/21/2019	77	5000 Block of Cape Ann Dr.	2.69
10/22/2019	45	15200 Block of Cruiser St.	3.11
10/22/2019	36	1300 Block of Sandstone Dr.	2.74
10/22/2019	71	5500 Block of Fox Run Dr.	2.78
10/22/2019	68	5300 Block of Alejandro St.	2.96
10/22/2019	14	900 Block of Rosedale Dr.	3.04
10/22/2019	50	5500 Block of IH 37 Access Rd.	3.43
10/22/2019	47	8100 Block of Barrogate Dr.	3.60
10/22/2019	90	11700 Block of Haven Dr.	3.28
10/23/2019	83	4100 Block of Summit Dr.	2.10
10/23/2019	40	9500 Block of Quetzal St.	2.54
10/23/2019	76	1100 Block of Harbor Lights Dr.	2.62
10/23/2019	85	300 Block of Glenmore St.	2.52
10/23/2019	77	5000 Block of Cape Ann Dr.	2.58
10/23/2019	58	4800 Block of French Dr.	2.98
10/23/2019	95	15800 Block of El Socorro Loop	2.40
10/23/2019	59	3600 Block of Capri Dr.	2.74

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/23/2019	98	15800 Block of Almeria Ave.	2.80
10/23/2019	95	15800 Block of El Socorro Loop	2.38
10/23/2019	72	7700 Block of Starnberg Lake Dr.	2.81
10/23/2019	2	5800 Block of St. Andrews Dr.	2.85
10/23/2019	33	3900 Block of Ocean Dr.	2.91
10/23/2019	25	4100 Block of Bascule Dr.	3.08
10/23/2019	48	1200 Block of Southern Minerals Rd.	3.67
10/23/2019	44	9600 Block of Wilkins Dr.	3.33
10/24/2019	97	13900 Block of Skysail St.	2.64
10/24/2019	43	200 Block of Caribbean Dr.	2.80
10/24/2019	37	6500 Block of Brockhampton St.	2.91
10/24/2019	34	4300 Block of Harry St.	3.03
10/24/2019	10	3100 Block of Saratoga Blvd.	3.01
10/24/2019	57	1400 Block of Arlington Dr.	2.98
10/24/2019	46	8900 Block of McNorton Rd.	3.64
10/24/2019	44	9600 Block of Wilkins Dr.	3.66
10/25/2019	94	15200 Block of Caravel Dr.	2.60
10/25/2019	41	1600 Block of Amber Dr.	2.66
10/25/2019	75	2900 Block of Oso Pkwy.	2.70
10/25/2019	81	6600 Block of Meadowheights Dr.	3.19
10/25/2019	5	4600 Block of Evelyn St.	2.90
10/25/2019	67	500 Block of S Carancahua St.	3.04
10/25/2019	53	9100 Block of Stock Dr.	2.73
10/25/2019	88	4200 Block of Western Dr.	3.92
10/26/2019	98	15800 Block of Almeria Ave.	2.72
10/26/2019	38	7500 Block of Annemasse St.	2.87
10/26/2019	25	4100 Block of Bascule Dr.	3.29

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/26/2019	93	11000 Block of Annville Rd.	4.18
10/27/2019	97	13900 Block of Skysail St.	3.14
10/27/2019	8	1100 Block of Cornerstone Dr.	3.00
10/27/2019	26	200 Block of Eastgate Dr.	3.46
10/27/2019	86	14800 Block of Santa Gertrudis Dr.	3.11
10/28/2019	83	4100 Block of Summit Dr.	2.37
10/28/2019	40	9500 Block of Quetzal St.	2.90
10/28/2019	76	1100 Block of Harbor Lights Dr.	2.99
10/28/2019	85	300 Block of Glenmore St.	2.83
10/28/2019	77	5000 Block of Cape Ann Dr.	2.99
10/28/2019	4	14200 Block of Playa del Rey	3.35
10/28/2019	84	3600 Block of Flour Bluff Dr.	3.24
10/28/2019	99	3900 Block of Elvis Dr.	3.43
10/28/2019	22	6700 Block of Weber Rd.	3.53
10/28/2019	20	3900 Block of Cott St.	3.48
10/28/2019	6	1200 Block of 10th St.	3.26
10/28/2019	27	2800 Block of S Port Ave.	3.56
10/28/2019	89	3800 Block of Castle Ridge Dr.	3.46
10/29/2019	45	15200 Block of Cruiser St.	3.49
10/29/2019	42	700 Block of Orleans Dr.	3.04
10/29/2019	21	900 Block of Lum Ave.	3.15
10/29/2019	32	4900 Block of Hakei Dr.	3.35
10/29/2019	28	1700 Block of Bois d' Arc Pl.	3.40
10/29/2019	9	1000 Block of International Dr.	3.08
10/29/2019	49	100 Block of Commerce St.	3.39
10/29/2019	91	2700 Block of Wind Rock Dr.	3.30
10/30/2019	83	4100 Block of Summit Dr.	2.46

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/30/2019	40	9500 Block of Quetzal St.	2.92
10/30/2019	76	1100 Block of Harbor Lights Dr.	2.88
10/30/2019	85	300 Block of Glenmore St.	2.78
10/30/2019	77	5000 Block of Cape Ann Dr.	2.79
10/30/2019	98	15800 Block of Almeria Ave.	2.65
10/30/2019	82	2100 Block of Whispering Oak Dr.	2.86
10/30/2019	79	900 Block of Egyptian Dr.	2.88
10/30/2019	7	600 Block of Carmel Pkwy.	2.82
10/30/2019	59	3600 Block of Capri Dr.	3.22
10/30/2019	30	3100 Block of Brawner Pkwy.	2.84
10/30/2019	56	200 Block of Amistad St.	3.03
10/30/2019	90	11700 Block of Haven Dr.	3.50
10/31/2019	4	14200 Block of Playa del Rey	3.04
10/31/2019	58	4800 Block of French Dr.	3.20
10/31/2019	29	1600 Block of La Joya St.	3.28
10/31/2019	88	4200 Block of Western Dr.	3.84

November

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/1/2019	98	15800 Block of Almeria Ave.	2.93
11/1/2019	74	7900 Block of Impala Dr.	2.91
11/1/2019	78	7600 Block of Timber Crest Dr.	3.18
11/1/2019	69	4000 Block of Donaho Dr.	2.85
11/1/2019	66	600 Block of Southern St.	3.03
11/1/2019	64	4000 Block of Hidalgo St.	3.09
11/1/2019	91	2700 Block of Wind Rock Dr.	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/2/2019	98	15800 Block of Almeria Ave.	2.60
11/2/2019	38	7500 Block of Annemasse St.	3.02
11/2/2019	25	4100 Block of Bascule Dr.	3.21
11/2/2019	93	11000 Block of Annaville Rd.	3.96
11/3/2019	97	13900 Block of Skysail St.	3.28
11/3/2019	8	1100 Block of Cornerstone Dr.	2.86
11/3/2019	26	200 Block of Eastgate Dr.	3.08
11/3/2019	86	14800 Block of Santa Gertrudis Dr.	2.84
11/4/2019	83	4100 Block of Summit Dr.	2.32
11/4/2019	40	9500 Block of Quetzal St.	2.61
11/4/2019	76	1100 Block of Harbor Lights Dr.	2.63
11/4/2019	85	300 Block of Glenmore St.	2.65
11/4/2019	77	5000 Block of Cape Ann Dr.	2.79
11/4/2019	96	14900 Block of Windward Dr.	2.73
11/4/2019	38	7500 Block of Annemasse St.	2.78
11/4/2019	35	4700 Block of Congressional Dr.	3.26
11/4/2019	58	4800 Block of French Dr.	3.16
11/4/2019	19	1300 Block of Horne Rd.	3.40
11/4/2019	92	300 Block of Wildwood Dr.	4.08
11/5/2019	97	13900 Block of Skysail St.	2.93
11/5/2019	43	200 Block of Caribbean Dr.	2.69
11/5/2019	37	6500 Block of Brockhampton St.	3.03
11/5/2019	34	4300 Block of Harry St.	3.25
11/5/2019	10	3100 Block of Saratoga Blvd.	3.14
11/5/2019	57	1400 Block of Arlington Dr.	2.94
11/5/2019	46	8900 Block of McNorton Rd.	3.77
11/6/2019	83	4100 Block of Summit Dr.	2.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/6/2019	40	9500 Block of Quetzal St.	3.02
11/6/2019	76	1100 Block of Harbor Lights Dr.	2.90
11/6/2019	85	300 Block of Glenmore St.	2.84
11/6/2019	77	5000 Block of Cape Ann Dr.	2.76
11/6/2019	58	4800 Block of French Dr.	3.10
11/6/2019	95	15800 Block of El Socorro Loop	2.38
11/6/2019	59	3600 Block of Capri Dr.	3.10
11/6/2019	98	15800 Block of Almeria Ave.	2.74
11/6/2019	94	15200 Block of Caravel Dr.	2.77
11/6/2019	41	1600 Block of Amber Dr.	2.98
11/6/2019	75	2900 Block of Oso Pkwy.	2.97
11/6/2019	81	6600 Block of Meadowheights Dr.	3.12
11/6/2019	5	4600 Block of Evelyn St.	2.92
11/6/2019	67	500 Block of S Carancahua St.	3.12
11/6/2019	53	9100 Block of Stock Dr.	3.08
11/6/2019	88	4200 Block of Western Dr.	3.96
11/6/2019	4	14200 Block of Playa del Rey	2.75
11/6/2019	84	3600 Block of Flour Bluff Dr.	2.93
11/6/2019	99	3900 Block of Elvis Dr.	3.26
11/6/2019	22	6700 Block of Weber Rd.	3.23
11/6/2019	20	3900 Block of Cott St.	3.03
11/6/2019	6	1200 Block of 10th St.	2.96
11/6/2019	27	2800 Block of S Port Ave.	3.21
11/6/2019	89	3800 Block of Castle Ridge Dr.	3.13
11/7/2019	45	15200 Block of Cruiser St.	3.34
11/7/2019	42	700 Block of Orleans Dr.	3.02
11/7/2019	21	900 Block of Lum Ave.	2.90

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/7/2019	32	4900 Block of Haket Dr.	3.56
11/7/2019	28	1700 Block of Bois d' Arc Pl.	3.46
11/7/2019	9	1000 Block of International Dr.	3.18
11/7/2019	49	100 Block of Commerce St.	3.48
11/7/2019	91	2700 Block of Wind Rock Dr.	3.54
11/7/2019	98	15800 Block of Almeria Ave.	2.88
11/7/2019	82	2100 Block of Whispering Oak Dr.	3.01
11/7/2019	79	900 Block of Egyptian Dr.	2.95
11/7/2019	7	600 Block of Carmel Pkwy.	3.07
11/7/2019	59	3600 Block of Capri Dr.	3.14
11/7/2019	30	3100 Block of Brawner Pkwy.	3.09
11/7/2019	56	200 Block of Amistad St.	3.11
11/7/2019	90	11700 Block of Haven Dr.	3.53
11/8/2019	97	13900 Block of Skysail St.	2.99
11/8/2019	11	500 Block of Military Dr.	2.70
11/8/2019	60	1300 Block of Calle San Marcos	2.97
11/8/2019	31	4300 Block of Cedar St.	2.89
11/8/2019	54	3700 Block of Seagull Blvd.	3.05
11/8/2019	12	2200 Block of Buford Ave.	3.38
11/8/2019	51	200 Block of Gibson Ln.	3.36
11/8/2019	93	11000 Block of Annville Rd.	3.86
11/9/2019	96	14900 Block of Windward Dr.	2.64
11/9/2019	99	3900 Block of Elvis Dr.	3.08
11/9/2019	14	900 Block of Rosedale Dr.	3.08
11/9/2019	16	4200 Block of Wildcat Dr.	3.55
11/10/2019	95	15800 Block of El Socorro Loop	2.54
11/10/2019	82	2100 Block of Whispering Oak Dr.	2.59

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/10/2019	55	500 Block of Belden St.	3.10
11/10/2019	87	5200 Block of Northwest Trl.	3.38
11/11/2019	4	14200 Block of Playa del Rey	3.01
11/11/2019	3	3000 Block of S Fork Dr.	2.91
11/11/2019	23	5500 Block of Wooldridge Rd.	3.03
11/11/2019	29	1600 Block of La Joya St.	3.09
11/11/2019	52	200 Block of Junior Beck Dr.	3.43
11/11/2019	13	1500 Block of 6th St.	2.89
11/11/2019	65	700 Block of Westchester Dr.	3.21
11/11/2019	86	14800 Block of Santa Gertrudis Dr.	3.28
11/11/2019	83	4100 Block of Summit Dr.	2.23
11/11/2019	40	9500 Block of Quetzal St.	2.55
11/11/2019	76	1100 Block of Harbor Lights Dr.	2.61
11/11/2019	85	300 Block of Glenmore St.	2.53
11/11/2019	77	5000 Block of Cape Ann Dr.	2.63
11/12/2019	96	14900 Block of Windward Dr.	2.93
11/12/2019	8	1100 Block of Cornerstone Dr.	2.91
11/12/2019	70	1600 Block of E Manor Dr.	3.06
11/12/2019	15	6100 Block of Parkway Dr.	2.74
11/12/2019	73	5600 Block of King Trl.	3.38
11/12/2019	61	200 Block of Saratoga Blvd.	3.71
11/12/2019	26	200 Block of Eastgate Dr.	3.34
11/12/2019	87	5200 Block of Northwest Trl.	3.53
11/13/2019	45	15200 Block of Cruiser St.	2.57
11/13/2019	36	1300 Block of Sandstone Dr.	2.98
11/13/2019	71	5500 Block of Fox Run Dr.	2.85
11/13/2019	68	5300 Block of Alejandro St.	3.33

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/13/2019	14	900 Block of Rosedale Dr.	3.44
11/13/2019	50	5500 Block of IH 37 Access Rd.	3.88
11/13/2019	47	8100 Block of Barrogate Dr.	3.98
11/13/2019	90	11700 Block of Haven Dr.	3.63
11/13/2019	94	15200 Block of Caravel Dr.	2.69
11/13/2019	24	2300 Block of Rodd Field Rd.	3.33
11/13/2019	39	5900 Block of Long Creek Dr.	2.57
11/13/2019	55	500 Block of Belden St.	3.53
11/13/2019	18	900 Block of Nueces Bay Blvd.	3.49
11/13/2019	1	4800 Block of Neptune St.	3.99
11/13/2019	62	5800 Block of Hampshire Rd.	3.85
11/13/2019	16	4200 Block of Wildcat Dr.	4.14
11/13/2019	83	4100 Block of Summit Dr.	2.20
11/13/2019	40	9500 Block of Quetzal St.	2.74
11/13/2019	76	1100 Block of Harbor Lights Dr.	2.87
11/13/2019	85	300 Block of Glenmore St.	2.57
11/13/2019	77	5000 Block of Cape Ann Dr.	2.81
11/14/2019	95	15800 Block of El Socorro Loop	2.32
11/14/2019	72	7700 Block of Starnberg Lake Dr.	3.09
11/14/2019	2	5800 Block of St. Andrews Dr.	3.08
11/14/2019	33	3900 Block of Ocean Dr.	3.12
11/14/2019	25	4100 Block of Bascule Dr.	3.64
11/14/2019	48	1200 Block of Southern Minerals Rd.	3.84
11/14/2019	44	9600 Block of Wilkins Dr.	3.81
11/14/2019	98	15800 Block of Almeria Ave.	2.78
11/14/2019	74	7900 Block of Impala Dr.	3.24
11/14/2019	78	7600 Block of Timber Crest Dr.	3.47

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/14/2019	69	4000 Block of Donaho Dr.	3.35
11/14/2019	66	600 Block of Southern St.	3.56
11/14/2019	64	4000 Block of Hidalgo St.	3.61
11/14/2019	91	2700 Block of Wind Rock Dr.	3.55
11/15/2019	4	14200 Block of Playa del Rey	3.10
11/15/2019	84	3600 Block of Flour Bluff Dr.	3.10
11/15/2019	99	3900 Block of Elvis Dr.	3.34
11/15/2019	22	6700 Block of Weber Rd.	3.44
11/15/2019	20	3900 Block of Cott St.	3.51
11/15/2019	6	1200 Block of 10th St.	3.01
11/15/2019	27	2800 Block of S Port Ave.	3.49
11/15/2019	89	3800 Block of Castle Ridge Dr.	3.04
11/15/2019	73	5600 Block of King Trl.	3.53
11/15/2019	61	200 Block of Saratoga Blvd.	3.40
11/15/2019	26	200 Block of Eastgate Dr.	3.38
11/15/2019	87	5200 Block of Northwest Trl.	3.66
11/16/2019	98	15800 Block of Almeria Ave.	2.60
11/16/2019	38	7500 Block of Annemasse St.	3.28
11/16/2019	25	4100 Block of Bascule Dr.	3.08
11/16/2019	93	11000 Block of Annville Rd.	4.23
11/17/2019	97	13900 Block of Skysail St.	3.47
11/17/2019	8	1100 Block of Cornerstone Dr.	2.98
11/17/2019	26	200 Block of Eastgate Dr.	3.45
11/17/2019	86	14800 Block of Santa Gertrudis Dr.	3.18
11/18/2019	83	4100 Block of Summit Dr.	2.31
11/18/2019	40	9500 Block of Quetzal St.	2.85
11/18/2019	76	1100 Block of Harbor Lights Dr.	2.97

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/18/2019	85	300 Block of Glenmore St.	2.70
11/18/2019	77	5000 Block of Cape Ann Dr.	3.01
11/18/2019	96	14900 Block of Windward Dr.	2.83
11/18/2019	38	7500 Block of Annemasse St.	3.01
11/18/2019	80	7000 Block of Arapahoe St.	3.13
11/18/2019	35	4700 Block of Congressional Dr.	3.10
11/18/2019	58	4800 Block of French Dr.	3.34
11/18/2019	19	1300 Block of Horne Rd.	3.47
11/18/2019	92	300 Block of Wildwood Dr.	3.96
11/19/2019	97	13900 Block of Skysail St.	3.23
11/19/2019	43	200 Block of Caribbean Dr.	2.91
11/19/2019	37	6500 Block of Brockhampton St.	3.05
11/19/2019	34	4300 Block of Harry St.	3.35
11/19/2019	10	3100 Block of Saratoga Blvd.	3.20
11/19/2019	57	1400 Block of Arlington Dr.	3.33
11/19/2019	46	8900 Block of McNorton Rd.	3.80
11/19/2019	72	7700 Block of Starnberg Lake Dr.	3.28
11/19/2019	15	6100 Block of Parkway Dr.	3.36
11/19/2019	2	5800 Block of St. Andrews Dr.	2.83
11/19/2019	70	1600 Block of E Manor Dr.	3.28
11/19/2019	33	3900 Block of Ocean Dr.	3.19
11/19/2019	48	1200 Block of Southern Minerals Rd.	3.90
11/19/2019	44	9600 Block of Wilkins Dr.	3.64
11/20/2019	83	4100 Block of Summit Dr.	2.39
11/20/2019	40	9500 Block of Quetzal St.	2.80
11/20/2019	76	1100 Block of Harbor Lights Dr.	2.93
11/20/2019	85	300 Block of Glenmore St.	2.89

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/20/2019	77	5000 Block of Cape Ann Dr.	3.08
11/20/2019	45	15200 Block of Cruiser St.	3.13
11/20/2019	42	700 Block of Orleans Dr.	3.30
11/20/2019	21	900 Block of Lum Ave.	3.14
11/20/2019	32	4900 Block of Haket Dr.	3.81
11/20/2019	28	1700 Block of Bois d' Arc Pl.	3.79
11/20/2019	9	1000 Block of International Dr.	3.74
11/20/2019	49	100 Block of Commerce St.	3.73
11/20/2019	91	2700 Block of Wind Rock Dr.	3.82
11/20/2019	69	4000 Block of Donaho Dr.	3.89
11/20/2019	5	4600 Block of Evelyn St.	3.41
11/20/2019	66	600 Block of Southern St.	3.74
11/20/2019	67	500 Block of S Carancahua St.	3.69
11/20/2019	64	4000 Block of Hidalgo St.	3.75
11/20/2019	53	9100 Block of Stock Dr.	3.04
11/20/2019	88	4200 Block of Western Dr.	4.06
11/20/2019	94	15200 Block of Caravel Dr.	2.81
11/20/2019	95	15800 Block of El Socorro Loop	2.75
11/20/2019	41	1600 Block of Amber Dr.	3.04
11/20/2019	81	6600 Block of Meadowheights Dr.	3.80
11/20/2019	75	2900 Block of Oso Pkwy.	2.75
11/20/2019	74	7900 Block of Impala Dr.	2.81
11/20/2019	78	7600 Block of Timber Crest Dr.	3.02
11/20/2019	80	7000 Block of Arapahoe St.	3.20
11/21/2019	98	15800 Block of Almeria Ave.	2.65
11/21/2019	82	2100 Block of Whispering Oak Dr.	2.90
11/21/2019	79	900 Block of Egyptian Dr.	3.17

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/21/2019	7	600 Block of Carmel Pkwy.	3.16
11/21/2019	59	3600 Block of Capri Dr.	3.24
11/21/2019	30	3100 Block of Brawner Pkwy.	3.41
11/21/2019	56	200 Block of Amistad St.	3.34
11/21/2019	90	11700 Block of Haven Dr.	3.50
11/21/2019	97	13900 Block of Skysail St.	3.25
11/21/2019	11	500 Block of Military Dr.	2.70
11/21/2019	60	1300 Block of Calle San Marcos	3.17
11/21/2019	31	4300 Block of Cedar St.	3.06
11/21/2019	54	3700 Block of Seagull Blvd.	3.01
11/21/2019	12	2200 Block of Buford Ave.	3.38
11/21/2019	51	200 Block of Gibson Ln.	3.53
11/21/2019	93	11000 Block of Annville Rd.	3.76
11/22/2019	45	15200 Block of Cruiser St.	2.74
11/22/2019	36	1300 Block of Sandstone Dr.	3.04
11/22/2019	71	5500 Block of Fox Run Dr.	2.93
11/22/2019	68	5300 Block of Alejandro St.	3.14
11/22/2019	14	900 Block of Rosedale Dr.	3.14
11/22/2019	50	5500 Block of IH 37 Access Rd.	3.63
11/22/2019	47	8100 Block of Barrogate Dr.	3.63
11/22/2019	90	11700 Block of Haven Dr.	3.38
11/22/2019	11	500 Block of Military Dr.	2.61
11/22/2019	59	3600 Block of Capri Dr.	3.12
11/22/2019	60	1300 Block of Calle San Marcos	3.06
11/22/2019	31	4300 Block of Cedar St.	3.07
11/22/2019	34	4300 Block of Harry St.	3.12
11/22/2019	54	3700 Block of Seagull Blvd.	3.00

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/22/2019	12	2200 Block of Buford Ave.	3.50
11/22/2019	51	200 Block of Gibson Ln.	3.60
11/23/2019	96	14900 Block of Windward Dr.	3.12
11/23/2019	99	3900 Block of Elvis Dr.	3.08
11/23/2019	14	900 Block of Rosedale Dr.	2.97
11/23/2019	16	4200 Block of Wildcat Dr.	3.80
11/23/2019	16	4200 Block of Wildcat Dr.	3.78
11/24/2019	95	15800 Block of El Socorro Loop	2.55
11/24/2019	82	2100 Block of Whispering Oak Dr.	2.83
11/24/2019	55	500 Block of Belden St.	3.31
11/24/2019	87	5200 Block of Northwest Trl.	3.75
11/25/2019	83	4100 Block of Summit Dr.	2.20
11/25/2019	40	9500 Block of Quetzal St.	2.59
11/25/2019	76	1100 Block of Harbor Lights Dr.	2.65
11/25/2019	85	300 Block of Glenmore St.	2.51
11/25/2019	77	5000 Block of Cape Ann Dr.	2.79
11/25/2019	95	15800 Block of El Socorro Loop	2.77
11/25/2019	72	7700 Block of Starnberg Lake Dr.	3.40
11/25/2019	2	5800 Block of St. Andrews Dr.	3.13
11/25/2019	33	3900 Block of Ocean Dr.	3.26
11/25/2019	25	4100 Block of Bascule Dr.	3.50
11/25/2019	48	1200 Block of Southern Minerals Rd.	3.88
11/25/2019	44	9600 Block of Wilkins Dr.	3.81
11/25/2019	61	200 Block of Saratoga Blvd.	3.49
11/26/2019	4	14200 Block of Playa del Rey	2.71
11/26/2019	3	3000 Block of S Fork Dr.	3.14
11/26/2019	23	5500 Block of Wooldridge Rd.	2.98

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/26/2019	29	1600 Block of La Joya St.	2.80
11/26/2019	52	200 Block of Junior Beck Dr.	3.27
11/26/2019	13	1500 Block of 6th St.	3.23
11/26/2019	65	700 Block of Westchester Dr.	3.29
11/26/2019	86	14800 Block of Santa Gertrudis Dr.	2.99
11/27/2019	24	2300 Block of Rodd Field Rd.	3.07
11/27/2019	55	500 Block of Belden St.	3.14
11/27/2019	1	4800 Block of Neptune St.	3.50
11/27/2019	62	5800 Block of Hampshire Rd.	3.29
11/27/2019	83	4100 Block of Summit Dr.	2.20
11/27/2019	40	9500 Block of Quetzal St.	2.72
11/27/2019	76	1100 Block of Harbor Lights Dr.	2.77
11/27/2019	85	300 Block of Glenmore St.	2.66
11/27/2019	77	5000 Block of Cape Ann Dr.	2.73
11/27/2019	96	14900 Block of Windward Dr.	3.11
11/27/2019	8	1100 Block of Cornerstone Dr.	2.99
11/27/2019	8	1100 Block of Cornerstone Dr.	3.05
11/27/2019	70	1600 Block of E Manor Dr.	3.10
11/27/2019	15	6100 Block of Parkway Dr.	3.20
11/27/2019	73	5600 Block of King Trl.	3.07
11/27/2019	61	200 Block of Saratoga Blvd.	3.22
11/27/2019	26	200 Block of Eastgate Dr.	3.10
11/27/2019	87	5200 Block of Northwest Trl.	3.49
11/27/2019	87	5200 Block of Northwest Trl.	3.72
11/28/2019	94	15200 Block of Caravel Dr.	3.02
11/28/2019	39	5900 Block of Long Creek Dr.	2.90
11/28/2019	61	200 Block of Saratoga Blvd.	3.61

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/28/2019	18	900 Block of Nueces Bay Blvd.	3.30
11/28/2019	16	4200 Block of Wildcat Dr.	3.91
11/29/2019	4	14200 Block of Playa del Rey	2.76
11/29/2019	58	4800 Block of French Dr.	3.02
11/29/2019	29	1600 Block of La Joya St.	2.77
11/29/2019	88	4200 Block of Western Dr.	3.94
11/30/2019	98	15800 Block of Almeria Ave.	2.78
11/30/2019	38	7500 Block of Annemasse St.	3.24
11/30/2019	25	4100 Block of Bascule Dr.	3.28
11/30/2019	93	11000 Block of Annville Rd.	3.85

December

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/1/2019	97	13900 Block of Skysail St.	3.14
12/1/2019	8	1100 Block of Cornerstone Dr.	2.91
12/1/2019	26	200 Block of Eastgate Dr.	3.16
12/1/2019	86	14800 Block of Santa Gertrudis Dr.	3.06
12/2/2019	83	4100 Block of Summit Dr.	2.07
12/2/2019	40	9500 Block of Quetzal St.	2.58
12/2/2019	76	1100 Block of Harbor Lights Dr.	2.61
12/2/2019	85	300 Block of Glenmore St.	2.51
12/2/2019	77	5000 Block of Cape Ann Dr.	2.52
12/2/2019	20	3900 Block of Cott St.	3.30
12/2/2019	6	1200 Block of 10th St.	2.95
12/2/2019	27	2800 Block of S Port Ave.	3.54
12/2/2019	89	3800 Block of Castle Ridge Dr.	3.10

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/2/2019	4	14200 Block of Playa del Rey	2.97
12/2/2019	84	3600 Block of Flour Bluff Dr.	2.90
12/2/2019	99	3900 Block of Elvis Dr.	3.12
12/2/2019	22	6700 Block of Weber Rd.	3.30
12/3/2019	28	1700 Block of Bois d' Arc Pl.	3.49
12/3/2019	9	1000 Block of International Dr.	3.34
12/3/2019	49	100 Block of Commerce St.	3.42
12/3/2019	91	2700 Block of Wind Rock Dr.	3.43
12/3/2019	6	1200 Block of 10th St.	3.03
12/3/2019	45	15200 Block of Cruiser St.	2.93
12/3/2019	42	700 Block of Orleans Dr.	2.81
12/3/2019	21	900 Block of Lum Ave.	3.04
12/3/2019	32	4900 Block of Hakel Dr.	3.46
12/4/2019	83	4100 Block of Summit Dr.	2.27
12/4/2019	40	9500 Block of Quetzal St.	2.73
12/4/2019	76	1100 Block of Harbor Lights Dr.	2.73
12/4/2019	85	300 Block of Glenmore St.	2.56
12/4/2019	77	5000 Block of Cape Ann Dr.	2.72
12/4/2019	98	15800 Block of Almeria Ave.	2.90
12/4/2019	82	2100 Block of Whispering Oak Dr.	2.89
12/4/2019	79	900 Block of Egyptian Dr.	2.87
12/4/2019	7	600 Block of Carmel Pkwy.	2.82
12/4/2019	58	4800 Block of French Dr.	3.06
12/4/2019	95	15800 Block of El Socorro Loop	2.34
12/4/2019	59	3600 Block of Capri Dr.	3.14
12/4/2019	98	15800 Block of Almeria Ave.	2.96
12/4/2019	59	3600 Block of Capri Dr.	3.19

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/4/2019	30	3100 Block of Brawner Pkwy.	3.19
12/4/2019	56	200 Block of Amistad St.	3.05
12/4/2019	90	11700 Block of Haven Dr.	3.48
12/4/2019	45	15200 Block of Cruiser St.	3.35
12/4/2019	36	1300 Block of Sandstone Dr.	2.63
12/4/2019	71	5500 Block of Fox Run Dr.	2.83
12/4/2019	68	5300 Block of Alejandro St.	2.95
12/4/2019	14	900 Block of Rosedale Dr.	2.93
12/4/2019	50	5500 Block of IH 37 Access Rd.	3.55
12/4/2019	47	8100 Block of Barrogate Dr.	3.61
12/4/2019	90	11700 Block of Haven Dr.	3.29
12/4/2019	6	1200 Block of 10th St.	3.45
12/5/2019	97	13900 Block of Skysail St.	3.36
12/5/2019	11	500 Block of Military Dr.	2.51
12/5/2019	60	1300 Block of Calle San Marcos	2.89
12/5/2019	31	4300 Block of Cedar St.	2.81
12/5/2019	10	3100 Block of Saratoga Blvd.	3.11
12/5/2019	61	200 Block of Saratoga Blvd.	3.44
12/5/2019	26	200 Block of Eastgate Dr.	3.12
12/5/2019	54	3700 Block of Seagull Blvd.	2.77
12/5/2019	12	2200 Block of Buford Ave.	3.34
12/5/2019	51	200 Block of Gibson Ln.	3.20
12/5/2019	93	11000 Block of Annville Rd.	3.79
12/6/2019	95	15800 Block of El Socorro Loop	2.29
12/6/2019	72	7700 Block of Starnberg Lake Dr.	3.24
12/6/2019	2	5800 Block of St. Andrews Dr.	2.80
12/6/2019	33	3900 Block of Ocean Dr.	2.90

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/6/2019	25	4100 Block of Bascule Dr.	3.25
12/6/2019	48	1200 Block of Southern Minerals Rd.	3.73
12/6/2019	44	9600 Block of Wilkins Dr.	3.46
12/7/2019	96	14900 Block of Windward Dr.	2.75
12/7/2019	99	3900 Block of Elvis Dr.	3.05
12/7/2019	14	900 Block of Rosedale Dr.	2.90
12/7/2019	16	4200 Block of Wildcat Dr.	3.63
12/8/2019	95	15800 Block of El Socorro Loop	2.29
12/8/2019	82	2100 Block of Whispering Oak Dr.	2.56
12/8/2019	55	500 Block of Belden St.	2.99
12/8/2019	87	5200 Block of Northwest Trl.	3.79
12/9/2019	83	4100 Block of Summit Dr.	2.17
12/9/2019	40	9500 Block of Quetzal St.	2.60
12/9/2019	76	1100 Block of Harbor Lights Dr.	2.60
12/9/2019	85	300 Block of Glenmore St.	2.32
12/9/2019	77	5000 Block of Cape Ann Dr.	2.71
12/9/2019	4	14200 Block of Playa del Rey	2.64
12/9/2019	3	3000 Block of S Fork Dr.	3.46
12/9/2019	23	5500 Block of Wooldridge Rd.	3.23
12/9/2019	29	1600 Block of La Joya St.	3.35
12/9/2019	52	200 Block of Junior Beck Dr.	3.70
12/9/2019	13	1500 Block of 6th St.	3.41
12/9/2019	65	700 Block of Westchester Dr.	3.60
12/9/2019	86	14800 Block of Santa Gertrudis Dr.	3.56
12/10/2019	96	14900 Block of Windward Dr.	3.18
12/10/2019	8	1100 Block of Cornerstone Dr.	3.41
12/10/2019	70	1600 Block of E Manor Dr.	3.39

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/10/2019	15	6100 Block of Parkway Dr.	3.42
12/10/2019	73	5600 Block of King Trl.	3.34
12/10/2019	61	200 Block of Saratoga Blvd.	3.53
12/10/2019	26	200 Block of Eastgate Dr.	3.33
12/10/2019	87	5200 Block of Northwest Trl.	3.55
12/11/2019	94	15200 Block of Caravel Dr.	2.83
12/11/2019	24	2300 Block of Rodd Field Rd.	3.05
12/11/2019	39	5900 Block of Long Creek Dr.	3.13
12/11/2019	55	500 Block of Belden St.	3.31
12/11/2019	18	900 Block of Nueces Bay Blvd.	3.39
12/11/2019	1	4800 Block of Neptune St.	3.60
12/11/2019	62	5800 Block of Hampshire Rd.	3.42
12/11/2019	16	4200 Block of Wildcat Dr.	3.75
12/11/2019	98	15800 Block of Almeria Ave.	2.53
12/11/2019	74	7900 Block of Impala Dr.	3.12
12/11/2019	78	7600 Block of Timber Crest Dr.	3.15
12/11/2019	69	4000 Block of Donaho Dr.	3.27
12/11/2019	66	600 Block of Southern St.	3.31
12/11/2019	64	4000 Block of Hidalgo St.	3.34
12/11/2019	91	2700 Block of Wind Rock Dr.	3.45
12/11/2019	83	4100 Block of Summit Dr.	2.03
12/11/2019	40	9500 Block of Quetzal St.	2.99
12/11/2019	76	1100 Block of Harbor Lights Dr.	2.96
12/11/2019	85	300 Block of Glenmore St.	2.79
12/11/2019	77	5000 Block of Cape Ann Dr.	2.88
12/12/2019	97	13900 Block of Skysail St.	3.25
12/12/2019	43	200 Block of Caribbean Dr.	2.89

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/12/2019	37	6500 Block of Brockhampton St.	2.83
12/12/2019	34	4300 Block of Harry St.	2.87
12/12/2019	10	3100 Block of Saratoga Blvd.	3.16
12/12/2019	57	1400 Block of Arlington Dr.	2.90
12/12/2019	46	8900 Block of McNorton Rd.	3.63
12/12/2019	96	14900 Block of Windward Dr.	2.95
12/12/2019	38	7500 Block of Annemasse St.	3.12
12/12/2019	80	7000 Block of Arapahoe St.	3.14
12/12/2019	35	4700 Block of Congressional Dr.	3.31
12/12/2019	58	4800 Block of French Dr.	3.09
12/12/2019	19	1300 Block of Horne Rd.	3.26
12/12/2019	92	300 Block of Wildwood Dr.	3.76
12/13/2019	94	15200 Block of Caravel Dr.	2.86
12/13/2019	41	1600 Block of Amber Dr.	2.91
12/13/2019	75	2900 Block of Oso Pkwy.	2.90
12/13/2019	81	6600 Block of Meadowheights Dr.	3.03
12/13/2019	5	4600 Block of Evelyn St.	2.82
12/13/2019	67	500 Block of S Carancahua St.	3.28
12/13/2019	53	9100 Block of Stock Dr.	2.93
12/13/2019	88	4200 Block of Western Dr.	4.07
12/14/2019	98	15800 Block of Almeria Ave.	2.78
12/14/2019	38	7500 Block of Annemasse St.	3.29
12/14/2019	25	4100 Block of Bascule Dr.	3.47
12/14/2019	93	11000 Block of Annville Rd.	3.89
12/15/2019	97	13900 Block of Skysail St.	2.97
12/15/2019	8	1100 Block of Cornerstone Dr.	3.11
12/15/2019	26	200 Block of Eastgate Dr.	3.40

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/15/2019	86	14800 Block of Santa Gertrudis Dr.	3.43
12/16/2019	45	15200 Block of Cruiser St.	3.48
12/16/2019	36	1300 Block of Sandstone Dr.	3.10
12/16/2019	71	5500 Block of Fox Run Dr.	3.19
12/16/2019	68	5300 Block of Alejandro St.	3.22
12/16/2019	14	900 Block of Rosedale Dr.	3.44
12/16/2019	50	5500 Block of IH 37 Access Rd.	3.92
12/16/2019	47	8100 Block of Barrogate Dr.	4.03
12/16/2019	90	11700 Block of Haven Dr.	3.77
12/16/2019	83	4100 Block of Summit Dr.	2.28
12/16/2019	40	9500 Block of Quetzal St.	2.73
12/16/2019	76	1100 Block of Harbor Lights Dr.	2.80
12/16/2019	85	300 Block of Glenmore St.	2.50
12/16/2019	77	5000 Block of Cape Ann Dr.	2.88
12/17/2019	33	3900 Block of Ocean Dr.	3.28
12/17/2019	25	4100 Block of Bascule Dr.	3.59
12/17/2019	48	1200 Block of Southern Minerals Rd.	4.07
12/17/2019	44	9600 Block of Wilkins Dr.	4.11
12/17/2019	95	15800 Block of El Socorro Loop	2.46
12/17/2019	72	7700 Block of Starnberg Lake Dr.	3.43
12/17/2019	2	5800 Block of St. Andrews Dr.	3.07
12/18/2019	4	14200 Block of Playa del Rey	3.50
12/18/2019	84	3600 Block of Flour Bluff Dr.	3.33
12/18/2019	99	3900 Block of Elvis Dr.	3.53
12/18/2019	22	6700 Block of Weber Rd.	3.90
12/18/2019	20	3900 Block of Cott St.	3.69
12/18/2019	6	1200 Block of 10th St.	3.38

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/18/2019	27	2800 Block of S Port Ave.	3.99
12/18/2019	89	3800 Block of Castle Ridge Dr.	3.49
12/18/2019	83	4100 Block of Summit Dr.	2.27
12/18/2019	40	9500 Block of Quetzal St.	2.88
12/18/2019	76	1100 Block of Harbor Lights Dr.	2.94
12/18/2019	85	300 Block of Glenmore St.	2.74
12/18/2019	77	5000 Block of Cape Ann Dr.	3.03
12/18/2019	45	15200 Block of Cruiser St.	3.70
12/18/2019	42	700 Block of Orleans Dr.	3.10
12/18/2019	21	900 Block of Lum Ave.	3.19
12/18/2019	32	4900 Block of Hakel Dr.	3.82
12/18/2019	28	1700 Block of Bois d' Arc Pl.	3.89
12/18/2019	9	1000 Block of International Dr.	3.89
12/18/2019	49	100 Block of Commerce St.	3.71
12/18/2019	91	2700 Block of Wind Rock Dr.	3.74
12/18/2019	41	1600 Block of Amber Dr.	3.11
12/18/2019	8	1100 Block of Cornerstone Dr.	3.24
12/18/2019	70	1600 Block of E Manor Dr.	3.39
12/18/2019	15	6100 Block of Parkway Dr.	3.37
12/18/2019	73	5600 Block of King Trl.	3.58
12/18/2019	61	200 Block of Saratoga Blvd.	3.82
12/18/2019	26	200 Block of Eastgate Dr.	3.55
12/18/2019	87	5200 Block of Northwest Trl.	3.80
12/19/2019	97	13900 Block of Skysail St.	3.49
12/19/2019	11	500 Block of Military Dr.	2.72
12/19/2019	60	1300 Block of Calle San Marcos	3.37
12/19/2019	31	4300 Block of Cedar St.	3.34

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/19/2019	54	3700 Block of Seagull Blvd.	3.11
12/19/2019	12	2200 Block of Buford Ave.	3.64
12/19/2019	51	200 Block of Gibson Ln.	3.80
12/19/2019	93	11000 Block of Annville Rd.	4.06
12/19/2019	98	15800 Block of Almeria Ave.	2.69
12/19/2019	82	2100 Block of Whispering Oak Dr.	3.18
12/19/2019	79	900 Block of Egyptian Dr.	3.17
12/19/2019	7	600 Block of Carmel Pkwy.	3.14
12/19/2019	59	3600 Block of Capri Dr.	3.22
12/19/2019	30	3100 Block of Brawner Pkwy.	3.35
12/19/2019	56	200 Block of Amistad St.	3.27
12/19/2019	90	11700 Block of Haven Dr.	3.33
12/20/2019	4	14200 Block of Playa del Rey	3.37
12/20/2019	3	3000 Block of S Fork Dr.	3.28
12/20/2019	23	5500 Block of Wooldridge Rd.	3.22
12/20/2019	29	1600 Block of La Joya St.	3.14
12/20/2019	52	200 Block of Junior Beck Dr.	3.40
12/20/2019	13	1500 Block of 6th St.	3.31
12/20/2019	65	700 Block of Westchester Dr.	3.38
12/20/2019	86	14800 Block of Santa Gertrudis Dr.	3.08
12/21/2019	96	14900 Block of Windward Dr.	3.32
12/21/2019	99	3900 Block of Elvis Dr.	3.19
12/21/2019	14	900 Block of Rosedale Dr.	2.97
12/21/2019	16	4200 Block of Wildcat Dr.	3.91
12/22/2019	95	15800 Block of El Socorro Loop	2.77
12/22/2019	82	2100 Block of Whispering Oak Dr.	2.84
12/22/2019	55	500 Block of Belden St.	3.39

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/22/2019	87	5200 Block of Northwest Trl.	3.64
12/23/2019	83	4100 Block of Summit Dr.	2.51
12/23/2019	40	9500 Block of Quetzal St.	2.75
12/23/2019	76	1100 Block of Harbor Lights Dr.	2.87
12/23/2019	85	300 Block of Glenmore St.	2.72
12/23/2019	77	5000 Block of Cape Ann Dr.	3.09
12/23/2019	96	14900 Block of Windward Dr.	3.19
12/23/2019	8	1100 Block of Cornerstone Dr.	3.32
12/23/2019	70	1600 Block of E Manor Dr.	3.45
12/23/2019	15	6100 Block of Parkway Dr.	3.43
12/23/2019	73	5600 Block of King Trl.	3.49
12/23/2019	61	200 Block of Saratoga Blvd.	3.78
12/23/2019	26	200 Block of Eastgate Dr.	3.52
12/23/2019	87	5200 Block of Northwest Trl.	3.68
12/24/2019	94	15200 Block of Caravel Dr.	3.21
12/24/2019	24	2300 Block of Rodd Field Rd.	3.50
12/24/2019	39	5900 Block of Long Creek Dr.	3.67
12/24/2019	55	500 Block of Belden St.	3.69
12/24/2019	18	900 Block of Nueces Bay Blvd.	4.04
12/24/2019	1	4800 Block of Neptune St.	4.00
12/24/2019	62	5800 Block of Hampshire Rd.	3.82
12/24/2019	16	4200 Block of Wildcat Dr.	4.15
12/24/2019	69	4000 Block of Donaho Dr.	3.66
12/24/2019	3	3000 Block of S Fork Dr.	3.42
12/24/2019	75	2900 Block of Oso Pkwy.	3.42
12/24/2019	23	5500 Block of Wooldridge Rd.	3.59
12/24/2019	29	1600 Block of La Joya St.	3.59

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/24/2019	52	200 Block of Junior Beck Dr.	3.89
12/24/2019	13	1500 Block of 6th St.	3.53
12/24/2019	65	700 Block of Westchester Dr.	3.74
12/24/2019	86	14800 Block of Santa Gertrudis Dr.	3.76
12/25/2019	83	4100 Block of Summit Dr.	2.58
12/25/2019	40	9500 Block of Quetzal St.	3.13
12/25/2019	76	1100 Block of Harbor Lights Dr.	3.25
12/25/2019	85	300 Block of Glenmore St.	3.07
12/25/2019	77	5000 Block of Cape Ann Dr.	3.20
12/25/2019	98	15800 Block of Almeria Ave.	2.98
12/25/2019	74	7900 Block of Impala Dr.	3.36
12/25/2019	66	600 Block of Southern St.	3.80
12/25/2019	91	2700 Block of Wind Rock Dr.	3.86
12/26/2019	78	7600 Block of Timber Crest Dr.	3.43
12/26/2019	69	4000 Block of Donaho Dr.	3.76
12/26/2019	64	4000 Block of Hidalgo St.	3.71
12/26/2019	96	14900 Block of Windward Dr.	3.51
12/26/2019	38	7500 Block of Annemasse St.	3.37
12/26/2019	80	7000 Block of Arapahoe St.	3.40
12/26/2019	35	4700 Block of Congressional Dr.	3.33
12/26/2019	58	4800 Block of French Dr.	3.37
12/26/2019	19	1300 Block of Horne Rd.	3.40
12/26/2019	92	300 Block of Wildwood Dr.	3.65
12/27/2019	97	13900 Block of Skysail St.	3.62
12/27/2019	43	200 Block of Caribbean Dr.	3.14
12/27/2019	37	6500 Block of Brockhampton St.	3.21
12/27/2019	34	4300 Block of Harry St.	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/27/2019	10	3100 Block of Saratoga Blvd.	3.28
12/27/2019	57	1400 Block of Arlington Dr.	3.16
12/27/2019	46	8900 Block of McNorton Rd.	3.76
12/28/2019	98	15800 Block of Almeria Ave.	3.07
12/28/2019	38	7500 Block of Annemasse St.	3.33
12/28/2019	25	4100 Block of Bascule Dr.	3.59
12/28/2019	93	11000 Block of Annville Rd.	4.06
12/29/2019	97	13900 Block of Skysail St.	3.65
12/29/2019	8	1100 Block of Cornerstone Dr.	3.33
12/29/2019	26	200 Block of Eastgate Dr.	3.53
12/29/2019	86	14800 Block of Santa Gertrudis Dr.	3.48
12/30/2019	83	4100 Block of Summit Dr.	2.61
12/30/2019	40	9500 Block of Quetzal St.	2.74
12/30/2019	76	1100 Block of Harbor Lights Dr.	2.88
12/30/2019	85	300 Block of Glenmore St.	2.74
12/30/2019	77	5000 Block of Cape Ann Dr.	3.08
12/30/2019	94	15200 Block of Caravel Dr.	3.18
12/30/2019	41	1600 Block of Amber Dr.	3.28
12/30/2019	75	2900 Block of Oso Pkwy.	3.15
12/30/2019	81	6600 Block of Meadowheights Dr.	3.58
12/30/2019	5	4600 Block of Evelyn St.	3.27
12/30/2019	67	500 Block of S Carancahua St.	3.46
12/30/2019	53	9100 Block of Stock Dr.	3.37
12/30/2019	88	4200 Block of Western Dr.	4.41
12/30/2019	47	8100 Block of Barrogate Dr.	4.13
12/31/2019	4	14200 Block of Playa del Rey	3.36
12/31/2019	58	4800 Block of French Dr.	3.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/31/2019	29	1600 Block of La Joya St.	3.31
12/31/2019	88	4200 Block of Western Dr.	4.27