



2020 Chlorine Residuals

January

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/1/2020	86	14814 Santa Gertrudis Dr.	3.46
1/1/2020	77	5018 Cape Ann Dr.	3.16
1/1/2020	85	302 Glenmore St.	2.96
1/1/2020	65	726 Westchester	3.62
1/1/2020	76	1109 Harbor Lights Dr.	3.22
1/1/2020	23	5506 Wooldridge Rd.	3.46
1/1/2020	40	9550 Quetzal St.	3.12
1/1/2020	83	4101 Summit Dr.	2.66
1/1/2020	4	14233 Playa del Rey	3.18
1/2/2020	87	5226 Northwest Trl.	3.92
1/2/2020	26	225 Eastgate Dr.	3.47
1/2/2020	13	1505 6th St.	3.34
1/2/2020	61	234 Saratoga Blvd.	3.83
1/2/2020	52	221 Junior Beck Dr.	3.59
1/2/2020	73	5649 King Trl.	3.51
1/2/2020	29	1601 La Joya St.	3.19
1/2/2020	15	6130 Parkway Dr.	3.32
1/2/2020	70	1633 E. Manor Dr.	3.38
1/2/2020	3	3013 S Folk Dr.	3.26
1/2/2020	8	1126 Cornerstone Dr.	3.36
1/2/2020	96	14926 Windward Dr.	3.37

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/3/2020	16	4205 Wildcat Dr.	3.66
1/3/2020	62	5809 Hampshire Rd.	3.56
1/3/2020	1	4810 Neptune St.	3.68
1/3/2020	18	902 Nueces Bay Blvd.	3.67
1/3/2020	55	514 Belden St.	3.51
1/3/2020	39	5929 Long Creek Dr.	3.41
1/3/2020	24	2342 Rodd Field Rd.	3.49
1/3/2020	94	15209 Caravel Dr.	3.47
1/4/2020	93	11025 Annville Rd.	3.91
1/4/2020	25	4101 Bascule Dr.	3.38
1/4/2020	38	7525 Annemasse St.	3.19
1/4/2020	98	15806 Almeria Ave.	3.08
1/5/2020	86	14814 Santa Gertrudis Dr.	3.25
1/5/2020	26	225 Eastgate Dr.	3.46
1/5/2020	8	1126 Cornerstone Dr.	3.19
1/5/2020	97	13902 Skysail St.	3.51
1/6/2020	69	4013 Donaho Dr.	3.96
1/6/2020	77	5018 Cape Ann Dr.	3.03
1/6/2020	78	7602 Timber Crest Dr.	3.53
1/6/2020	91	2713 Wind Rock Dr.	3.80
1/6/2020	85	302 Glenmore St.	2.82
1/6/2020	74	7910 Impala Dr.	3.13
1/6/2020	76	1109 Harbor Lights Dr.	2.90
1/6/2020	64	4013 Hidalgo St.	3.91
1/6/2020	66	635 Southern St.	4.06
1/6/2020	40	9550 Quetzal St.	2.85
1/6/2020	98	15806 Almeria Ave.	3.07

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/6/2020	83	4101 Summit Dr.	2.83
1/7/2020	35	4702 Congressional Dr.	3.73
1/7/2020	80	7042 Arapahoe St.	3.45
1/7/2020	92	334 Wildwood Dr.	3.85
1/7/2020	38	7525 Annemasse St.	3.22
1/7/2020	19	1301 Horne Rd.	3.61
1/7/2020	96	14926 Windward Dr.	3.52
1/7/2020	58	4801 French Dr.	3.53
1/8/2020	46	8903 McNorton Rd.	3.70
1/8/2020	37	6502 Brockhampton St.	3.47
1/8/2020	57	1409 Arlington Dr.	3.37
1/8/2020	77	5018 Cape Ann Dr.	3.16
1/8/2020	59	3633 Capri Dr.	3.33
1/8/2020	85	302 Glenmore St.	3.07
1/8/2020	43	245 Caribbean Dr.	3.38
1/8/2020	58	4801 French Dr.	3.39
1/8/2020	76	1109 Harbor Lights Dr.	3.19
1/8/2020	10	3146 Saratoga Blvd.	3.51
1/8/2020	40	9550 Quetzal St.	3.01
1/8/2020	97	13902 Skysail St.	3.78
1/8/2020	98	15806 Almeria Ave.	3.21
1/8/2020	95	15837 El Socorro Loop	2.81
1/8/2020	83	4101 Summit Dr.	2.59
1/8/2020	34	4341 Harry St.	3.50
1/9/2020	89	3814 Castle Ridge Dr.	3.40
1/9/2020	86	14814 Santa Gertrudis Dr.	3.47
1/9/2020	27	2823 S Port Ave.	3.71

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/9/2020	87	5226 Northwest Trl.	3.79
1/9/2020	6	1213 10th St.	3.07
1/9/2020	65	726 Westchester Dr.	3.36
1/9/2020	88	4214 Western Dr.	4.00
1/9/2020	20	3901 Cott St.	3.47
1/9/2020	81	6630 Meadowheights Dr.	3.33
1/9/2020	26	225 Eastgate Dr.	3.39
1/9/2020	53	9105 Stock Dr.	3.15
1/9/2020	22	6713 Weber Rd.	3.46
1/9/2020	61	234 Saratoga Blvd.	3.27
1/9/2020	75	2938 Oso Pkwy.	3.20
1/9/2020	67	509 S. Carancahua St.	3.26
1/9/2020	99	3926 Elvis Dr.	3.45
1/9/2020	23	5506 Wooldridge Rd.	3.36
1/9/2020	5	4609 Evelyn St.	3.22
1/9/2020	84	3640 Flour Bluff Dr.	3.23
1/9/2020	70	1633 E. Manor Dr.	3.35
1/9/2020	41	1605 Amber Dr.	3.27
1/9/2020	4	14233 Playa del Rey	3.54
1/9/2020	8	1126 Cornerstone Dr.	3.41
1/9/2020	94	15209 Caravel Dr.	3.46
1/10/2020	91	2713 Wind Rock Dr.	3.81
1/10/2020	49	113 Commerce St.	3.66
1/10/2020	9	1000 International Dr.	3.71
1/10/2020	28	1718 Bois d' Arc Pl.	3.74
1/10/2020	32	4901 Hakel Dr.	3.61
1/10/2020	21	913 Lum Ave.	3.31

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/10/2020	74	7910 Impala Dr.	3.25
1/10/2020	42	753 Orleans Dr.	3.31
1/10/2020	45	15222 Cruiser St.	3.12
1/11/2020	16	4205 Wildcat Dr.	3.73
1/11/2020	14	922 Rosedale Dr.	3.32
1/11/2020	99	3926 Elvis Dr.	3.66
1/11/2020	96	14926 Windward Dr.	3.54
1/12/2020	87	5226 Northwest Trl.	3.61
1/12/2020	55	514 Belden St.	3.39
1/12/2020	82	2101 Whispering Oak Dr.	3.32
1/12/2020	95	15837 El Socorro Loop	3.11
1/13/2020	83	4101 Summit Dr.	2.66
1/13/2020	40	9550 Quetzal St.	2.90
1/13/2020	76	1109 Harbor Lights Dr.	2.99
1/13/2020	85	302 Glenmore St.	2.82
1/13/2020	77	5018 Cape Ann Dr.	3.03
1/13/2020	98	15806 Almeria Ave.	3.12
1/13/2020	82	2101 Whispering Oak Dr.	3.24
1/13/2020	79	905 Egyptian Dr.	3.15
1/13/2020	7	617 Carmel Pkwy.	3.14
1/13/2020	59	3633 Capri Dr.	3.21
1/13/2020	30	3100 Brawner Pkwy.	3.29
1/13/2020	56	202 Amistad St.	3.14
1/13/2020	90	11722 Haven Dr.	3.67
1/14/2020	93	11025 Annville Rd.	3.76
1/14/2020	51	249 Gibson Ln.	3.40
1/14/2020	12	2219 Buford Ave.	3.82

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/14/2020	54	3710 Seagull Blvd.	3.04
1/14/2020	31	4306 Cedar St.	3.28
1/14/2020	60	1346 Calle San Marcos	3.22
1/14/2020	11	534 Military Dr.	2.78
1/14/2020	97	13902 Skysail St.	3.55
1/15/2020	44	9602 Wilkins Dr.	3.52
1/15/2020	48	1237 Southern Minerals Rd.	3.52
1/15/2020	90	11722 Haven Dr.	3.28
1/15/2020	25	4101 Bascule Dr.	3.16
1/15/2020	47	8121 Barrogate Dr.	3.65
1/15/2020	50	5534 IH 37 Access Rd.	3.43
1/15/2020	33	3913 Ocean Dr.	3.00
1/15/2020	14	922 Rosedale Dr.	3.17
1/15/2020	77	5018 Cape Ann Dr.	2.91
1/15/2020	2	5809 St. Andrews Dr.	2.95
1/15/2020	68	5322 Alejandro St.	3.02
1/15/2020	85	302 Glenmore St.	2.73
1/15/2020	72	7717 Starnberg Lake Dr.	3.00
1/15/2020	71	5510 Fox Run Dr.	3.06
1/15/2020	76	1109 Harbor Lights Dr.	2.90
1/15/2020	40	9550 Quetzal St.	2.85
1/15/2020	36	1338 Sandstone Dr.	3.06
1/15/2020	95	15837 El Socorro Loop	2.84
1/15/2020	45	15222 Cruiser St.	3.54
1/15/2020	83	4101 Summit Dr.	2.63
1/16/2020	98	15806 Almeria Ave.	2.91
1/16/2020	74	7910 Impala Dr.	2.81

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/16/2020	78	7602 Timber Crest Dr.	3.15
1/16/2020	69	4013 Donaho Dr.	3.49
1/16/2020	66	635 Southern St.	3.50
1/16/2020	64	4013 Hidalgo St.	3.57
1/16/2020	91	2713 Wind Rock Dr.	3.20
1/17/2020	90	11722 Haven Dr.	3.61
1/17/2020	56	202 Amistad St.	3.27
1/17/2020	92	334 Wildwood Dr.	3.77
1/17/2020	30	3100 Brawner Pkwy.	2.99
1/17/2020	59	3633 Capri Dr.	3.22
1/17/2020	19	1301 Horne Rd.	3.48
1/17/2020	7	617 Carmel Pkwy.	3.18
1/17/2020	58	4801 French Dr.	3.22
1/17/2020	79	905 Egyptian Dr.	2.98
1/17/2020	82	2101 Whispering Oak Dr.	3.12
1/17/2020	35	4702 Congressional Dr.	3.41
1/17/2020	84	3640 Flour Bluff Dr.	3.16
1/17/2020	80	7042 Arapahoe St.	3.30
1/17/2020	38	7525 Annemasse St.	3.12
1/17/2020	11	534 Military Dr.	2.64
1/17/2020	96	14926 Windward Dr.	3.12
1/18/2020	93	11025 Annville Rd.	3.81
1/18/2020	25	4101 Bascule Dr.	3.34
1/18/2020	38	7525 Annemasse St.	3.15
1/18/2020	98	15806 Almeria Ave.	2.83
1/19/2020	86	14814 Santa Gertrudis Dr.	3.06
1/19/2020	26	225 Eastgate Dr.	3.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/19/2020	8	1126 Cornerstone Dr.	3.06
1/19/2020	97	13902 Skysail St.	3.46
1/20/2020	77	5018 Cape Ann Dr.	2.73
1/20/2020	85	302 Glenmore St.	2.68
1/20/2020	81	6630 Meadowheights Dr.	3.25
1/20/2020	88	4214 Western Dr.	4.18
1/20/2020	76	1109 Harbor Lights Dr.	2.76
1/20/2020	75	2938 Oso Pkwy.	2.79
1/20/2020	40	9550 Quetzal St.	2.71
1/20/2020	53	9105 Stock Dr.	3.03
1/20/2020	41	1605 Amber Dr.	2.88
1/20/2020	83	4101 Summit Dr.	2.62
1/20/2020	94	15209 Caravel Dr.	2.86
1/20/2020	67	509 S. Carancahua St.	3.23
1/20/2020	5	4609 Evelyn St.	2.93
1/21/2020	15	6130 Parkway Dr.	3.32
1/21/2020	87	5226 Northwest Trl.	3.64
1/21/2020	70	1633 E. Manor Dr.	3.12
1/21/2020	8	1126 Cornerstone Dr.	3.25
1/21/2020	26	225 Eastgate Dr.	3.52
1/21/2020	61	234 Saratoga Blvd.	3.83
1/21/2020	96	14926 Windward Dr.	3.18
1/21/2020	73	5649 King Trl.	3.71
1/22/2020	55	514 Belden St.	3.42
1/22/2020	77	5018 Cape Ann Dr.	3.00
1/22/2020	16	4205 Wildcat Dr.	4.02
1/22/2020	39	5929 Long Creek Dr.	3.17

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/22/2020	85	302 Glenmore St.	2.92
1/22/2020	24	2342 Rodd Field Rd.	3.45
1/22/2020	62	5809 Hampshire Rd.	3.70
1/22/2020	76	1109 Harbor Lights Dr.	2.93
1/22/2020	40	9550 Quetzal St.	2.93
1/22/2020	94	15209 Caravel Dr.	3.00
1/22/2020	1	4810 Neptune St.	3.78
1/22/2020	83	4101 Summit Dr.	2.44
1/22/2020	18	902 Nueces Bay Blvd.	3.70
1/23/2020	89	3814 Castle Ridge Dr.	3.27
1/23/2020	27	2823 S Port Ave.	3.59
1/23/2020	29	1601 La Joya St.	3.26
1/23/2020	6	1213 10th St.	3.17
1/23/2020	20	3901 Cott St.	3.46
1/23/2020	23	5506 Wooldridge Rd.	3.01
1/23/2020	86	14814 Santa Gertrudis Dr.	3.38
1/23/2020	22	6713 Weber Rd.	3.56
1/23/2020	99	3926 Elvis Dr.	3.11
1/23/2020	75	2938 Oso Pkwy.	2.99
1/23/2020	65	726 Westchester Dr.	3.42
1/23/2020	52	221 Junior Beck Dr.	3.59
1/23/2020	84	3640 Flour Bluff Dr.	3.03
1/23/2020	3	3013 S Fork Dr.	3.33
1/23/2020	13	1505 6th St.	3.21
1/23/2020	4	14233 Playa del Rey	3.21
1/23/2020	4	14233 Playa del Rey	3.17
1/24/2020	16	4205 Wildcat Dr.	3.96

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/24/2020	62	5809 Hampshire Rd.	3.64
1/24/2020	46	8903 McNorton Rd.	3.63
1/24/2020	1	4810 Neptune St.	3.61
1/24/2020	91	2713 Wind Rock Dr.	3.68
1/24/2020	64	4013 Hidalgo St.	3.56
1/24/2020	57	1409 Arlington Dr.	3.11
1/24/2020	49	113 Commerce St.	3.49
1/24/2020	18	902 Nueces Bay Blvd.	3.78
1/24/2020	9	1000 International Dr.	3.47
1/24/2020	10	3146 Saratoga Blvd.	3.17
1/24/2020	55	514 Belden St.	3.46
1/24/2020	28	1718 Bois d' Arc Pl.	3.67
1/24/2020	34	4341 Harry St.	2.97
1/24/2020	13	1505 6th St.	3.38
1/24/2020	32	4901 Hakel Dr.	3.58
1/24/2020	37	6502 Brockhampton St.	3.00
1/24/2020	39	5929 Long Creek Dr.	3.14
1/24/2020	21	913 Lum Ave.	3.23
1/24/2020	24	2342 Rodd Field Rd.	3.42
1/24/2020	43	245 Caribbean Dr.	3.04
1/24/2020	42	753 Orleans Dr.	2.90
1/24/2020	97	13902 Skysail St.	3.36
1/24/2020	45	15222 Cruiser St.	3.52
1/25/2020	99	3926 Elvis Dr.	3.23
1/25/2020	96	14926 Windward Dr.	3.29
1/25/2020	14	922 Rosedale Dr.	3.20
1/25/2020	16	4205 Wildcat Dr.	4.19

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/26/2020	87	5226 Northwest Trl.	3.70
1/26/2020	55	514 Belden St.	3.72
1/26/2020	82	2101 Whispering Oak Dr.	3.07
1/26/2020	95	15837 El Socorro Loop	2.87
1/27/2020	90	11722 Haven Dr.	3.59
1/27/2020	56	202 Amistad St.	3.33
1/27/2020	30	3100 Brawner Pkwy.	3.21
1/27/2020	77	5018 Cape Ann Dr.	3.15
1/27/2020	59	3633 Capri Dr.	3.29
1/27/2020	85	302 Glenmore St.	2.99
1/27/2020	7	617 Carmel Pkwy.	3.13
1/27/2020	76	1109 Harbor Lights Dr.	3.16
1/27/2020	79	905 Egyptian Dr.	3.28
1/27/2020	40	9550 Quetzal St.	3.08
1/27/2020	82	2101 Whispering Oak Dr.	3.43
1/27/2020	83	4101 Summit Dr.	2.49
1/27/2020	98	15806 Almeria Ave.	2.98
1/27/2020	83	4101 Summit Dr.	2.54
1/28/2020	93	11025 Annville Rd.	4.01
1/28/2020	51	249 Gibson Ln.	3.59
1/28/2020	12	2219 Buford Ave.	3.61
1/28/2020	54	3710 Seagull Blvd.	3.11
1/28/2020	31	4306 Cedar St.	3.13
1/28/2020	60	1346 Calle San Marcos	3.11
1/28/2020	11	534 Military Dr.	3.01
1/28/2020	97	13902 Skysail St.	3.52
1/29/2020	90	11722 Haven Dr.	3.51

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/29/2020	9	1000 International Dr.	3.49
1/29/2020	49	113 Commerce St.	3.54
1/29/2020	47	8121 Barrogate Dr.	3.80
1/29/2020	50	5534 IH 37 Access Rd.	3.80
1/29/2020	1	4810 Neptune St.	3.72
1/29/2020	14	922 Rosedale Dr.	3.50
1/29/2020	68	5322 Alejandro St.	3.30
1/29/2020	77	5018 Cape Ann Dr.	3.00
1/29/2020	85	302 Glenmore St.	3.01
1/29/2020	71	5510 Fox Run Dr.	3.26
1/29/2020	76	1109 Harbor Lights Dr.	3.14
1/29/2020	40	9550 Quetzal St.	2.99
1/29/2020	36	1338 Sandstone Dr.	3.12
1/29/2020	45	15222 Cruiser St.	3.65
1/29/2020	83	4101 Summit Dr.	2.90
1/30/2020	44	9602 Wilkins Dr.	3.78
1/30/2020	48	1237 Southern Minerals Rd.	3.99
1/30/2020	25	4101 Bascule Dr.	3.64
1/30/2020	33	3913 Ocean Dr.	3.34
1/30/2020	2	5809 St. Andrews Dr.	3.11
1/30/2020	95	15837 El Socorro Loop	2.91
1/30/2020	72	7717 Starnberg Lake Dr.	3.66
1/31/2020	88	4214 Western Dr.	4.30
1/31/2020	29	1601 La Joya St.	3.35
1/31/2020	76	1109 Harbor Lights Dr.	3.21
1/31/2020	58	4801 French Dr.	3.51
1/31/2020	40	9550 Quetzal St.	3.10

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
1/31/2020	4	14233 Playa del Rey	3.08
1/31/2020	11	534 Military Dr.	2.86

February

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/1/2020	93	11025 Annville Rd.	4.13
2/1/2020	25	4101 Bascule Dr.	3.66
2/1/2020	38	7525 Annemasse St.	3.46
2/1/2020	98	15806 Almeria Ave.	3.14
2/2/2020	86	14814 Santa Gertrudis Dr.	3.73
2/2/2020	26	225 Eastgate Dr.	3.62
2/2/2020	8	1126 Cornerstone Dr.	3.47
2/2/2020	97	13902 Skysail St.	3.59
2/3/2020	93	11025 Annville Rd.	4.00
2/3/2020	51	249 Gibson Ln.	3.65
2/3/2020	12	2219 Buford Ave.	3.65
2/3/2020	54	3710 Seagull Blvd.	3.24
2/3/2020	77	5018 Cape Ann Dr.	3.16
2/3/2020	31	4306 Cedar St.	3.45
2/3/2020	85	302 Glenmore St.	3.17
2/3/2020	76	1109 Harbor Lights Dr.	3.26
2/3/2020	60	1346 Calle San Marcos	3.56
2/3/2020	40	9550 Quetzal St.	3.07
2/3/2020	83	4101 Summit Dr.	2.71
2/3/2020	11	534 Military Dr.	3.17
2/3/2020	97	13902 Skysail St.	3.75

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/4/2020	22	6713 Weber Rd.	3.72
2/4/2020	89	3814 Castle Ridge Dr.	3.35
2/4/2020	99	3926 Elvis Dr.	3.76
2/4/2020	27	2823 S Port Ave.	3.65
2/4/2020	84	3640 Flour Bluff Dr.	3.41
2/4/2020	6	1213 10th St.	3.24
2/4/2020	4	14233 Playa del Rey	3.43
2/4/2020	20	3901 Cott St.	3.69
2/5/2020	95	15837 El Socorro Loop	3.22
2/5/2020	98	15806 Almeria Ave.	3.01
2/5/2020	91	2713 Wind Rock Dr.	3.65
2/5/2020	32	4901 Hakel Dr.	3.67
2/5/2020	49	113 Commerce St.	3.57
2/5/2020	58	4801 French Dr.	3.42
2/5/2020	59	3633 Capri Dr.	3.45
2/5/2020	77	5018 Cape Ann Dr.	3.22
2/5/2020	9	1000 International Dr.	3.61
2/5/2020	21	913 Lum Ave.	3.52
2/5/2020	85	302 Glenmore St.	3.10
2/5/2020	76	1109 Harbor Lights Dr.	3.54
2/5/2020	28	1718 Bois d' Arc Pl.	3.76
2/5/2020	40	9550 Quetzal St.	3.22
2/5/2020	42	753 Orleans Dr.	3.22
2/5/2020	83	4101 Summit Dr.	2.90
2/5/2020	45	15222 Cruiser St.	3.85
2/6/2020	90	11722 Haven Dr.	3.53
2/6/2020	47	8121 Barrogate Dr.	3.67

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/6/2020	50	5534 IH 37 Access Rd.	3.86
2/6/2020	90	11722 Haven Dr.	3.54
2/6/2020	14	922 Rosedale Dr.	3.26
2/6/2020	7	617 Carmel Pkwy.	3.25
2/6/2020	68	5322 Alejandro St.	3.34
2/6/2020	79	905 Egyptian Dr.	3.17
2/6/2020	56	202 Amistad St.	3.22
2/6/2020	71	5510 Fox Run Dr.	3.30
2/6/2020	82	2101 Whispering Oak Dr.	3.30
2/6/2020	30	3100 Brawner Pkwy.	3.18
2/6/2020	36	1338 Sandstone Dr.	3.18
2/6/2020	59	3633 Capri Dr.	3.37
2/6/2020	98	15806 Almeria Ave.	3.01
2/6/2020	45	15222 Cruiser St.	3.44
2/7/2020	44	9602 Wilkins Dr.	3.60
2/7/2020	48	1237 Southern Minerals Rd.	3.99
2/7/2020	25	4101 Bascule Dr.	3.60
2/7/2020	33	3913 Ocean Dr.	3.21
2/7/2020	76	1109 Harbor Lights Dr.	3.53
2/7/2020	2	5809 St. Andrews Dr.	3.19
2/7/2020	40	9550 Quetzal St.	3.31
2/7/2020	72	7717 Starnberg Lake Dr.	3.40
2/7/2020	11	534 Military Dr.	2.96
2/7/2020	95	15837 El Socorro Loop	2.90
2/8/2020	16	4205 Wildcat Dr.	3.95
2/8/2020	14	922 Rosedale Dr.	3.00
2/8/2020	99	3926 Elvis Dr.	3.62

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/8/2020	96	14926 Windward Dr.	3.37
2/9/2020	87	5226 Northwest Trl.	3.86
2/9/2020	55	514 Belden St.	3.67
2/9/2020	82	2101 Whispering Oak Dr.	3.16
2/9/2020	95	15837 El Socorro Loop	2.94
2/10/2020	86	14814 Santa Gertrudis Dr.	3.63
2/10/2020	65	726 Westchester Dr.	3.44
2/10/2020	13	1505 6th St.	3.35
2/10/2020	52	221 Junior Beck Dr.	3.81
2/10/2020	29	1601 La Joya St.	3.57
2/10/2020	77	5018 Cape Ann Dr.	3.27
2/10/2020	85	302 Glenmore St.	3.07
2/10/2020	23	5506 Wooldridge Rd.	3.51
2/10/2020	3	3013 S Fork Dr.	3.86
2/10/2020	76	1109 Harbor Lights Dr.	3.27
2/10/2020	4	14233 Playa del Rey	3.17
2/10/2020	40	9550 Quetzal St.	3.39
2/10/2020	83	4101 Summit Dr.	2.74
2/11/2020	87	5226 Northwest Trl.	3.79
2/11/2020	26	225 Eastgate Dr.	3.59
2/11/2020	61	234 Saratoga Blvd.	3.85
2/11/2020	73	5649 King Trl.	3.54
2/11/2020	15	6130 Parkway Dr.	3.51
2/11/2020	70	1633 E. Manor Dr.	3.56
2/11/2020	8	1126 Cornerstone Dr.	3.58
2/11/2020	96	14926 Windward Dr.	3.45
2/12/2020	16	4205 Wildcat Dr.	4.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/12/2020	62	5809 Hampshire Rd.	3.65
2/12/2020	1	4810 Neptune St.	3.70
2/12/2020	91	2713 Wind Rock Dr.	3.68
2/12/2020	18	902 Nueces Bay Blvd.	3.43
2/12/2020	64	4013 Hidalgo St.	3.72
2/12/2020	55	514 Belden St.	3.49
2/12/2020	66	635 Southern St.	3.65
2/12/2020	39	5929 Long Creek Dr.	3.46
2/12/2020	77	5018 Cape Ann Dr.	3.21
2/12/2020	24	2342 Rodd Field Rd.	3.66
2/12/2020	85	302 Glenmore St.	3.13
2/12/2020	69	4013 Donaho Dr.	3.48
2/12/2020	76	1109 Harbor Lights Dr.	3.28
2/12/2020	40	9550 Quetzal St.	3.30
2/12/2020	78	7602 Timber Crest Dr.	3.62
2/12/2020	83	4101 Summit Dr.	2.99
2/12/2020	74	7910 Impala Dr.	3.43
2/12/2020	94	15209 Caravel Dr.	3.00
2/12/2020	98	15806 Almeria Ave.	3.56
2/13/2020	46	8903 McNorton Rd.	3.79
2/13/2020	92	334 Wildwood Dr.	3.79
2/13/2020	57	1409 Arlington Dr.	3.14
2/13/2020	19	1301 Horne Rd.	3.50
2/13/2020	10	3146 Saratoga Blvd.	3.41
2/13/2020	58	4801 French Dr.	3.29
2/13/2020	35	4702 Congressional Dr.	3.55
2/13/2020	34	4341 Harry St.	3.41

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/13/2020	80	7042 Arapahoe St.	3.64
2/13/2020	37	6502 Brockhampton St.	3.26
2/13/2020	38	7525 Annemasse St.	3.51
2/13/2020	43	245 Caribbean Dr.	3.20
2/13/2020	96	14926 Windward Dr.	3.08
2/13/2020	97	13902 Skysail St.	3.46
2/14/2020	88	4214 Western Dr.	4.16
2/14/2020	53	9105 Stock Dr.	3.28
2/14/2020	67	509 S. Carancahua St.	3.50
2/14/2020	5	4609 Evelyn St.	3.28
2/14/2020	81	6630 Meadowheights Dr.	3.43
2/14/2020	76	1109 Harbor Lights Dr.	3.18
2/14/2020	75	2938 Oso Pkwy.	3.27
2/14/2020	40	9550 Quetzal St.	3.03
2/14/2020	41	1605 Amber Dr.	3.30
2/14/2020	11	534 Military Dr.	2.94
2/14/2020	94	15209 Caravel Dr.	3.40
2/15/2020	93	11025 Annville Rd.	3.98
2/15/2020	25	4101 Bascule Dr.	3.32
2/15/2020	38	7525 Annemasse St.	3.36
2/15/2020	98	15806 Almeria Ave.	3.06
2/16/2020	86	14814 Santa Gertrudis Dr.	3.34
2/16/2020	26	225 Eastgate Dr.	3.38
2/16/2020	8	1126 Cornerstone Dr.	3.33
2/16/2020	97	13902 Skysail St.	3.66
2/17/2020	87	5226 Northwest Trl.	3.73
2/17/2020	26	225 Eastgate Dr.	3.48

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/17/2020	57	1409 Arlington Dr.	3.16
2/17/2020	5	4609 Evelyn St.	3.22
2/17/2020	89	3814 Castle Ridge Dr.	3.27
2/17/2020	61	234 Saratoga Blvd.	3.75
2/17/2020	27	2823 S Port Ave.	3.55
2/17/2020	6	1213 10th St.	3.22
2/17/2020	76	1109 Harbor Lights Dr.	2.97
2/17/2020	20	3901 Cott St.	3.51
2/17/2020	40	9550 Quetzal St.	2.87
2/17/2020	22	6713 Weber Rd.	3.46
2/17/2020	77	5018 Cape Ann Dr.	3.03
2/17/2020	85	302 Glenmore St.	2.74
2/17/2020	99	3926 Elvis Dr.	3.21
2/17/2020	84	3640 Flour Bluff Dr.	2.90
2/17/2020	76	1109 Harbor Lights Dr.	2.91
2/17/2020	4	14233 Playa del Rey	3.19
2/17/2020	40	9550 Quetzal St.	2.81
2/17/2020	83	4101 Summit Dr.	2.80
2/18/2020	16	4205 Wildcat Dr.	3.82
2/18/2020	55	514 Belden St.	3.48
2/18/2020	31	4306 Cedar St.	3.15
2/18/2020	60	1346 Calle San Marcos	3.26
2/18/2020	93	11025 Annville Rd.	3.90
2/18/2020	11	534 Military Dr.	2.83
2/18/2020	51	249 Gibson Ln.	3.53
2/18/2020	1	4810 Neptune St.	3.64
2/18/2020	97	13902 Skysail St.	3.39

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/18/2020	12	2219 Buford Ave.	3.74
2/18/2020	54	3710 Seagull Blvd.	3.11
2/19/2020	90	11722 Haven Dr.	3.52
2/19/2020	56	202 Amistad St.	3.19
2/19/2020	30	3100 Brawner Pkwy.	3.05
2/19/2020	59	3633 Capri Dr.	3.18
2/19/2020	90	11722 Haven Dr.	3.43
2/19/2020	7	617 Carmel Pkwy.	3.06
2/19/2020	77	5018 Cape Ann Dr.	2.90
2/19/2020	47	8121 Barrogate Dr.	3.65
2/19/2020	79	905 Egyptian Dr.	2.99
2/19/2020	85	302 Glenmore St.	2.76
2/19/2020	68	5322 Alejandro St.	3.20
2/19/2020	50	5534 IH 37 Access Rd.	3.56
2/19/2020	82	2101 Whispering Oak Dr.	3.01
2/19/2020	76	1109 Harbor Lights Dr.	2.84
2/19/2020	71	5510 Fox Run Dr.	2.98
2/19/2020	14	922 Rosedale Dr.	3.17
2/19/2020	40	9550 Quetzal St.	2.90
2/19/2020	98	15806 Almeria Ave.	2.78
2/19/2020	20	3901 Cott St.	3.47
2/19/2020	83	4101 Summit Dr.	2.82
2/19/2020	36	1338 Sandstone Dr.	3.03
2/19/2020	84	3640 Flour Bluff Dr.	3.19
2/19/2020	45	15222 Cruiser St.	2.97
2/20/2020	91	2713 Wind Rock Dr.	3.70
2/20/2020	49	113 Commerce St.	3.38

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/20/2020	74	7910 Impala Dr.	3.11
2/20/2020	9	1000 International Dr.	3.52
2/20/2020	44	9602 Wilkins Dr.	3.71
2/20/2020	39	5929 Long Creek Dr.	3.32
2/20/2020	28	1718 Bois d' Arc Pl.	3.63
2/20/2020	48	1237 Southern Minerals Rd.	3.84
2/20/2020	2	5809 St. Andrews Dr.	3.11
2/20/2020	32	4901 Hakel Dr.	3.59
2/20/2020	25	4101 Bascule Dr.	3.43
2/20/2020	72	7717 Starnberg Lake Dr.	3.54
2/20/2020	21	913 Lum Ave.	3.09
2/20/2020	42	753 Orleans Dr.	2.86
2/20/2020	78	7602 Timber Crest Dr.	3.17
2/20/2020	95	15837 El Socorro Loop	2.59
2/20/2020	33	3913 Ocean Dr.	3.15
2/20/2020	45	15222 Cruiser St.	3.61
2/21/2020	64	4013 Hidalgo St.	3.57
2/21/2020	9	1000 International Dr.	3.51
2/21/2020	66	635 Southern St.	3.36
2/21/2020	86	14814 Santa Gertrudis Dr.	3.25
2/21/2020	32	4901 Hakel Dr.	3.56
2/21/2020	56	202 Amistad St.	3.16
2/21/2020	73	5649 King Trl.	3.28
2/21/2020	65	726 Westchester Dr.	3.42
2/21/2020	69	4013 Donaho Dr.	3.39
2/21/2020	15	6130 Parkway Dr.	3.34
2/21/2020	21	913 Lum Ave.	3.31

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/21/2020	78	7602 Timber Crest Dr.	3.14
2/21/2020	13	1505 6th St.	3.28
2/21/2020	79	905 Egyptian Dr.	3.16
2/21/2020	36	1338 Sandstone Dr.	3.04
2/21/2020	8	1126 Cornerstone Dr.	3.17
2/21/2020	52	221 Junior Beck Dr.	3.61
2/21/2020	84	3640 Flour Bluff Dr.	3.30
2/21/2020	41	1605 Amber Dr.	3.04
2/21/2020	29	1601 La Joya St.	3.32
2/21/2020	42	753 Orleans Dr.	2.88
2/21/2020	76	1109 Harbor Lights Dr.	2.94
2/21/2020	23	5506 Wooldridge Rd.	3.25
2/21/2020	40	9550 Quetzal St.	2.99
2/21/2020	3	3013 S Fork Dr.	3.19
2/21/2020	11	534 Military Dr.	2.63
2/21/2020	4	14233 Playa del Rey	3.12
2/22/2020	16	4205 Wildcat Dr.	3.94
2/22/2020	48	1237 Southern Minerals Rd.	4.05
2/22/2020	14	922 Rosedale Dr.	3.40
2/22/2020	99	3926 Elvis Dr.	3.25
2/22/2020	45	15222 Cruiser St.	3.03
2/23/2020	87	5226 Northwest Trl.	3.78
2/23/2020	55	514 Belden St.	3.47
2/23/2020	28	1718 Bois d' Arc Pl.	3.64
2/23/2020	32	4901 Hakel Dr.	3.52
2/23/2020	82	2101 Whispering Oak Dr.	3.01
2/23/2020	95	15837 El Socorro Loop	2.33

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/24/2020	87	5226 Northwest Trl.	3.73
2/24/2020	26	225 Eastgate Dr.	3.46
2/24/2020	61	234 Saratoga Blvd.	3.75
2/24/2020	73	5649 King Trl.	3.17
2/24/2020	77	5018 Cape Ann Dr.	2.99
2/24/2020	85	302 Glenmore St.	2.89
2/24/2020	15	6130 Parkway Dr.	3.35
2/24/2020	76	1109 Harbor Lights Dr.	3.04
2/24/2020	40	9550 Quetzal St.	2.87
2/24/2020	70	1633 E. Manor Dr.	3.41
2/24/2020	83	4101 Summit Dr.	2.86
2/24/2020	8	1126 Cornerstone Dr.	3.08
2/24/2020	96	14926 Windward Dr.	3.02
2/25/2020	16	4205 Wildcat Dr.	3.90
2/25/2020	62	5809 Hampshire Rd.	3.76
2/25/2020	1	4810 Neptune St.	3.78
2/25/2020	18	902 Nueces Bay Blvd.	3.58
2/25/2020	55	514 Belden St.	3.50
2/25/2020	39	5929 Long Creek Dr.	3.19
2/25/2020	24	2342 Rodd Field Rd.	3.20
2/25/2020	94	15209 Caravel Dr.	2.98
2/26/2020	44	9602 Wilkins Dr.	3.79
2/26/2020	49	113 Commerce St.	3.66
2/26/2020	9	1000 International Dr.	3.59
2/26/2020	92	334 Wildwood Dr.	3.97
2/26/2020	25	4101 Bascule Dr.	3.46
2/26/2020	91	2713 Wind Rock Dr.	3.75

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/26/2020	19	1301 Horne Rd.	3.55
2/26/2020	33	3913 Ocean Dr.	3.14
2/26/2020	64	4013 Hidalgo St.	3.81
2/26/2020	21	913 Lum Ave.	3.22
2/26/2020	58	4801 French Dr.	3.23
2/26/2020	66	635 Southern St.	3.72
2/26/2020	36	1338 Sandstone Dr.	2.96
2/26/2020	35	4702 Congressional Dr.	3.41
2/26/2020	77	5018 Cape Ann Dr.	3.03
2/26/2020	69	4013 Donaho Dr.	3.60
2/26/2020	80	7042 Arapahoe St.	3.11
2/26/2020	85	302 Glenmore St.	2.92
2/26/2020	78	7602 Timber Crest Dr.	3.28
2/26/2020	38	7525 Annemasse St.	3.26
2/26/2020	76	1109 Harbor Lights Dr.	2.98
2/26/2020	74	7910 Impala Dr.	3.04
2/26/2020	40	9550 Quetzal St.	2.91
2/26/2020	96	14926 Windward Dr.	2.84
2/26/2020	83	4101 Summit Dr.	2.77
2/26/2020	98	15806 Almeria Ave.	2.69
2/27/2020	88	4214 Western Dr.	4.24
2/27/2020	53	9105 Stock Dr.	3.15
2/27/2020	67	509 S. Carancahua St.	3.80
2/27/2020	5	4609 Evelyn St.	3.16
2/27/2020	44	9602 Wilkins Dr.	3.92
2/27/2020	46	8903 McNorton Rd.	3.94
2/27/2020	81	6630 Meadowheights Dr.	3.38

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
2/27/2020	57	1409 Arlington Dr.	3.46
2/27/2020	75	2938 Oso Pkwy.	2.93
2/27/2020	10	3146 Saratoga Blvd.	3.67
2/27/2020	41	1605 Amber Dr.	2.97
2/27/2020	34	4341 Harry St.	3.39
2/27/2020	37	6502 Brockhampton St.	2.86
2/27/2020	94	15209 Caravel Dr.	2.98
2/27/2020	43	245 Caribbean Dr.	3.00
2/27/2020	97	13902 Skysail St.	3.27
2/28/2020	88	4214 Western Dr.	4.11
2/28/2020	29	1601 La Joya St.	3.66
2/28/2020	58	4801 French Dr.	3.50
2/28/2020	4	14233 Playa del Rey	3.19
2/29/2020	93	11025 Annville Rd.	3.99
2/29/2020	25	4101 Bascule Dr.	3.54
2/29/2020	38	7525 Annemasse St.	3.36
2/29/2020	98	15806 Almeria Ave.	2.81

March

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/1/2020	86	14814 Santa Gertrudis Dr.	3.26
3/1/2020	26	225 Eastgate Dr.	3.52
3/1/2020	8	1126 Cornerstone Dr.	3.31
3/1/2020	97	13902 Skysail St.	3.68
3/2/2020	91	2713 Wind Rock Dr.	3.82
3/2/2020	64	4013 Hidalgo St.	3.71

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/2/2020	66	635 Southern St.	3.74
3/2/2020	69	4013 Donaho Dr.	3.24
3/2/2020	77	5018 Cape Ann Dr.	2.95
3/2/2020	78	7602 Timber Crest Dr.	3.09
3/2/2020	74	7910 Impala Dr.	2.98
3/2/2020	85	302 Glenmore St.	2.80
3/2/2020	76	1109 Harbor Lights Dr.	2.87
3/2/2020	98	15806 Almeria Ave.	3.34
3/2/2020	40	9550 Quetzal St.	2.87
3/2/2020	83	4101 Summit Dr.	2.81
3/3/2020	92	334 Wildwood Dr.	4.08
3/3/2020	19	1301 Horne Rd.	3.78
3/3/2020	58	4801 French Dr.	3.88
3/3/2020	35	4702 Congressional Dr.	3.84
3/3/2020	80	7042 Arapahoe St.	3.83
3/3/2020	96	14926 Windward Dr.	2.93
3/3/2020	38	7525 Annemasse St.	3.57
3/3/2020	96	14926 Windward Dr.	3.04
3/3/2020	96	14926 Windward Dr.	3.08
3/4/2020	29	1601 La Joya St.	3.31
3/4/2020	86	14814 Santa Gertrudis Dr.	3.34
3/4/2020	87	5226 Northwest Trl.	3.40
3/4/2020	77	5018 Cape Ann Dr.	3.15
3/4/2020	23	5506 Wooldridge Rd.	3.32
3/4/2020	15	6130 Parkway Dr.	3.42
3/4/2020	85	302 Glenmore St.	3.20
3/4/2020	65	726 Westchester Dr.	3.56

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/4/2020	3	3013 S Fork Dr.	3.34
3/4/2020	26	225 Eastgate Dr.	3.47
3/4/2020	76	1109 Harbor Lights Dr.	3.42
3/4/2020	70	1633 E. Manor Dr.	3.55
3/4/2020	13	1505 6th St.	3.39
3/4/2020	40	9550 Quetzal St.	3.32
3/4/2020	4	14233 Playa del Rey	3.37
3/4/2020	61	234 Saratoga Blvd.	3.60
3/4/2020	8	1126 Cornerstone Dr.	3.34
3/4/2020	83	4101 Summit Dr.	2.60
3/4/2020	52	221 Junior Beck Dr.	3.59
3/4/2020	96	14926 Windward Dr.	2.98
3/4/2020	73	5649 King Trl.	3.62
3/5/2020	58	4801 French Dr.	3.36
3/5/2020	59	3633 Capri Dr.	3.29
3/5/2020	55	514 Belden St.	3.47
3/5/2020	16	4205 Wildcat Dr.	3.97
3/5/2020	95	15837 El Socorro Loop	2.77
3/5/2020	39	5929 Long Creek Dr.	3.29
3/5/2020	98	15806 Almeria Ave.	3.52
3/5/2020	62	5809 Hampshire Rd.	3.57
3/5/2020	24	2342 Rodd Field Rd.	3.34
3/5/2020	1	4810 Neptune St.	3.67
3/5/2020	94	15209 Caravel Dr.	3.34
3/5/2020	18	902 Nueces Bay Blvd.	3.44
3/6/2020	46	8903 McNorton Rd.	3.90
3/6/2020	57	1409 Arlington Dr.	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/6/2020	10	3146 Saratoga Blvd.	3.38
3/6/2020	34	4341 Harry St.	3.37
3/6/2020	37	6502 Brockhampton St.	2.95
3/6/2020	43	245 Caribbean Dr.	2.99
3/6/2020	97	13902 Skysail St.	3.44
3/7/2020	16	4205 Wildcat Dr.	3.83
3/7/2020	14	922 Rosedale Dr.	3.51
3/7/2020	99	3926 Elvis Dr.	3.39
3/7/2020	96	14926 Windward Dr.	3.33
3/8/2020	87	5226 Northwest Trl.	3.57
3/8/2020	55	514 Belden St.	3.52
3/8/2020	82	2101 Whispering Oak Dr.	3.29
3/8/2020	95	15837 El Socorro Loop	2.78
3/9/2020	88	4214 Western Dr.	3.99
3/9/2020	53	9105 Stock Dr.	3.32
3/9/2020	67	509 S. Carancahua St.	3.62
3/9/2020	77	5018 Cape Ann Dr.	3.26
3/9/2020	5	4609 Evelyn St.	3.39
3/9/2020	85	302 Glenmore St.	3.18
3/9/2020	76	1109 Harbor Lights Dr.	3.53
3/9/2020	81	6630 Meadowheights Dr.	3.48
3/9/2020	40	9550 Quetzal St.	3.13
3/9/2020	75	2938 Oso Pkwy.	3.65
3/9/2020	83	4101 Summit Dr.	2.82
3/9/2020	41	1605 Amber Dr.	3.31
3/9/2020	94	15209 Caravel Dr.	3.09
3/10/2020	89	3814 Castle Ridge Dr.	3.34

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/10/2020	27	2823 S Port Ave.	3.55
3/10/2020	6	1213 10th St.	3.16
3/10/2020	20	3901 Cott St.	3.48
3/10/2020	22	6713 Weber Rd.	3.29
3/10/2020	99	3926 Elvis Dr.	3.35
3/10/2020	84	3640 Flour Bluff Dr.	3.28
3/10/2020	4	14233 Playa del Rey	3.29
3/11/2020	90	11722 Haven Dr.	3.30
3/11/2020	56	202 Amistad St.	3.06
3/11/2020	91	2713 Wind Rock Dr.	3.39
3/11/2020	30	3100 Brawner Pkwy.	3.04
3/11/2020	49	113 Commerce St.	3.45
3/11/2020	59	3633 Capri Dr.	3.14
3/11/2020	7	617 Carmel Pkwy.	3.20
3/11/2020	9	1000 International Dr.	3.39
3/11/2020	28	1718 Bois d' Arc Pl.	3.49
3/11/2020	79	905 Egyptian Dr.	3.01
3/11/2020	77	5018 Cape Ann Dr.	2.98
3/11/2020	32	4901 Hakel Dr.	3.51
3/11/2020	82	2101 Whispering Oak Dr.	2.95
3/11/2020	85	302 Glenmore St.	2.95
3/11/2020	21	913 Lum Ave.	3.18
3/11/2020	76	1109 Harbor Lights Dr.	2.96
3/11/2020	98	15806 Almeria Ave.	3.27
3/11/2020	42	753 Orleans Dr.	2.96
3/11/2020	40	9550 Quetzal St.	2.87
3/11/2020	45	15222 Cruiser St.	3.37

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/11/2020	83	4101 Summit Dr.	2.95
3/12/2020	90	11722 Haven Dr.	3.23
3/12/2020	47	8121 Barrogate Dr.	3.55
3/12/2020	93	11025 Annville Rd.	3.77
3/12/2020	50	5534 IH 37 Access Rd.	3.58
3/12/2020	51	249 Gibson Ln.	3.30
3/12/2020	12	2219 Buford Ave.	3.33
3/12/2020	14	922 Rosedale Dr.	3.08
3/12/2020	54	3710 Seagull Blvd.	2.91
3/12/2020	31	4306 Cedar St.	2.86
3/12/2020	68	5322 Alejandro St.	2.89
3/12/2020	60	1346 Calle San Marcos	2.79
3/12/2020	71	5510 Fox Run Dr.	2.84
3/12/2020	11	534 Military Dr.	2.68
3/12/2020	97	13902 Skysail St.	3.34
3/12/2020	36	1338 Sandstone Dr.	2.96
3/12/2020	45	15222 Cruiser St.	3.00
3/13/2020	44	9602 Wilkins Dr.	3.65
3/13/2020	48	1237 Southern Minerals Rd.	3.58
3/13/2020	25	4101 Bascule Dr.	3.21
3/13/2020	55	514 Belden St.	3.21
3/13/2020	33	3913 Ocean Dr.	2.92
3/13/2020	2	5809 St. Andrews Dr.	2.74
3/13/2020	72	7717 Starnberg Lake Dr.	3.03
3/13/2020	95	15837 El Socorro Loop	2.85
3/14/2020	93	11025 Annville Rd.	3.74
3/14/2020	25	4101 Bascule Dr.	3.38

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/14/2020	38	7525 Annemasse St.	2.96
3/14/2020	98	15806 Almeria Ave.	2.64
3/15/2020	86	14814 Santa Gertrudis Dr.	3.06
3/15/2020	26	225 Eastgate Dr.	3.21
3/15/2020	8	1126 Cornerstone Dr.	3.01
3/15/2020	97	13902 Skysail St.	3.12
3/16/2020	69	4013 Donaho Dr.	3.14
3/16/2020	78	7602 Timber Crest Dr.	2.84
3/16/2020	77	5018 Cape Ann Dr.	2.86
3/16/2020	74	7910 Impala Dr.	2.77
3/16/2020	85	302 Glenmore St.	2.75
3/16/2020	76	1109 Harbor Lights Dr.	2.79
3/16/2020	40	9550 Quetzal St.	2.68
3/16/2020	98	15806 Almeria Ave.	2.78
3/16/2020	91	2713 Wind Rock Dr.	3.60
3/16/2020	83	4101 Summit Dr.	2.49
3/16/2020	64	4013 Hidalgo St.	3.65
3/16/2020	66	635 Southern St.	3.34
3/17/2020	35	4702 Congressional Dr.	2.98
3/17/2020	80	7042 Arapahoe St.	3.07
3/17/2020	92	334 Wildwood Dr.	3.51
3/17/2020	38	7525 Annemasse St.	3.07
3/17/2020	96	14926 Windward Dr.	3.09
3/17/2020	19	1301 Horne Rd.	3.41
3/17/2020	58	4801 French Dr.	3.02
3/18/2020	86	14814 Santa Gertrudis Dr.	3.02
3/18/2020	65	726 Westchester Dr.	3.05

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/18/2020	13	1505 6th St.	3.13
3/18/2020	77	5018 Cape Ann Dr.	2.79
3/18/2020	85	302 Glenmore St.	2.69
3/18/2020	52	221 Junior Beck Dr.	3.22
3/18/2020	76	1109 Harbor Lights Dr.	2.71
3/18/2020	46	8903 McNorton Rd.	3.24
3/18/2020	29	1601 La Joya St.	3.15
3/18/2020	40	9550 Quetzal St.	2.74
3/18/2020	57	1409 Arlington Dr.	3.02
3/18/2020	83	4101 Summit Dr.	2.52
3/18/2020	23	5506 Wooldridge Rd.	2.95
3/18/2020	37	6502 Brockhampton St.	2.83
3/18/2020	10	3146 Saratoga Blvd.	2.81
3/18/2020	3	3013 S Fork Dr.	3.25
3/18/2020	43	245 Caribbean Dr.	2.81
3/18/2020	34	4341 Harry St.	2.95
3/18/2020	97	13902 Skysail St.	3.30
3/18/2020	4	14233 Playa del Rey	3.14
3/19/2020	88	4214 Western Dr.	3.45
3/19/2020	87	5226 Northwest Trl.	3.25
3/19/2020	81	6630 Meadowheights Dr.	2.88
3/19/2020	53	9105 Stock Dr.	2.86
3/19/2020	26	225 Eastgate Dr.	3.02
3/19/2020	75	2938 Oso Pkwy.	2.73
3/19/2020	67	509 S. Carancahua St.	2.92
3/19/2020	41	1605 Amber Dr.	2.71
3/19/2020	61	234 Saratoga Blvd.	3.24

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/19/2020	5	4609 Evelyn St.	2.87
3/19/2020	94	15209 Caravel Dr.	2.80
3/19/2020	15	6130 Parkway Dr.	3.02
3/19/2020	3	3013 S Fork Dr.	3.07
3/20/2020	87	5226 Northwest Trl.	3.39
3/20/2020	26	225 Eastgate Dr.	2.95
3/20/2020	61	234 Saratoga Blvd.	3.24
3/20/2020	73	5649 King Trl.	3.15
3/20/2020	15	6130 Parkway Dr.	2.76
3/20/2020	70	1633 E. Manor Dr.	2.81
3/20/2020	8	1126 Cornerstone Dr.	2.79
3/20/2020	96	14926 Windward Dr.	2.78
3/21/2020	14	922 Rosedale Dr.	2.77
3/21/2020	99	3926 Elvis Dr.	2.98
3/21/2020	96	14926 Windward Dr.	2.73
3/21/2020	16	4205 Wildcat Dr.	3.53
3/22/2020	82	2101 Whispering Oak Dr.	2.77
3/22/2020	95	15837 El Socorro Loop	2.36
3/22/2020	55	514 Belden St.	2.97
3/22/2020	87	5226 Northwest Trl.	3.44
3/23/2020	16	4205 Wildcat Dr.	3.70
3/23/2020	62	5809 Hampshire Rd.	3.45
3/23/2020	1	4810 Neptune St.	3.71
3/23/2020	18	902 Nueces Bay Blvd.	3.13
3/23/2020	55	514 Belden St.	3.11
3/23/2020	39	5929 Long Creek Dr.	2.52
3/23/2020	77	5018 Cape Ann Dr.	2.64

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/23/2020	24	2342 Rodd Field Rd.	3.04
3/23/2020	85	302 Glenmore St.	2.50
3/23/2020	94	15209 Caravel Dr.	2.65
3/23/2020	76	1109 Harbor Lights Dr.	2.57
3/23/2020	40	9550 Quetzal St.	2.76
3/23/2020	83	4101 Summit Dr.	2.25
3/24/2020	89	3814 Castle Ridge Dr.	3.19
3/24/2020	27	2823 S Port Ave.	3.50
3/24/2020	6	1213 10th St.	2.98
3/24/2020	20	3901 Cott St.	3.37
3/24/2020	22	6713 Weber Rd.	3.53
3/24/2020	99	3926 Elvis Dr.	3.18
3/24/2020	84	3640 Flour Bluff Dr.	2.90
3/24/2020	4	14233 Playa del Rey	2.67
3/25/2020	90	11722 Haven Dr.	3.50
3/25/2020	91	2713 Wind Rock Dr.	3.40
3/25/2020	13	1505 6th St.	2.97
3/25/2020	49	113 Commerce St.	3.44
3/25/2020	56	202 Amistad St.	2.99
3/25/2020	9	1000 International Dr.	3.54
3/25/2020	30	3100 Brawner Pkwy.	2.76
3/25/2020	28	1718 Bois d' Arc Pl.	3.44
3/25/2020	59	3633 Capri Dr.	3.09
3/25/2020	32	4901 Hakel Dr.	3.50
3/25/2020	7	617 Carmel Pkwy.	3.10
3/25/2020	21	913 Lum Ave.	2.97
3/25/2020	77	5018 Cape Ann Dr.	2.78

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/25/2020	79	905 Egyptian Dr.	2.92
3/25/2020	85	302 Glenmore St.	2.75
3/25/2020	42	753 Orleans Dr.	2.72
3/25/2020	76	1109 Harbor Lights Dr.	2.90
3/25/2020	82	2101 Whispering Oak Dr.	2.83
3/25/2020	40	9550 Quetzal St.	2.85
3/25/2020	45	15222 Cruiser St.	3.08
3/25/2020	98	15806 Almeria Ave.	2.69
3/25/2020	83	4101 Summit Dr.	2.34
3/26/2020	93	11025 Annville Rd.	3.90
3/26/2020	51	249 Gibson Ln.	3.47
3/26/2020	12	2219 Buford Ave.	3.37
3/26/2020	54	3710 Seagull Blvd.	2.59
3/26/2020	31	4306 Cedar St.	2.99
3/26/2020	60	1346 Calle San Marcos	2.97
3/26/2020	11	534 Military Dr.	2.50
3/26/2020	97	13902 Skysail St.	3.21
3/27/2020	13	1505 6th St.	2.91
3/27/2020	13	1505 6th St.	3.10
3/27/2020	90	11722 Haven Dr.	3.26
3/27/2020	47	8121 Barrogate Dr.	3.50
3/27/2020	50	5534 IH 37 Access Rd.	3.45
3/27/2020	14	922 Rosedale Dr.	2.94
3/27/2020	68	5322 Alejandro St.	2.92
3/27/2020	71	5510 Fox Run Dr.	2.93
3/27/2020	36	1338 Sandstone Dr.	2.77
3/27/2020	45	15222 Cruiser St.	3.24

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
3/28/2020	93	11025 Annville Rd.	3.93
3/28/2020	25	4101 Bascule Dr.	3.14
3/28/2020	38	7525 Annemasse St.	2.80
3/28/2020	98	15806 Almeria Ave.	2.86
3/29/2020	86	14814 Santa Gertrudis Dr.	3.52
3/29/2020	26	225 Eastgate Dr.	3.39
3/29/2020	8	1126 Cornerstone Dr.	2.90
3/29/2020	97	13902 Skysail St.	3.18
3/30/2020	44	9602 Wilkins Dr.	4.14
3/30/2020	48	1237 Southern Minerals Rd.	4.13
3/30/2020	25	4101 Bascule Dr.	3.59
3/30/2020	33	3913 Ocean Dr.	3.22
3/30/2020	77	5018 Cape Ann Dr.	2.95
3/30/2020	2	5809 St. Andrews Dr.	3.24
3/30/2020	85	302 Glenmore St.	2.88
3/30/2020	72	7717 Starnberg Lake Dr.	3.71
3/30/2020	76	1109 Harbor Lights Dr.	2.94
3/30/2020	40	9550 Quetzal St.	2.77
3/30/2020	95	15837 El Socorro Loop	2.35
3/30/2020	83	4101 Summit Dr.	2.32
3/31/2020	88	4214 Western Dr.	4.11
3/31/2020	29	1601 La Joya St.	3.75
3/31/2020	58	4801 French Dr.	3.40
3/31/2020	4	14233 Playa del Rey	3.29

April

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/1/2020	90	11722 Haven Dr.	3.54
4/1/2020	47	8121 Barrogate Dr.	3.83
4/1/2020	44	9602 Wilkins Dr.	3.96
4/1/2020	50	5534 IH 37 Access Rd.	3.53
4/1/2020	48	1237 Southern Minerals Rd.	3.94
4/1/2020	14	922 Rosedale Dr.	3.24
4/1/2020	25	4101 Bascule Dr.	3.55
4/1/2020	68	5322 Alejandro St.	3.49
4/1/2020	77	5018 Cape Ann Dr.	3.19
4/1/2020	33	3913 Ocean Dr.	3.38
4/1/2020	71	5510 Fox Run Dr.	3.32
4/1/2020	85	302 Glenmore St.	3.09
4/1/2020	76	1109 Harbor Lights Dr.	3.26
4/1/2020	2	5809 St. Andrews Dr.	3.23
4/1/2020	36	1338 Sandstone Dr.	3.26
4/1/2020	40	9550 Quetzal St.	3.10
4/1/2020	72	7717 Starnberg Lake Dr.	3.59
4/1/2020	45	15222 Cruiser St.	3.20
4/1/2020	83	4101 Summit Dr.	2.68
4/1/2020	95	15837 El Socorro Loop	2.41
4/2/2020	86	14814 Santa Gertrudis Dr.	3.64
4/2/2020	65	726 Westchester Dr.	3.66
4/2/2020	13	1505 6th St.	3.76
4/2/2020	52	221 Junior Beck Dr.	3.71

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/2/2020	29	1601 La Joya St.	3.59
4/2/2020	59	3633 Capri Dr.	3.34
4/2/2020	23	5506 Wooldridge Rd.	3.47
4/2/2020	58	4801 French Dr.	3.39
4/2/2020	3	3013 S Fork Dr.	3.59
4/2/2020	98	15806 Almeria Ave.	2.65
4/2/2020	95	15837 El Socorro Loop	2.49
4/2/2020	4	14233 Playa del Rey	3.27
4/3/2020	87	5226 Northwest Trl.	3.71
4/3/2020	26	225 Eastgate Dr.	3.52
4/3/2020	61	234 Saratoga Blvd.	3.83
4/3/2020	73	5649 King Trl.	3.40
4/3/2020	15	6130 Parkway Dr.	3.47
4/3/2020	70	1633 E. Manor Dr.	3.45
4/3/2020	8	1126 Cornerstone Dr.	3.38
4/3/2020	96	14926 Windward Dr.	3.13
4/4/2020	16	4205 Wildcat Dr.	3.71
4/4/2020	14	922 Rosedale Dr.	3.24
4/4/2020	99	3926 Elvis Dr.	3.49
4/4/2020	96	14926 Windward Dr.	3.31
4/5/2020	87	5226 Northwest Trl.	3.60
4/5/2020	55	514 Belden St.	3.24
4/5/2020	82	2101 Whispering Oak Dr.	2.96
4/5/2020	95	15837 El Socorro Loop	2.62
4/6/2020	77	5018 Cape Ann Dr.	3.00
4/6/2020	85	302 Glenmore St.	2.88
4/6/2020	76	1109 Harbor Lights Dr.	2.95

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/6/2020	89	3814 Castle Ridge Dr.	3.35
4/6/2020	40	9550 Quetzal St.	2.90
4/6/2020	27	2823 S Port Ave.	3.62
4/6/2020	22	6713 Weber Rd.	3.58
4/6/2020	83	4101 Summit Dr.	2.69
4/6/2020	6	1213 10th St.	3.16
4/6/2020	20	3901 Cott St.	3.36
4/6/2020	99	3926 Elvis Dr.	3.45
4/6/2020	84	3640 Flour Bluff Dr.	3.20
4/6/2020	4	14233 Playa del Rey	3.18
4/7/2020	45	15222 Cruiser St.	2.74
4/7/2020	42	753 Orleans Dr.	3.11
4/7/2020	91	2713 Wind Rock Dr.	3.62
4/7/2020	49	113 Commerce St.	3.36
4/7/2020	21	913 Lum Ave.	3.22
4/7/2020	9	1000 International Dr.	3.43
4/7/2020	32	4901 Hakel Dr.	3.51
4/7/2020	28	1718 Bois d' Arc Pl.	3.67
4/8/2020	16	4205 Wildcat Dr.	3.84
4/8/2020	62	5809 Hampshire Rd.	3.78
4/8/2020	1	4810 Neptune St.	3.73
4/8/2020	18	902 Nueces Bay Blvd.	3.54
4/8/2020	77	5018 Cape Ann Dr.	2.96
4/8/2020	55	514 Belden St.	3.55
4/8/2020	7	617 Carmel Pkwy.	3.32
4/8/2020	85	302 Glenmore St.	2.85
4/8/2020	90	11722 Haven Dr.	3.77

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/8/2020	79	905 Egyptian Dr.	3.04
4/8/2020	39	5929 Long Creek Dr.	3.51
4/8/2020	76	1109 Harbor Lights Dr.	3.01
4/8/2020	40	9550 Quetzal St.	2.87
4/8/2020	82	2101 Whispering Oak Dr.	3.01
4/8/2020	24	2342 Rodd Field Rd.	3.68
4/8/2020	56	202 Amistad St.	3.30
4/8/2020	83	4101 Summit Dr.	2.67
4/8/2020	98	15806 Almeria Ave.	2.81
4/8/2020	94	15209 Caravel Dr.	3.00
4/8/2020	30	3100 Brawner Pkwy.	3.05
4/8/2020	59	3633 Capri Dr.	3.65
4/9/2020	98	15806 Almeria Ave.	2.75
4/9/2020	74	7910 Impala Dr.	3.32
4/9/2020	93	11025 Annville Rd.	4.04
4/9/2020	31	4306 Cedar St.	3.13
4/9/2020	78	7602 Timber Crest Dr.	3.34
4/9/2020	51	249 Gibson Ln.	3.71
4/9/2020	69	4013 Donaho Dr.	3.68
4/9/2020	60	1346 Calle San Marcos	3.09
4/9/2020	12	2219 Buford Ave.	3.71
4/9/2020	66	635 Southern St.	3.77
4/9/2020	54	3710 Seagull Blvd.	3.29
4/9/2020	11	534 Military Dr.	2.70
4/9/2020	64	4013 Hidalgo St.	3.74
4/9/2020	97	13902 Skysail St.	3.19
4/9/2020	91	2713 Wind Rock Dr.	3.87

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/10/2020	92	334 Wildwood Dr.	3.97
4/10/2020	19	1301 Horne Rd.	3.44
4/10/2020	58	4801 French Dr.	3.15
4/10/2020	35	4702 Congressional Dr.	3.51
4/10/2020	80	7042 Arapahoe St.	3.46
4/10/2020	38	7525 Annemasse St.	3.52
4/10/2020	96	14926 Windward Dr.	3.24
4/11/2020	93	11025 Annville Rd.	3.99
4/11/2020	38	7525 Annemasse St.	3.41
4/11/2020	25	4101 Bascule Dr.	3.47
4/11/2020	98	15806 Almeria Ave.	2.88
4/12/2020	86	14814 Santa Gertrudis Dr.	3.29
4/12/2020	26	225 Eastgate Dr.	3.46
4/12/2020	8	1126 Cornerstone Dr.	3.40
4/12/2020	97	13902 Skysail St.	3.30
4/13/2020	46	8903 McNorton Rd.	3.64
4/13/2020	57	1409 Arlington Dr.	3.35
4/13/2020	10	3146 Saratoga Blvd.	3.29
4/13/2020	77	5018 Cape Ann Dr.	3.02
4/13/2020	34	4341 Harry St.	3.28
4/13/2020	85	302 Glenmore St.	2.95
4/13/2020	76	1109 Harbor Lights Dr.	3.04
4/13/2020	37	6502 Brockhampton St.	3.09
4/13/2020	40	9550 Quetzal St.	2.99
4/13/2020	83	4101 Summit Dr.	2.88
4/13/2020	43	245 Caribbean Dr.	3.20
4/13/2020	97	13902 Skysail St.	3.50

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/14/2020	88	4214 Western Dr.	4.17
4/14/2020	53	9105 Stock Dr.	3.17
4/14/2020	67	509 S. Carancahua St.	3.54
4/14/2020	5	4609 Evelyn St.	3.29
4/14/2020	99	3926 Elvis Dr.	3.30
4/14/2020	81	6630 Meadowheights Dr.	3.28
4/14/2020	84	3640 Flour Bluff Dr.	3.20
4/14/2020	75	2938 Oso Pkwy.	3.15
4/14/2020	41	1605 Amber Dr.	3.05
4/14/2020	94	15209 Caravel Dr.	3.17
4/15/2020	29	1601 La Joya St.	3.42
4/15/2020	86	14814 Santa Gertrudis Dr.	3.54
4/15/2020	87	5226 Northwest Trl.	3.82
4/15/2020	65	726 Westchester Dr.	3.33
4/15/2020	26	225 Eastgate Dr.	3.41
4/15/2020	13	1505 6th St.	3.59
4/15/2020	61	234 Saratoga Blvd.	3.69
4/15/2020	52	221 Junior Beck Dr.	3.71
4/15/2020	73	5649 King Trl.	3.41
4/15/2020	77	5018 Cape Ann Dr.	3.03
4/15/2020	15	6130 Parkway Dr.	3.33
4/15/2020	85	302 Glenmore St.	3.00
4/15/2020	70	1633 E. Manor Dr.	3.40
4/15/2020	23	5506 Wooldridge Rd.	3.30
4/15/2020	76	1109 Harbor Lights Dr.	3.11
4/15/2020	8	1126 Cornerstone Dr.	3.31
4/15/2020	40	9550 Quetzal St.	3.00

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/15/2020	3	3013 S Fork Dr.	3.22
4/15/2020	83	4101 Summit Dr.	2.81
4/15/2020	4	14233 Playa del Rey	3.13
4/15/2020	96	14926 Windward Dr.	2.76
4/16/2020	16	4205 Wildcat Dr.	3.74
4/16/2020	91	2713 Wind Rock Dr.	3.78
4/16/2020	62	5809 Hampshire Rd.	3.79
4/16/2020	1	4810 Neptune St.	3.99
4/16/2020	64	4013 Hidalgo St.	3.76
4/16/2020	66	635 Southern St.	3.56
4/16/2020	18	902 Nueces Bay Blvd.	3.59
4/16/2020	69	4013 Donaho Dr.	3.68
4/16/2020	55	514 Belden St.	3.54
4/16/2020	78	7602 Timber Crest Dr.	3.43
4/16/2020	74	7910 Impala Dr.	3.33
4/16/2020	39	5929 Long Creek Dr.	3.32
4/16/2020	24	2342 Rodd Field Rd.	3.51
4/16/2020	98	15806 Almeria Ave.	2.99
4/16/2020	94	15209 Caravel Dr.	2.93
4/17/2020	92	334 Wildwood Dr.	3.98
4/17/2020	19	1301 Horne Rd.	3.61
4/17/2020	58	4801 French Dr.	3.48
4/17/2020	35	4702 Congressional Dr.	3.55
4/17/2020	80	7042 Arapahoe St.	3.45
4/17/2020	38	7525 Annemasse St.	3.64
4/17/2020	96	14926 Windward Dr.	3.23
4/18/2020	16	4205 Wildcat Dr.	3.90

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/18/2020	14	922 Rosedale Dr.	3.13
4/18/2020	99	3926 Elvis Dr.	3.49
4/18/2020	96	14926 Windward Dr.	3.26
4/19/2020	87	5226 Northwest Trl.	3.45
4/19/2020	55	514 Belden St.	3.41
4/19/2020	82	2101 Whispering Oak Dr.	3.13
4/19/2020	95	15837 El Socorro Loop	2.77
4/20/2020	89	3814 Castle Ridge Dr.	3.27
4/20/2020	27	2823 S Port Ave.	3.27
4/20/2020	6	1213 10th St.	3.01
4/20/2020	20	3901 Cott St.	3.22
4/20/2020	22	6713 Weber Rd.	3.41
4/20/2020	77	5018 Cape Ann Dr.	3.11
4/20/2020	85	302 Glenmore St.	2.99
4/20/2020	99	3926 Elvis Dr.	3.37
4/20/2020	76	1109 Harbor Lights Dr.	2.99
4/20/2020	84	3640 Flour Bluff Dr.	3.12
4/20/2020	4	14233 Playa del Rey	3.32
4/20/2020	40	9550 Quetzal St.	2.99
4/20/2020	83	4101 Summit Dr.	2.87
4/21/2020	90	11722 Haven Dr.	3.68
4/21/2020	68	5322 Alejandro St.	3.25
4/21/2020	47	8121 Barrogate Dr.	3.74
4/21/2020	50	5534 IH 37 Access Rd.	3.95
4/21/2020	36	1338 Sandstone Dr.	3.02
4/21/2020	14	922 Rosedale Dr.	3.46
4/21/2020	84	3640 Flour Bluff Dr.	3.18

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/21/2020	45	15222 Cruiser St.	3.73
4/22/2020	44	9602 Wilkins Dr.	3.46
4/22/2020	48	1237 Southern Minerals Rd.	3.79
4/22/2020	25	4101 Bascule Dr.	3.48
4/22/2020	77	5018 Cape Ann Dr.	3.24
4/22/2020	33	3913 Ocean Dr.	3.30
4/22/2020	2	5809 St. Andrews Dr.	3.31
4/22/2020	85	302 Glenmore St.	3.04
4/22/2020	72	7717 Starnberg Lake Dr.	3.58
4/22/2020	76	1109 Harbor Lights Dr.	3.14
4/22/2020	40	9550 Quetzal St.	3.02
4/22/2020	95	15837 El Socorro Loop	2.80
4/22/2020	83	4101 Summit Dr.	3.06
4/23/2020	91	2713 Wind Rock Dr.	3.49
4/23/2020	49	113 Commerce St.	3.50
4/23/2020	9	1000 International Dr.	3.41
4/23/2020	28	1718 Bois d' Arc Pl.	3.48
4/23/2020	32	4901 Hakel Dr.	3.53
4/23/2020	21	913 Lum Ave.	3.30
4/23/2020	42	753 Orleans Dr.	3.29
4/23/2020	45	15222 Cruiser St.	3.76
4/24/2020	98	15806 Almeria Ave.	3.50
4/24/2020	82	2101 Whispering Oak Dr.	3.30
4/24/2020	79	905 Egyptian Dr.	3.10
4/24/2020	7	617 Carmel Pkwy.	3.12
4/24/2020	59	3633 Capri Dr.	3.13
4/24/2020	30	3100 Brawner Pkwy.	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/24/2020	56	202 Amistad St.	3.14
4/24/2020	90	11722 Haven Dr.	3.45
4/25/2020	93	11025 Annville Rd.	4.03
4/25/2020	25	4101 Bascule Dr.	3.28
4/25/2020	71	5510 Fox Run Dr.	3.09
4/25/2020	38	7525 Annemasse St.	3.19
4/25/2020	98	15806 Almeria Ave.	3.02
4/26/2020	86	14814 Santa Gertrudis Dr.	3.37
4/26/2020	26	225 Eastgate Dr.	3.34
4/26/2020	8	1126 Cornerstone Dr.	3.18
4/26/2020	97	13902 Skysail St.	3.11
4/27/2020	46	8903 McNorton Rd.	3.95
4/27/2020	57	1409 Arlington Dr.	3.11
4/27/2020	10	3146 Saratoga Blvd.	3.36
4/27/2020	34	4341 Harry St.	3.31
4/27/2020	37	6502 Brockhampton St.	3.18
4/27/2020	43	245 Caribbean Dr.	2.97
4/27/2020	77	5018 Cape Ann Dr.	2.94
4/27/2020	85	302 Glenmore St.	2.89
4/27/2020	97	13902 Skysail St.	3.12
4/27/2020	76	1109 Harbor Lights Dr.	2.95
4/27/2020	40	9550 Quetzal St.	2.88
4/27/2020	83	4101 Summit Dr.	2.65
4/28/2020	88	4214 Western Dr.	4.02
4/28/2020	53	9105 Stock Dr.	3.45
4/28/2020	67	509 S. Carancahua St.	3.49
4/28/2020	5	4609 Evelyn St.	3.22

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/28/2020	81	6630 Meadowheights Dr.	3.55
4/28/2020	75	2938 Oso Pkwy.	3.33
4/28/2020	41	1605 Amber Dr.	3.30
4/28/2020	94	15209 Caravel Dr.	2.97
4/29/2020	93	11025 Annaville Rd.	3.83
4/29/2020	51	249 Gibson Ln.	3.37
4/29/2020	12	2219 Buford Ave.	3.32
4/29/2020	54	3710 Seagull Blvd.	3.01
4/29/2020	31	4306 Cedar St.	3.17
4/29/2020	60	1346 Calle San Marcos	3.17
4/29/2020	77	5018 Cape Ann Dr.	3.07
4/29/2020	11	534 Military Dr.	2.70
4/29/2020	85	302 Glenmore St.	2.98
4/29/2020	11	534 Military Dr.	2.74
4/29/2020	76	1109 Harbor Lights Dr.	3.09
4/29/2020	40	9550 Quetzal St.	3.02
4/29/2020	97	13902 Skysail St.	3.55
4/29/2020	83	4101 Summit Dr.	2.72
4/30/2020	88	4214 Western Dr.	3.99
4/30/2020	29	1601 La Joya St.	3.26
4/30/2020	58	4801 French Dr.	3.14
4/30/2020	4	14233 Playa del Rey	3.36

May

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/1/2020	96	14926 Windward Dr.	2.96

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/1/2020	38	7525 Annemasse St.	3.52
5/1/2020	80	7042 Arapahoe St.	3.47
5/1/2020	35	4702 Congressional Dr.	3.44
5/1/2020	58	4801 French Dr.	3.21
5/1/2020	19	1301 Horne Rd.	3.75
5/1/2020	92	334 Wildwood Dr.	4.31
5/2/2020	16	4205 Wildcat Dr.	3.64
5/2/2020	14	922 Rosedale Dr.	3.17
5/2/2020	99	3926 Elvis Dr.	3.30
5/2/2020	96	14926 Windward Dr.	2.81
5/3/2020	87	5226 Northwest Trl.	3.60
5/3/2020	55	514 Belden St.	3.24
5/3/2020	82	2101 Whispering Oak Dr.	2.99
5/3/2020	95	15837 El Socorro Loop	2.46
5/4/2020	46	8903 McNorton Rd.	3.81
5/4/2020	57	1409 Arlington Dr.	3.17
5/4/2020	10	3146 Saratoga Blvd.	3.29
5/4/2020	77	5018 Cape Ann Dr.	2.76
5/4/2020	34	4341 Harry St.	3.04
5/4/2020	85	302 Glenmore St.	2.62
5/4/2020	76	1109 Harbor Lights Dr.	2.77
5/4/2020	37	6502 Brockhampton St.	3.23
5/4/2020	40	9550 Quetzal St.	2.68
5/4/2020	83	4101 Summit Dr.	2.57
5/4/2020	43	245 Caribbean Dr.	2.93
5/4/2020	97	13902 Skysail St.	3.00
5/5/2020	76	1109 Harbor Lights Dr.	2.89

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/5/2020	88	4214 Western Dr.	3.91
5/5/2020	53	9105 Stock Dr.	3.19
5/5/2020	67	509 S. Carancahua St.	3.54
5/5/2020	5	4609 Evelyn St.	3.21
5/5/2020	81	6630 Meadowheights Dr.	3.36
5/5/2020	75	2938 Oso Pkwy.	3.50
5/5/2020	41	1605 Amber Dr.	3.43
5/5/2020	94	15209 Caravel Dr.	3.13
5/6/2020	91	2713 Wind Rock Dr.	3.47
5/6/2020	49	113 Commerce St.	3.37
5/6/2020	89	3814 Castle Ridge Dr.	3.33
5/6/2020	77	5018 Cape Ann Dr.	2.88
5/6/2020	9	1000 International Dr.	3.15
5/6/2020	27	2823 S Port Ave.	3.57
5/6/2020	85	302 Glenmore St.	2.83
5/6/2020	28	1718 Bois d' Arc Pl.	3.48
5/6/2020	6	1213 10th St.	3.36
5/6/2020	76	1109 Harbor Lights Dr.	2.97
5/6/2020	20	3901 Cott St.	3.23
5/6/2020	32	4901 Hakel Dr.	3.31
5/6/2020	59	3633 Capri Dr.	3.13
5/6/2020	22	6713 Weber Rd.	3.40
5/6/2020	21	913 Lum Ave.	3.05
5/6/2020	58	4801 French Dr.	3.11
5/6/2020	99	3926 Elvis Dr.	3.50
5/6/2020	42	753 Orleans Dr.	3.29
5/6/2020	95	15837 El Socorro Loop	2.71

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/6/2020	84	3640 Flour Bluff Dr.	3.20
5/6/2020	98	15806 Almeria Ave.	3.33
5/6/2020	40	9550 Quetzal St.	2.92
5/6/2020	45	15222 Cruiser St.	3.67
5/6/2020	4	14233 Playa del Rey	3.56
5/6/2020	83	4101 Summit Dr.	2.85
5/7/2020	90	11722 Haven Dr.	3.25
5/7/2020	56	202 Amistad St.	2.92
5/7/2020	30	3100 Brawner Pkwy.	2.77
5/7/2020	59	3633 Capri Dr.	2.93
5/7/2020	7	617 Carmel Pkwy.	2.95
5/7/2020	79	905 Egyptian Dr.	2.69
5/7/2020	82	2101 Whispering Oak Dr.	2.95
5/7/2020	98	15806 Almeria Ave.	3.14
5/8/2020	93	11025 Annville Rd.	3.89
5/8/2020	54	3710 Seagull Blvd.	3.15
5/8/2020	12	2219 Buford Ave.	3.54
5/8/2020	51	249 Gibson Ln.	3.47
5/8/2020	31	4306 Cedar St.	2.88
5/8/2020	60	1346 Calle San Marcos	3.04
5/8/2020	11	534 Military Dr.	2.60
5/8/2020	97	13902 Skysail St.	3.33
5/9/2020	98	15806 Almeria Ave.	2.84
5/9/2020	38	7525 Annemasse St.	3.26
5/9/2020	25	4101 Bascule Dr.	3.32
5/9/2020	93	11025 Annville Rd.	3.88
5/10/2020	86	14814 Santa Gertrudis Dr.	3.29

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/10/2020	26	225 Eastgate Dr.	3.13
5/10/2020	8	1126 Cornerstone Dr.	3.11
5/10/2020	97	13902 Skysail St.	3.10
5/11/2020	86	14814 Santa Gertrudis Dr.	3.30
5/11/2020	65	726 Westchester Dr.	3.01
5/11/2020	13	1505 6th St.	3.20
5/11/2020	29	1601 La Joya St.	3.19
5/11/2020	77	5018 Cape Ann Dr.	2.84
5/11/2020	52	221 Junior Beck Dr.	3.52
5/11/2020	85	302 Glenmore St.	2.65
5/11/2020	71	5510 Fox Run Dr.	3.06
5/11/2020	76	1109 Harbor Lights Dr.	2.71
5/11/2020	23	5506 Wooldridge Rd.	3.20
5/11/2020	40	9550 Quetzal St.	2.64
5/11/2020	83	4101 Summit Dr.	2.62
5/11/2020	3	3013 S Fork Dr.	3.39
5/11/2020	4	14233 Playa del Rey	3.17
5/12/2020	15	6130 Parkway Dr.	3.07
5/12/2020	87	5226 Northwest Trl.	3.56
5/12/2020	70	1633 E. Manor Dr.	3.20
5/12/2020	26	225 Eastgate Dr.	3.40
5/12/2020	8	1126 Cornerstone Dr.	3.23
5/12/2020	61	234 Saratoga Blvd.	3.60
5/12/2020	96	14926 Windward Dr.	2.82
5/12/2020	73	5649 King Trl.	3.64
5/13/2020	90	11722 Haven Dr.	3.44
5/13/2020	47	8121 Barrogate Dr.	3.64

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/13/2020	50	5534 IH 37 Access Rd.	3.44
5/13/2020	14	922 Rosedale Dr.	3.22
5/13/2020	77	5018 Cape Ann Dr.	2.94
5/13/2020	55	514 Belden St.	3.18
5/13/2020	68	5322 Alejandro St.	3.04
5/13/2020	85	302 Glenmore St.	2.79
5/13/2020	71	5510 Fox Run Dr.	2.97
5/13/2020	16	4205 Wildcat Dr.	3.57
5/13/2020	36	1338 Sandstone Dr.	2.94
5/13/2020	39	5929 Long Creek Dr.	2.99
5/13/2020	76	1109 Harbor Lights Dr.	2.97
5/13/2020	40	9550 Quetzal St.	2.85
5/13/2020	62	5809 Hampshire Rd.	3.39
5/13/2020	24	2342 Rodd Field Rd.	3.36
5/13/2020	45	15222 Cruiser St.	3.40
5/13/2020	1	4810 Neptune St.	3.47
5/13/2020	83	4101 Summit Dr.	2.67
5/13/2020	94	15209 Caravel Dr.	3.04
5/13/2020	18	902 Nueces Bay Blvd.	3.20
5/14/2020	69	4013 Donaho Dr.	3.10
5/14/2020	72	7717 Starnberg Lake Dr.	3.17
5/14/2020	78	7602 Timber Crest Dr.	3.38
5/14/2020	91	2713 Wind Rock Dr.	3.59
5/14/2020	74	7910 Impala Dr.	2.98
5/14/2020	64	4013 Hidalgo St.	3.39
5/14/2020	66	635 Southern St.	3.31
5/14/2020	98	15806 Almeria Ave.	3.05

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/15/2020	44	9602 Wilkins Dr.	3.73
5/15/2020	48	1237 Southern Minerals Rd.	3.62
5/15/2020	25	4101 Bascule Dr.	3.24
5/15/2020	33	3913 Ocean Dr.	2.89
5/15/2020	2	5809 St. Andrews Dr.	2.69
5/15/2020	72	7717 Starnberg Lake Dr.	3.42
5/15/2020	95	15837 El Socorro Loop	2.62
5/16/2020	14	922 Rosedale Dr.	2.88
5/16/2020	99	3926 Elvis Dr.	3.08
5/16/2020	96	14926 Windward Dr.	2.50
5/16/2020	16	4205 Wildcat Dr.	3.59
5/17/2020	82	2101 Whispering Oak Dr.	2.80
5/17/2020	95	15837 El Socorro Loop	2.40
5/17/2020	55	514 Belden St.	2.97
5/17/2020	87	5226 Northwest Trl.	3.26
5/18/2020	77	5018 Cape Ann Dr.	2.56
5/18/2020	85	302 Glenmore St.	2.55
5/18/2020	35	4702 Congressional Dr.	2.78
5/18/2020	76	1109 Harbor Lights Dr.	2.61
5/18/2020	40	9550 Quetzal St.	2.53
5/18/2020	80	7042 Arapahoe St.	3.24
5/18/2020	92	334 Wildwood Dr.	3.85
5/18/2020	83	4101 Summit Dr.	2.50
5/18/2020	19	1301 Horne Rd.	3.35
5/18/2020	38	7525 Annemasse St.	2.72
5/18/2020	58	4801 French Dr.	2.87
5/18/2020	96	14926 Windward Dr.	2.96

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/19/2020	46	8903 McNorton Rd.	3.46
5/19/2020	57	1409 Arlington Dr.	3.07
5/19/2020	10	3146 Saratoga Blvd.	2.91
5/19/2020	37	6502 Brockhampton St.	2.94
5/19/2020	34	4341 Harry St.	3.15
5/19/2020	43	245 Caribbean Dr.	2.96
5/19/2020	97	13902 Skysail St.	2.93
5/20/2020	89	3814 Castle Ridge Dr.	3.03
5/20/2020	27	2823 S Port Ave.	3.35
5/20/2020	88	4214 Western Dr.	3.63
5/20/2020	6	1213 10th St.	3.18
5/20/2020	53	9105 Stock Dr.	2.67
5/20/2020	81	6630 Meadowheights Dr.	3.27
5/20/2020	20	3901 Cott St.	3.19
5/20/2020	77	5018 Cape Ann Dr.	2.67
5/20/2020	85	302 Glenmore St.	2.72
5/20/2020	75	2938 Oso Pkwy.	3.21
5/20/2020	22	6713 Weber Rd.	3.14
5/20/2020	67	509 S. Carancahua St.	3.15
5/20/2020	76	1109 Harbor Lights Dr.	2.91
5/20/2020	99	3926 Elvis Dr.	3.23
5/20/2020	5	4609 Evelyn St.	2.75
5/20/2020	41	1605 Amber Dr.	3.03
5/20/2020	40	9550 Quetzal St.	3.05
5/20/2020	84	3640 Flour Bluff Dr.	3.41
5/20/2020	94	15209 Caravel Dr.	2.65
5/20/2020	83	4101 Summit Dr.	2.93

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/20/2020	4	14233 Playa del Rey	3.20
5/21/2020	90	11722 Haven Dr.	3.02
5/21/2020	91	2713 Wind Rock Dr.	3.21
5/21/2020	56	202 Amistad St.	2.76
5/21/2020	49	113 Commerce St.	3.04
5/21/2020	30	3100 Brawner Pkwy.	2.59
5/21/2020	9	1000 International Dr.	2.96
5/21/2020	59	3633 Capri Dr.	2.81
5/21/2020	28	1718 Bois d' Arc Pl.	3.11
5/21/2020	7	617 Carmel Pkwy.	2.75
5/21/2020	32	4901 Hakel Dr.	3.16
5/21/2020	79	905 Egyptian Dr.	2.62
5/21/2020	82	2101 Whispering Oak Dr.	2.81
5/21/2020	21	913 Lum Ave.	2.91
5/21/2020	98	15806 Almeria Ave.	2.73
5/21/2020	42	753 Orleans Dr.	2.88
5/21/2020	45	15222 Cruiser St.	3.36
5/22/2020	93	11025 Annville Rd.	3.84
5/22/2020	51	249 Gibson Ln.	2.96
5/22/2020	12	2219 Buford Ave.	3.21
5/22/2020	54	3710 Seagull Blvd.	2.51
5/22/2020	31	4306 Cedar St.	2.74
5/22/2020	74	7910 Impala Dr.	2.78
5/22/2020	60	1346 Calle San Marcos	2.64
5/22/2020	66	635 Southern St.	3.03
5/22/2020	11	534 Military Dr.	2.60
5/22/2020	1	4810 Neptune St.	3.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/22/2020	97	13902 Skysail St.	3.05
5/23/2020	93	11025 Annville Rd.	3.66
5/23/2020	25	4101 Bascule Dr.	3.03
5/23/2020	38	7525 Annemasse St.	2.71
5/23/2020	98	15806 Almeria Ave.	2.57
5/24/2020	86	14814 Santa Gertrudis Dr.	2.90
5/24/2020	26	225 Eastgate Dr.	3.02
5/24/2020	8	1126 Cornerstone Dr.	2.76
5/24/2020	97	13902 Skysail St.	2.73
5/25/2020	77	5018 Cape Ann Dr.	2.59
5/25/2020	86	14814 Santa Gertrudis Dr.	2.96
5/25/2020	85	302 Glenmore St.	2.67
5/25/2020	29	1601 La Joya St.	2.81
5/25/2020	76	1109 Harbor Lights Dr.	2.78
5/25/2020	65	726 Westchester Dr.	3.23
5/25/2020	23	5506 Wooldridge Rd.	2.84
5/25/2020	40	9550 Quetzal St.	2.71
5/25/2020	13	1505 6th St.	3.05
5/25/2020	3	3013 S Fork Dr.	2.75
5/25/2020	83	4101 Summit Dr.	2.62
5/25/2020	52	221 Junior Beck Dr.	3.34
5/25/2020	4	14233 Playa del Rey	3.02
5/26/2020	87	5226 Northwest Trl.	3.22
5/26/2020	26	225 Eastgate Dr.	3.16
5/26/2020	61	234 Saratoga Blvd.	3.27
5/26/2020	73	5649 King Trl.	2.89
5/26/2020	15	6130 Parkway Dr.	3.04

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/26/2020	70	1633 E. Manor Dr.	2.93
5/26/2020	8	1126 Cornerstone Dr.	2.77
5/26/2020	96	14926 Windward Dr.	2.91
5/27/2020	16	4205 Wildcat Dr.	3.65
5/27/2020	62	5809 Hampshire Rd.	3.46
5/27/2020	1	4810 Neptune St.	3.67
5/27/2020	86	14814 Santa Gertrudis Dr.	2.92
5/27/2020	91	2713 Wind Rock Dr.	3.58
5/27/2020	18	902 Nueces Bay Blvd.	3.38
5/27/2020	65	726 Westchester Dr.	3.29
5/27/2020	64	4013 Hidalgo St.	3.62
5/27/2020	55	514 Belden St.	3.12
5/27/2020	13	1505 6th St.	2.86
5/27/2020	66	635 Southern St.	3.21
5/27/2020	77	5018 Cape Ann Dr.	2.69
5/27/2020	69	4013 Donaho Dr.	2.85
5/27/2020	85	302 Glenmore St.	2.63
5/27/2020	52	221 Junior Beck Dr.	3.14
5/27/2020	39	5929 Long Creek Dr.	2.82
5/27/2020	78	7602 Timber Crest Dr.	3.01
5/27/2020	76	1109 Harbor Lights Dr.	2.66
5/27/2020	24	2342 Rodd Field Rd.	3.01
5/27/2020	8	1126 Cornerstone Dr.	2.99
5/27/2020	74	7910 Impala Dr.	2.77
5/27/2020	40	9550 Quetzal St.	2.57
5/27/2020	94	15209 Caravel Dr.	2.80
5/27/2020	98	15806 Almeria Ave.	2.41

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/27/2020	83	4101 Summit Dr.	2.50
5/28/2020	90	11722 Haven Dr.	3.41
5/28/2020	47	8121 Barrogate Dr.	3.64
5/28/2020	44	9602 Wilkins Dr.	3.64
5/28/2020	48	1237 Southern Minerals Rd.	3.70
5/28/2020	50	5534 IH 37 Access Rd.	3.58
5/28/2020	25	4101 Bascule Dr.	3.40
5/28/2020	14	922 Rosedale Dr.	3.04
5/28/2020	33	3913 Ocean Dr.	3.12
5/28/2020	68	5322 Alejandro St.	3.16
5/28/2020	2	5809 St. Andrews Dr.	2.92
5/28/2020	72	7717 Starnberg Lake Dr.	3.50
5/28/2020	71	5510 Fox Run Dr.	3.12
5/28/2020	36	1338 Sandstone Dr.	2.73
5/28/2020	95	15837 El Socorro Loop	2.34
5/28/2020	45	15222 Cruiser St.	2.56
5/29/2020	88	4214 Western Dr.	3.90
5/29/2020	29	1601 La Joya St.	3.06
5/29/2020	58	4801 French Dr.	3.03
5/29/2020	4	14233 Playa del Rey	3.18
5/30/2020	16	4205 Wildcat Dr.	3.34
5/30/2020	14	922 Rosedale Dr.	3.05
5/30/2020	99	3926 Elvis Dr.	3.11
5/30/2020	96	14926 Windward Dr.	3.15
5/31/2020	87	5226 Northwest Trl.	3.29
5/31/2020	55	514 Belden St.	2.93
5/31/2020	82	2101 Whispering Oak Dr.	2.85

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
5/31/2020	95	15837 El Socorro Loop	2.50

June

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/1/2020	32	4901 Hakel Dr.	3.08
6/1/2020	21	913 Lum Ave.	2.79
6/1/2020	42	753 Orleans Dr.	2.66
6/1/2020	45	15222 Cruiser St.	3.32
6/1/2020	77	5018 Cape Ann Dr.	2.69
6/1/2020	91	2713 Wind Rock Dr.	3.47
6/1/2020	85	302 Glenmore St.	2.53
6/1/2020	49	113 Commerce St.	3.24
6/1/2020	9	1000 International Dr.	3.05
6/1/2020	76	1109 Harbor Lights Dr.	2.61
6/1/2020	28	1718 Bois d' Arc Pl.	3.18
6/1/2020	40	9550 Quetzal St.	2.44
6/1/2020	83	4101 Summit Dr.	2.52
6/2/2020	22	6713 Weber Rd.	3.34
6/2/2020	89	3814 Castle Ridge Dr.	3.16
6/2/2020	99	3926 Elvis Dr.	3.17
6/2/2020	27	2823 S Port Ave.	3.25
6/2/2020	84	3640 Flour Bluff Dr.	2.73
6/2/2020	6	1213 10th St.	3.07
6/2/2020	4	14233 Playa del Rey	2.81
6/2/2020	20	3901 Cott St.	3.17
6/3/2020	7	617 Carmel Pkwy.	3.09

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/3/2020	77	5018 Cape Ann Dr.	2.85
6/3/2020	90	11722 Haven Dr.	3.44
6/3/2020	79	905 Egyptian Dr.	2.88
6/3/2020	85	302 Glenmore St.	2.72
6/3/2020	59	3633 Capri Dr.	3.18
6/3/2020	76	1109 Harbor Lights Dr.	2.82
6/3/2020	56	202 Amistad St.	3.07
6/3/2020	82	2101 Whispering Oak Dr.	2.97
6/3/2020	58	4801 French Dr.	3.17
6/3/2020	40	9550 Quetzal St.	2.63
6/3/2020	30	3100 Brawner Pkwy.	2.66
6/3/2020	98	15806 Almeria Ave.	2.96
6/3/2020	98	15806 Almeria Ave.	2.89
6/3/2020	83	4101 Summit Dr.	2.25
6/3/2020	95	15837 El Socorro Loop	2.48
6/3/2020	59	3633 Capri Dr.	3.27
6/4/2020	59	3633 Capri Dr.	3.05
6/4/2020	31	4306 Cedar St.	2.77
6/4/2020	93	11025 Annville Rd.	4.01
6/4/2020	60	1346 Calle San Marcos	2.86
6/4/2020	51	249 Gibson Ln.	3.15
6/4/2020	12	2219 Buford Ave.	3.29
6/4/2020	11	534 Military Dr.	2.41
6/4/2020	54	3710 Seagull Blvd.	2.96
6/4/2020	97	13902 Skysail St.	3.03
6/5/2020	91	2713 Wind Rock Dr.	3.35
6/5/2020	86	14814 Santa Gertrudis Dr.	2.77

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/5/2020	49	113 Commerce St.	3.24
6/5/2020	65	726 Westchester Dr.	3.30
6/5/2020	9	1000 International Dr.	3.29
6/5/2020	13	1505 6th St.	3.19
6/5/2020	28	1718 Bois d' Arc Pl.	3.32
6/5/2020	52	221 Junior Beck Dr.	2.87
6/5/2020	32	4901 Hakel Dr.	3.31
6/5/2020	29	1601 La Joya St.	3.18
6/5/2020	21	913 Lum Ave.	2.80
6/5/2020	23	5506 Wooldridge Rd.	2.67
6/5/2020	42	753 Orleans Dr.	2.98
6/5/2020	3	3013 S Fork Dr.	3.11
6/5/2020	4	14233 Playa del Rey	3.29
6/5/2020	45	15222 Cruiser St.	3.47
6/6/2020	28	1718 Bois d' Arc Pl.	3.33
6/6/2020	93	11025 Annville Rd.	3.64
6/6/2020	25	4101 Bascule Dr.	3.12
6/6/2020	38	7525 Annemasse St.	3.14
6/6/2020	98	15806 Almeria Ave.	2.83
6/7/2020	86	14814 Santa Gertrudis Dr.	2.91
6/7/2020	26	225 Eastgate Dr.	3.09
6/7/2020	8	1126 Cornerstone Dr.	2.93
6/7/2020	97	13902 Skysail St.	3.20
6/8/2020	87	5200 Block of Northwest Trl	3.17
6/8/2020	26	200 Block of Eastgate Dr	2.96
6/8/2020	61	200 Block of Saratoga Blvd	3.30
6/8/2020	73	5600 Block of King Trl	3.25

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/8/2020	77	5000 Block of Cape Ann Dr	2.60
6/8/2020	85	300 Block of Glenmore St	2.52
6/8/2020	15	6100 Block of Parkway Dr	2.96
6/8/2020	76	1100 Block of Harbor Lights Dr	2.62
6/8/2020	70	1600 Block of E Manor Dr	2.83
6/8/2020	40	9500 Block of Quetzal St	2.54
6/8/2020	83	4100 Block of Summit Dr	2.50
6/8/2020	8	1100 Block of Cornerstone Dr	2.77
6/8/2020	96	14900 Block of Windward Dr	3.04
6/9/2020	16	4200 Block of Wildcat Dr	3.34
6/9/2020	62	5800 Block of Hampshire Rd	3.09
6/9/2020	1	4800 Block of Neptune St	3.22
6/9/2020	18	900 Block of Nueces Bay Blvd	2.93
6/9/2020	55	500 Block of Belden St	2.91
6/9/2020	39	5900 Block of Long Creak Dr	2.78
6/9/2020	24	2300 Block of Rodd Field Rd	2.89
6/9/2020	94	15200 Block of Caravel Dr	2.93
6/10/2020	91	2700 Block of Wind Rock Dr	3.23
6/10/2020	92	300 Block of Wildwood Dr	3.34
6/10/2020	64	4000 Block of Hidalgo St	3.13
6/10/2020	19	1300 Block of Horne Rd	2.63
6/10/2020	66	600 Block of Southern St	2.97
6/10/2020	69	4000 Block of Donaho Dr	2.82
6/10/2020	58	4800 Block of French Dr	2.52
6/10/2020	77	5000 Block of Cape Ann Dr	2.46
6/10/2020	78	7600 Block of Timber Crest Dr	2.71
6/10/2020	35	4700 Block of Congressional Dr	2.58

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/10/2020	85	300 Block of Glenmore St	2.54
6/10/2020	76	1100 Block of Harbor Lights Dr	2.60
6/10/2020	80	7000 Block of Arapahoe St	2.46
6/10/2020	40	9500 Block of Quetzal St	2.54
6/10/2020	38	7500 Block of Annemasse St	2.50
6/10/2020	74	7900 Block of Impala Dr	2.73
6/10/2020	83	4100 Block of Summit Dr	2.50
6/10/2020	96	14900 Block of Windward Dr	2.72
6/10/2020	98	15800 Block of Almeria Ave	2.56
6/11/2020	88	4200 Block of Western Dr	3.61
6/11/2020	53	9100 Block of Stock Dr	2.74
6/11/2020	46	8900 Block of McNorton Rd	3.26
6/11/2020	67	500 Block of S Carancahua St	2.96
6/11/2020	57	1400 Block of Arlington Dr	2.68
6/11/2020	10	3100 Block of Saratoga Blvd	2.73
6/11/2020	5	4600 Block of Evelyn St	2.43
6/11/2020	34	4300 Block of Harry St	2.69
6/11/2020	81	6600 Block of Meadowheights Dr	2.65
6/11/2020	37	6500 Block of Brockhampton St	2.71
6/11/2020	75	2900 Block of Oso Pkwy	2.54
6/11/2020	43	200 Block of Caribbean Dr	2.51
6/11/2020	41	1600 Block of Amber Dr	2.43
6/11/2020	97	13900 Block of Skysail St	2.73
6/11/2020	94	15200 Block of Caravel Dr	2.67
6/12/2020	89	3800 Block of Castle Ridge Dr	3.10
6/12/2020	27	2800 Block of S Port Ave	3.26
6/12/2020	6	1200 Block of 10th St	3.16

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/12/2020	20	3900 Block of Cott St	3.13
6/12/2020	22	6700 Block of Weber Rd	2.96
6/12/2020	99	3900 Block of Elvis Dr	3.00
6/12/2020	84	3600 Block of Flour Bluff Dr	2.88
6/12/2020	4	14200 Block of Playa Del Rey	2.85
6/13/2020	16	4200 Block of Wildcat Dr	3.49
6/13/2020	14	900 Block of Rosedale Dr	2.70
6/13/2020	99	3900 Block of Elvis Dr	2.88
6/13/2020	96	14900 Block of Windward Dr	2.78
6/14/2020	95	15800 Block of El Socorro Loop	2.33
6/14/2020	82	2100 Block of Whispering Oak Dr	2.89
6/14/2020	55	500 Block of Belden St	3.05
6/14/2020	87	5200 Block of Northwest Trl	3.37
6/15/2020	90	11700 Block of Haven Dr	3.53
6/15/2020	56	200 Block of Amistad St	3.15
6/15/2020	30	3100 Block of Brawner Pkwy	3.22
6/15/2020	59	3600 Block of Capri Dr	3.13
6/15/2020	7	600 Block of Carmel Pkway	2.84
6/15/2020	77	5000 Block of Cape Ann Dr	2.76
6/15/2020	79	900 Block of Egyptian Dr	2.89
6/15/2020	85	300 Block of Glenmore St	2.73
6/15/2020	82	2100 Block of Whispering Oak Dr	3.22
6/15/2020	76	1100 Block of Harbor Lights Dr	2.76
6/15/2020	40	9500 Block of Quetzal St	2.70
6/15/2020	98	15800 Block of Almeria Ave	2.47
6/15/2020	83	4100 Block of Summit Dr	2.55
6/16/2020	90	11700 Block of Haven Dr	3.19

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/16/2020	47	8100 Block of Barrogate Dr	3.38
6/16/2020	68	5300 Block of Alejandro St	3.14
6/16/2020	50	5500 Block of IH 37 access rd	3.44
6/16/2020	36	1300 Block of Sandstone Dr	3.09
6/16/2020	14	900 Block of Rosedale Dr	2.85
6/16/2020	45	15200 Block of Cruiser st	2.58
6/17/2020	93	11000 Block of Annville Rd	3.70
6/17/2020	51	200 Block of Gibson Ln	3.10
6/17/2020	12	2200 Block of Buford Ave	3.17
6/17/2020	54	3700 Block of Seagull Blvd	2.66
6/17/2020	31	4300 Block of Cedar st	2.66
6/17/2020	44	9600 Block of Wilkins Dr	3.61
6/17/2020	2	5800 Block of St. Andrews St	2.70
6/17/2020	77	5000 Block of Cape Ann Dr	2.59
6/17/2020	48	200 Block of Southern Minerals Rd	3.79
6/17/2020	60	1300 Block of Calle San Marcos	2.61
6/17/2020	72	7700 Block of Starnberg Lake Dr	3.17
6/17/2020	85	300 Block of Glenmore St	2.63
6/17/2020	76	1100 Block of Harbor Lights Dr	2.76
6/17/2020	25	4100 Block of Bascule Dr	3.10
6/17/2020	11	500 Block of Military Dr	2.60
6/17/2020	95	15800 Block of El Socorro Loop	2.40
6/17/2020	40	9500 Block of Quetzal St	2.95
6/17/2020	97	13900 Block of Skysail St	3.03
6/17/2020	33	3900 Block of Ocean Dr	2.90
6/17/2020	83	4100 Block of Summit Dr	2.97
6/18/2020	68	5300 Block of Alejandro St	3.10

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/18/2020	90	11700 Block of Haven Dr	3.47
6/18/2020	47	8100 Block of Barrogate Dr	3.85
6/18/2020	36	1300 Block of Sandstone Dr	2.80
6/18/2020	50	5500 Block of IH 37 access rd	3.61
6/18/2020	45	15200 Block of Cruiser st	2.58
6/18/2020	14	900 Block of Rosedale Dr	3.06
6/19/2020	91	2700 Block of Wind Rock Dr	3.40
6/19/2020	49	100 Block of Commerce St	3.33
6/19/2020	9	1000 Block of International Dr	3.36
6/19/2020	28	1700 Block of Bois d' Arc Pl	3.32
6/19/2020	32	4900 Block of Hakel Dr	3.27
6/19/2020	21	900 Block of Lum Ave	2.99
6/19/2020	42	700 Block of Orleans Dr	2.92
6/19/2020	45	15200 Block of Cruiser st	2.89
6/19/2020	45	15200 Block of Cruiser st	2.92
6/20/2020	93	11000 Block of Annville Rd	3.81
6/20/2020	25	4100 Block of Bascule Dr	3.15
6/20/2020	71	5500 Block of Fox Run Dr	2.95
6/20/2020	38	7500 Block of Annemasse St	3.25
6/20/2020	98	15800 Block of Almeria Ave	2.90
6/21/2020	86	14800 Block of Santa Gertrudis Dr	2.89
6/21/2020	26	200 Block of Eastgate Dr	3.13
6/21/2020	8	1100 Block of Cornerstone Dr	2.98
6/21/2020	97	13900 Block of Skysail St	3.14
6/22/2020	92	300 Block of Wildwood Dr	3.78
6/22/2020	19	1300 Block of Horne Rd	3.25
6/22/2020	58	4800 Block of French Dr	2.91

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/22/2020	77	5000 Block of Cape Ann Dr	2.58
6/22/2020	85	300 Block of Glenmore St	2.50
6/22/2020	35	4700 Block of Congressional Dr	3.03
6/22/2020	76	1100 Block of Harbor Lights Dr	2.53
6/22/2020	80	7000 Block of Arapahoe St	3.13
6/22/2020	40	9500 Block of Quetzal St	2.50
6/22/2020	38	7500 Block of Annemasse St	2.75
6/22/2020	83	4100 Block of Summit Dr	2.58
6/22/2020	96	14900 Block of Windward Dr	2.85
6/23/2020	46	8900 Block of McNorton Rd	3.36
6/23/2020	57	1400 Block of Arlington Dr	2.98
6/23/2020	10	3100 Block of Saratoga Blvd	2.88
6/23/2020	34	4300 Block of Harry St	2.85
6/23/2020	37	6500 Block of Brockhampton St	2.89
6/23/2020	43	200 Block of Caribbean Dr	2.95
6/23/2020	97	13900 Block of Skysail St	3.06
6/24/2020	44	9600 Block of Wilkins Dr	3.72
6/24/2020	48	200 Block of Southern Minerals Rd	3.76
6/24/2020	25	4100 Block of Bascule Dr	3.07
6/24/2020	33	3900 Block of Ocean Dr	2.80
6/24/2020	2	5800 Block of St. Andrews St	2.78
6/24/2020	77	5000 Block of Cape Ann Dr	2.64
6/24/2020	72	7700 Block of Starnberg Lake Dr	3.17
6/24/2020	85	300 Block of Glenmore St	2.63
6/24/2020	76	1100 Block of Harbor Lights Dr	2.70
6/24/2020	40	9500 Block of Quetzal St	2.51
6/24/2020	95	15800 Block of El Socorro Loop	2.37

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/24/2020	83	4100 Block of Summit Dr	2.61
6/25/2020	86	14800 Block of Santa Gertrudis Dr	3.04
6/25/2020	65	700 Block of Westchester Dr	3.11
6/25/2020	13	1500 Block of 6th St	2.66
6/25/2020	52	200 Block of Junior Beck Dr	2.98
6/25/2020	29	1600 Block of La Joya St	3.12
6/25/2020	23	5500 Block of Wooldridge Rd	2.94
6/25/2020	3	3000 Block of S Fork Dr	2.74
6/25/2020	4	14200 Block of Playa Del Rey	2.91
6/26/2020	16	4200 Block of Wildcat Dr	3.62
6/26/2020	62	5800 Block of Hampshire Rd	3.36
6/26/2020	1	4800 Block of Neptune St	3.41
6/26/2020	18	900 Block of Nueces Bay Blvd	3.08
6/26/2020	55	500 Block of Belden St	3.14
6/26/2020	39	5900 Block of Long Creak Dr	2.99
6/26/2020	24	2300 Block of Rodd Field Rd	2.60
6/26/2020	94	15200 Block of Caravel Dr	2.71
6/27/2020	16	4200 Block of Wildcat Dr	3.43
6/27/2020	14	900 Block of Rosedale Dr	3.02
6/27/2020	99	3900 Block of Elvis Dr	2.98
6/27/2020	96	14900 Block of Windward Dr	2.93
6/28/2020	87	5200 Block of Northwest Trl	3.44
6/28/2020	55	500 Block of Belden St	3.08
6/28/2020	82	2100 Block of Whispering Oak Dr	3.08
6/28/2020	95	15800 Block of El Socorro Loop	2.25
6/29/2020	91	2700 Block of Wind Rock Dr	3.25
6/29/2020	64	4000 Block of Hidalgo St	3.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
6/29/2020	66	600 Block of Southern St	3.19
6/29/2020	69	4000 Block of Donaho Dr	3.17
6/29/2020	78	7600 Block of Timber Crest Dr	2.98
6/29/2020	77	5000 Block of Cape Ann Dr	2.69
6/29/2020	74	7900 Block of Impala Dr	2.91
6/29/2020	85	300 Block of Glenmore St	2.53
6/29/2020	76	1100 Block of Harbor Lights Dr	2.72
6/29/2020	40	9500 Block of Quetzal St	2.95
6/29/2020	98	15800 Block of Almeria Ave	2.69
6/29/2020	83	4100 Block of Summit Dr	2.63
6/30/2020	88	4200 Block of Western Dr	3.91
6/30/2020	29	1600 Block of La Joya St	3.13
6/30/2020	58	4800 Block of French Dr	3.18
6/30/2020	4	14200 Block of Playa del Rey	3.20

July

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/1/2020	89	3800 Block of Castle Ridge Dr	3.20
7/1/2020	27	2800 Block of S Port Ave	3.38
7/1/2020	91	2700 Block of Wind Rock Dr	3.47
7/1/2020	6	1200 Block of 10th St	2.89
7/1/2020	49	100 Block of Commerce St	3.32
7/1/2020	20	3900 Block of Cott St	3.08
7/1/2020	9	1000 Block of International Dr	3.19
7/1/2020	22	6700 Block of Weber Rd	3.12
7/1/2020	28	1700 Block of Bois d' Arc Pl	3.32

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/1/2020	32	4900 Block of Hakel Dr	3.21
7/1/2020	99	3900 Block of Elvis Dr	3.03
7/1/2020	77	5000 Block of Cape Ann Dr	2.91
7/1/2020	21	900 Block of Lum Ave	3.01
7/1/2020	84	3600 Block of Flour Bluff Dr	3.01
7/1/2020	85	300 Block of Glenmore St	2.79
7/1/2020	42	700 Block of Orleans Dr	3.02
7/1/2020	76	1100 Block of Harbor Lights Dr	2.89
7/1/2020	4	14200 Block of Playa del Rey	3.06
7/1/2020	40	9500 Block of Quetzal St	2.71
7/1/2020	45	15200 Block of Cruiser St	3.10
7/1/2020	83	4100 Block of Summit Dr	2.75
7/2/2020	59	3600 Block of Capri Dr	3.05
7/2/2020	90	11700 Block of Haven Dr	3.36
7/2/2020	58	4800 Block of French Dr	2.99
7/2/2020	56	200 Block of Amistad St	3.03
7/2/2020	30	3100 Block of Brawner Pkwy	3.08
7/2/2020	98	15800 Block of Almeria Ave	2.94
7/2/2020	59	3600 Block of Capri Dr	3.15
7/2/2020	95	15800 Block of El Socorro Loop	2.47
7/2/2020	7	600 Block of Carmel Pkwy	3.02
7/2/2020	79	900 Block of Egyptian Dr	2.89
7/2/2020	82	2100 Block of Whispering Oak Dr	2.93
7/2/2020	98	15800 Block of Almeria Ave	2.49
7/3/2020	31	4300 Block of Cedar St	2.90
7/3/2020	93	11000 Block of Annville Rd	4.00
7/3/2020	60	1300 Block of Calle San Marcos	3.01

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/3/2020	51	200 Block of Gibson Ln	3.32
7/3/2020	11	500 Block of Military Dr	2.67
7/3/2020	12	2200 Block of Buford Ave	3.47
7/3/2020	97	13900 Block of Skysail St	3.34
7/3/2020	54	3700 Block of Seagull Blvd	3.01
7/4/2020	98	15800 Block of Almeria Ave	2.93
7/4/2020	38	7500 Block of Annemasse St	2.98
7/4/2020	25	4100 Block of Bascule Dr	3.27
7/4/2020	93	11000 Block of Annville Rd	3.77
7/5/2020	97	13900 Block of Skysail St	3.38
7/5/2020	8	1100 Block of Cornerstone Dr	2.83
7/5/2020	26	200 Block of Eastgate Dr	3.18
7/5/2020	86	14800 Block of Santa Gertrudis Dr	3.24
7/6/2020	16	4200 Block of Wildcat Dr	3.57
7/6/2020	77	5000 Block of Cape Ann Dr	2.82
7/6/2020	85	300 Block of Glenmore St	2.71
7/6/2020	76	1100 Block of Harbor Lights Dr	2.86
7/6/2020	40	9500 Block of Quetzal St	2.76
7/6/2020	83	4100 Block of Summit Dr	2.62
7/6/2020	94	15200 Block of Caravel Dr	2.95
7/7/2020	88	4200 Block of Western Dr	3.50
7/7/2020	66	600 Block of Southern St	3.11
7/7/2020	69	4000 Block of Donaho Dr	2.98
7/7/2020	78	7600 Block of Timber Crest Dr	2.86
7/7/2020	98	15800 Block of Almeria Ave	2.73
7/8/2020	90	11700 Block of Haven Dr	3.22
7/8/2020	47	8100 Block of Barrogate Dr	3.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/8/2020	50	5500 Block of IH 37 Access Rd	3.27
7/8/2020	14	900 Block of Rosedale Dr	2.69
7/8/2020	68	5300 Block of Alejandro St	2.99
7/8/2020	71	5500 Block of Fox Run Dr	2.88
7/8/2020	77	5000 Block of Cape Ann Dr	2.64
7/8/2020	36	1300 Block of Sandstone Dr	2.64
7/8/2020	85	300 Block of Glenmore St	2.56
7/8/2020	76	1100 Block of Harbor Lights Dr	2.67
7/8/2020	45	15200 Block of Cruiser St	2.92
7/8/2020	40	9500 Block of Quetzal St	2.69
7/8/2020	83	4100 Block of Summit Dr	2.76
7/9/2020	91	2700 Block of Wind Rock Dr	3.34
7/9/2020	64	4000 Block of Hidalgo St	3.26
7/9/2020	74	7900 Block of Impala Dr	2.75
7/9/2020	4	14200 Block of Playa del Rey	3.01
7/10/2020	44	9600 Block of Wilkins Dr	3.55
7/10/2020	48	1200 Block of Southern Minerals Rd	3.54
7/10/2020	25	4100 Block of Bascule Dr	3.06
7/10/2020	33	3900 Block of Ocean Dr	2.89
7/10/2020	2	5800 Block of St. Andrews Dr	2.63
7/10/2020	72	7700 Block of Starnberg Lake Dr	2.77
7/10/2020	95	15800 Block of El Socorro Loop	2.75
7/11/2020	99	3900 Block of Elvis Dr	3.06
7/11/2020	96	14900 Block of Windward Dr	3.02
7/11/2020	14	900 Block of Rosedale Dr	2.60
7/11/2020	16	4200 Block of Wildcat Dr	3.56
7/12/2020	82	2100 Block of Whispering Oak Dr	2.97

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/12/2020	95	15800 Block of El Socorro Loop	2.52
7/12/2020	55	500 Block of Belden St	3.03
7/12/2020	87	5200 Block of Northwest Trl	3.52
7/13/2020	86	14800 Block of Santa Gertrudis Dr	3.28
7/13/2020	65	700 Block of Westchester Dr	3.33
7/13/2020	13	1500 Block of 6th St	2.97
7/13/2020	52	200 Block of Junior Beck Dr	3.14
7/13/2020	77	5000 Block of Cape Ann Dr	2.62
7/13/2020	29	1600 Block of La Joya St	3.27
7/13/2020	85	300 Block of Glenmore St	2.74
7/13/2020	23	5500 Block of Wooldridge Rd	3.10
7/13/2020	76	1100 Block of Harbor Lights Dr	2.83
7/13/2020	40	9500 Block of Quetzal St	2.74
7/13/2020	3	3000 Block of S Fork Dr	3.27
7/13/2020	83	4100 Block of Summit Dr	2.63
7/13/2020	4	14200 Block of Playa del Rey	3.27
7/14/2020	87	5200 Block of Northwest Trl	3.46
7/14/2020	26	200 Block of Eastgate Dr	3.33
7/14/2020	61	200 Block of Saratoga Blvd	3.68
7/14/2020	73	5600 Block of King Acres Dr	3.57
7/14/2020	15	6100 Block of Parkway Dr	3.12
7/14/2020	70	1600 Block of E Manor Dr	2.93
7/14/2020	8	1100 Block of Cornerstone Dr	3.20
7/14/2020	96	14900 Block of Windward Dr	3.24
7/15/2020	89	3800 Block of Castle Ridge Dr	3.24
7/15/2020	16	4200 Block of Wildcat Dr	3.45
7/15/2020	27	2800 Block of S Port Ave	3.41

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/15/2020	62	5800 Block of Hampshire Rd	3.34
7/15/2020	6	1200 Block of 10th St	3.10
7/15/2020	1	4800 Block of Neptune St	3.37
7/15/2020	77	5000 Block of Cape Ann Dr	2.85
7/15/2020	20	3900 Block of Cott St	3.45
7/15/2020	18	900 Block of Nueces Bay Blvd	3.29
7/15/2020	85	300 Block of Glenmore St	2.69
7/15/2020	22	6700 Block of Weber Rd	3.38
7/15/2020	55	500 Block of Belden St	3.34
7/15/2020	76	1100 Block of Harbor Lights Dr	2.84
7/15/2020	99	3900 Block of Elvis Dr	3.41
7/15/2020	40	9500 Block of Quetzal St	2.74
7/15/2020	39	5900 Block of Long Creek Dr	3.03
7/15/2020	84	3600 Block of Flour Bluff Dr	3.34
7/15/2020	24	2300 Block of Rodd Field Rd	2.99
7/15/2020	83	4100 Block of Summit Dr	2.88
7/15/2020	94	15200 Block of Caravel Dr	2.84
7/15/2020	4	14200 Block of Playa del Rey	3.37
7/16/2020	92	300 Block of Wildwood Dr	3.75
7/16/2020	46	8900 Block of McNorton Rd	3.60
7/16/2020	19	1300 Block of Horne Rd	3.21
7/16/2020	57	1400 Block of Arlington Dr	3.11
7/16/2020	58	4800 Block of French Dr	3.03
7/16/2020	10	3100 Block of Saratoga Blvd	2.93
7/16/2020	35	4700 Block of Congressional Dr	3.04
7/16/2020	80	7000 Block of Arapahoe St	2.97
7/16/2020	34	4300 Block of Harry St	3.11

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/16/2020	38	7500 Block of Annemasse St	3.17
7/16/2020	37	6500 Block of Brockhampton St	2.91
7/16/2020	96	14900 Block of Windward Dr	3.03
7/16/2020	43	200 Block of Caribbean Dr	3.18
7/16/2020	97	13900 Block of Skysail St	3.55
7/17/2020	88	4200 Block of Western Dr	3.76
7/17/2020	53	9100 Block of Stock Dr	2.99
7/17/2020	67	500 Block of S Carancahua St	3.33
7/17/2020	5	4600 Block of Evelyn St	2.87
7/17/2020	81	6600 Block of Meadowheights Dr	3.13
7/17/2020	75	2900 Block of Oso Pkwy	3.08
7/17/2020	41	1600 Block of Amber Dr	2.98
7/17/2020	94	15200 Block of Caravel Dr	3.10
7/18/2020	93	11000 Block of Annville Rd	3.54
7/18/2020	25	4100 Block of Bascule Dr	3.11
7/18/2020	38	7500 Block of Annemasse St	2.92
7/18/2020	98	15800 Block of Almeria Ave	3.09
7/19/2020	86	14800 Block of Santa Gertrudis Dr	3.15
7/19/2020	26	200 Block of Eastgate Dr	3.01
7/19/2020	8	1100 Block of Cornerstone Dr	2.93
7/19/2020	97	13900 Block of Skysail St	3.27
7/20/2020	93	11000 Block of Annville Rd	3.56
7/20/2020	89	3800 Block of Castle Ridge Dr	3.39
7/20/2020	51	200 Block of Gibson Ln	3.34
7/20/2020	93	11000 Block of Annville Rd	3.84
7/20/2020	88	4200 Block of Western Dr	3.71
7/20/2020	12	2200 Block of Buford Ave	3.44

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/20/2020	16	4200 Block of Wildcat Dr	3.40
7/20/2020	54	3700 Block of Seagull Blvd	2.69
7/20/2020	77	5000 Block of Cape Ann Dr	2.87
7/20/2020	31	4300 Block of Cedar St	2.77
7/20/2020	85	300 Block of Glenmore St	2.73
7/20/2020	60	1300 Block of Calle San Marcos	2.62
7/20/2020	76	1100 Block of Harbor Lights Dr	2.73
7/20/2020	40	9500 Block of Quetzal St	2.65
7/20/2020	11	500 Block of Military Dr	2.38
7/20/2020	97	13900 Block of Skysail St	2.99
7/20/2020	83	4100 Block of Summit Dr	2.65
7/21/2020	90	11700 Block of Haven Dr	3.03
7/21/2020	47	8100 Block of Barrogate Dr	3.62
7/21/2020	50	5500 Block of IH 37 Access Rd	3.12
7/21/2020	89	3800 Block of Castle Ridge Dr	3.05
7/21/2020	14	900 Block of Rosedale Dr	2.79
7/21/2020	93	11000 Block of Annville Rd	3.66
7/21/2020	68	5300 Block of Alejandro St	2.81
7/21/2020	88	4200 Block of Western Dr	3.60
7/21/2020	16	4200 Block of Wildcat Dr	3.24
7/21/2020	71	5500 Block of Fox Run Dr	2.84
7/21/2020	36	1300 Block of Sandstone Dr	2.84
7/21/2020	45	15200 Block of Cruiser St	3.40
7/21/2020	45	15200 Block of Cruiser St	3.36
7/22/2020	16	4200 Block of Wildcat Dr	3.30
7/22/2020	44	9600 Block of Wilkins Dr	3.56
7/22/2020	88	4200 Block of Western Dr	3.53

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/22/2020	48	1200 Block of Southern Minerals Rd	3.53
7/22/2020	93	11000 Block of Annville Rd	3.54
7/22/2020	25	4100 Block of Bascule Dr	2.89
7/22/2020	89	3800 Block of Castle Ridge Dr	2.80
7/22/2020	33	3900 Block of Ocean Dr	2.74
7/22/2020	77	5000 Block of Cape Ann Dr	2.45
7/22/2020	2	5800 Block of St. Andrews Dr	2.64
7/22/2020	85	300 Block of Glenmore St	2.45
7/22/2020	72	7700 Block of Starnberg Lake Dr	3.00
7/22/2020	76	1100 Block of Harbor Lights Dr	2.49
7/22/2020	40	9500 Block of Quetzal St	2.50
7/22/2020	95	15800 Block of El Socorro Loop	2.83
7/22/2020	83	4100 Block of Summit Dr	2.76
7/23/2020	16	4200 Block of Wildcat Dr	3.43
7/23/2020	88	4200 Block of Western Dr	3.79
7/23/2020	93	11000 Block of Annville Rd	3.72
7/23/2020	89	3800 Block of Castle Ridge Dr	3.02
7/23/2020	91	2700 Block of Wind Rock Dr	3.32
7/23/2020	49	100 Block of Commerce St	3.15
7/23/2020	9	1000 Block of International Dr	3.05
7/23/2020	28	1700 Block of Bois d' Arc Pl	3.18
7/23/2020	32	4900 Block of Hakel Dr	3.07
7/23/2020	21	900 Block of Lum Ave	2.63
7/23/2020	42	700 Block of Orleans Dr	2.55
7/23/2020	45	15200 Block of Cruiser St	2.84
7/24/2020	89	3800 Block of Castle Ridge Dr	3.03
7/24/2020	91	2700 Block of Wind Rock Dr	3.09

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/24/2020	90	11700 Block of Haven Dr	3.11
7/24/2020	93	11000 Block of Annville Rd	3.73
7/24/2020	88	4200 Block of Western Dr	3.69
7/24/2020	56	200 Block of Amistad St	2.78
7/24/2020	87	5200 Block of Northwest Trl	3.23
7/24/2020	30	3100 Block of Brawner Pkwy	2.53
7/24/2020	16	4200 Block of Wildcat Dr	3.43
7/24/2020	59	3600 Block of Capri Dr	2.68
7/24/2020	7	600 Block of Carmel Pkwy	2.54
7/24/2020	79	900 Block of Egyptian Dr	2.61
7/24/2020	82	2100 Block of Whispering Oak Dr	2.91
7/24/2020	98	15800 Block of Almeria Ave	2.32
7/24/2020	98	15800 Block of Almeria Ave	2.17
7/25/2020	16	4200 Block of Wildcat Dr	3.21
7/25/2020	14	900 Block of Rosedale Dr	2.46
7/25/2020	99	3900 Block of Elvis Dr	2.92
7/25/2020	96	14900 Block of Windward Dr	2.77
7/26/2020	87	5200 Block of Northwest Trl	2.91
7/26/2020	55	500 Block of Belden St	2.81
7/26/2020	82	2100 Block of Whispering Oak Dr	2.71
7/26/2020	95	15800 Block of El Socorro Loop	1.99
7/27/2020	92	300 Block of Wildwood Dr	3.45
7/27/2020	19	1300 Block of Horne Rd	3.05
7/27/2020	58	4800 Block of French Dr	2.59
7/27/2020	77	5000 Block of Cape Ann Dr	2.39
7/27/2020	85	300 Block of Glenmore St	2.22
7/27/2020	35	4700 Block of Congressional Dr	2.86

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/27/2020	76	1100 Block of Harbor Lights Dr	2.43
7/27/2020	80	7000 Block of Arapahoe St	2.89
7/27/2020	40	9500 Block of Quetzal St	2.33
7/27/2020	38	7500 Block of Annemasse St	2.83
7/27/2020	83	4100 Block of Summit Dr	2.32
7/27/2020	96	14900 Block of Windward Dr	2.50
7/28/2020	46	8900 Block of McNorton Rd	3.08
7/28/2020	57	1400 Block of Arlington Dr	2.59
7/28/2020	10	3100 Block of Saratoga Blvd	2.35
7/28/2020	34	4300 Block of Harry St	2.61
7/28/2020	37	6500 Block of Brockhampton St	2.50
7/28/2020	43	200 Block of Caribbean Dr	2.34
7/28/2020	97	13900 Block of Skysail St	2.70
7/29/2020	88	4200 Block of Western Dr	3.75
7/29/2020	53	9100 Block of Stock Dr	2.67
7/29/2020	67	500 Block of S Carancahua St	2.94
7/29/2020	5	4600 Block of Evelyn St	2.36
7/29/2020	77	5000 Block of Cape Ann Dr	2.33
7/29/2020	85	300 Block of Glenmore St	2.29
7/29/2020	81	6600 Block of Meadowheights Dr	2.73
7/29/2020	76	1100 Block of Harbor Lights Dr	2.43
7/29/2020	75	2900 Block of Oso Pkwy	2.54
7/29/2020	40	9500 Block of Quetzal St	2.34
7/29/2020	41	1600 Block of Amber Dr	2.34
7/29/2020	83	4100 Block of Summit Dr	2.26
7/29/2020	94	15200 Block of Caravel Dr	2.02
7/30/2020	91	2700 Block of Wind Rock Dr	3.24

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
7/30/2020	64	4000 Block of Hidalgo St	3.07
7/30/2020	66	600 Block of Southern St	3.12
7/30/2020	69	4000 Block of Donaho Dr	3.02
7/30/2020	78	7600 Block of Timber Crest Dr	2.72
7/30/2020	74	7900 Block of Impala Dr	2.69
7/30/2020	98	15800 Block of Almeria Ave	2.13
7/31/2020	88	4200 Block of Western Dr	3.80
7/31/2020	29	1600 Block of La Joya St	3.04
7/31/2020	58	4800 Block of French Dr	2.78
7/31/2020	4	14200 Block of Playa del Rey	2.75

August

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/1/2020	93	11000 Block of Annville Rd	3.82
8/1/2020	25	4100 Block of Bascule Dr	3.21
8/1/2020	98	15800 Block of Almeria Ave	2.22
8/1/2020	38	7500 Block of Annemasse St	3.01
8/2/2020	16	4200 Block of Wildcat Dr	3.57
8/2/2020	93	11000 Block of Annville Rd	3.84
8/2/2020	88	4200 Block of Western Dr	3.83
8/2/2020	89	3800 Block of Castle Ridge Dr	3.21
8/2/2020	86	14800 Block of Santa Gertrudis Dr	3.04
8/2/2020	26	200 Block of Eastgate Dr	3.19
8/2/2020	8	1100 Block of Cornerstone Dr	2.61
8/2/2020	97	13900 Block of Skysail St	2.58
8/3/2020	86	14800 Block of Santa Gertrudis Dr	2.85

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/3/2020	65	700 Block of Westchester Dr	3.10
8/3/2020	13	1500 Block of 6th St	2.70
8/3/2020	52	200 Block of Junior Beck Dr	3.15
8/3/2020	29	1600 Block of La Joya St	3.13
8/3/2020	77	5000 Block of Cape Ann Dr	2.60
8/3/2020	85	300 Block of Glenmore St	2.59
8/3/2020	23	5500 Block of Wooldridge Rd	2.94
8/3/2020	76	1100 Block of Harbor Lights Dr	2.76
8/3/2020	3	3000 Block of S Fork Dr	3.14
8/3/2020	40	9500 Block of Quetzal St	2.69
8/3/2020	83	4100 Block of Summit Dr	2.71
8/3/2020	4	14200 Block of Playa del Rey	2.94
8/4/2020	87	5200 Block of Northwest Trl	3.21
8/4/2020	26	200 Block of Eastgate Dr	3.15
8/4/2020	61	200 Block of Saratoga Blvd	3.22
8/4/2020	73	5600 Block of King Acres Dr	3.44
8/4/2020	15	6100 Block of Parkway Dr	3.12
8/4/2020	70	1600 Block of E Manor Dr	2.97
8/4/2020	8	1100 Block of Cornerstone Dr	2.88
8/4/2020	96	14900 Block of Windward Dr	3.21
8/5/2020	16	4200 Block of Wildcat Dr	3.25
8/5/2020	1	4800 Block of Neptune St	3.05
8/5/2020	62	5800 Block of Hampshire Rd	3.07
8/5/2020	77	5000 Block of Cape Ann Dr	2.66
8/5/2020	58	4800 Block of French Dr	2.74
8/5/2020	85	300 Block of Glenmore St	2.68
8/5/2020	18	900 Block of Nueces Bay Blvd	3.02

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/5/2020	55	500 Block of Belden St	2.87
8/5/2020	59	3600 Block of Capri Dr	2.79
8/5/2020	76	1100 Block of Harbor Lights Dr	3.01
8/5/2020	39	5900 Block of Long Creek Dr	2.72
8/5/2020	40	9500 Block of Quetzal St	2.77
8/5/2020	98	15800 Block of Almeria Ave	2.58
8/5/2020	24	2300 Block of Rodd Field Rd	2.97
8/5/2020	83	4100 Block of Summit Dr	2.82
8/5/2020	95	15800 Block of El Socorro Loop	2.45
8/5/2020	94	15200 Block of Caravel Dr	2.78
8/6/2020	92	300 Block of Wildwood Dr	3.71
8/6/2020	19	1300 Block of Horne Rd	3.08
8/6/2020	91	2700 Block of Wind Rock Dr	3.27
8/6/2020	58	4800 Block of French Dr	2.98
8/6/2020	64	4000 Block of Hidalgo St	3.18
8/6/2020	66	600 Block of Southern St	3.08
8/6/2020	35	4700 Block of Congressional Dr	2.94
8/6/2020	69	4000 Block of Donaho Dr	2.94
8/6/2020	80	7000 Block of Arapahoe St	2.80
8/6/2020	78	7600 Block of Timber Crest Dr	2.71
8/6/2020	38	7500 Block of Annemasse St	2.78
8/6/2020	98	15800 Block of Almeria Ave	2.58
8/6/2020	96	14900 Block of Windward Dr	2.87
8/6/2020	74	7900 Block of Impala Dr	2.74
8/7/2020	46	8900 Block of McNorton Rd	3.51
8/7/2020	57	1400 Block of Arlington Dr	2.75
8/7/2020	10	3100 Block of Saratoga Blvd	2.88

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/7/2020	64	4000 Block of Hidalgo St	3.07
8/7/2020	34	4300 Block of Harry St	2.82
8/7/2020	37	6500 Block of Brockhampton St	2.92
8/7/2020	43	200 Block of Caribbean Dr	2.92
8/7/2020	97	13900 Block of Skysail St	2.97
8/8/2020	16	4200 Block of Wildcat Dr	3.46
8/8/2020	14	900 Block of Rosedale Dr	3.02
8/8/2020	99	3900 Block of Elvis Dr	3.22
8/8/2020	96	14900 Block of Windward Dr	3.11
8/9/2020	87	5200 Block of Northwest Trl	3.34
8/9/2020	55	500 Block of Belden St	3.12
8/9/2020	82	2100 Block of Whispering Oak Dr	3.07
8/9/2020	95	15800 Block of El Socorro Loop	2.49
8/10/2020	89	3800 Block of Castle Ridge Dr	3.12
8/10/2020	27	2800 Block of S Port Ave	3.23
8/10/2020	6	1200 Block of 10th St	3.19
8/10/2020	77	5000 Block of Cape Ann Dr	2.74
8/10/2020	20	3900 Block of Cott St	2.99
8/10/2020	85	300 Block of Glenmore St	2.80
8/10/2020	22	6700 Block of Weber Rd	2.94
8/10/2020	76	1100 Block of Harbor Lights Dr	2.97
8/10/2020	99	3900 Block of Elvis Dr	3.11
8/10/2020	40	9500 Block of Quetzal St	2.82
8/10/2020	84	3600 Block of Flour Bluff Dr	3.21
8/10/2020	83	4100 Block of Summit Dr	2.92
8/10/2020	4	14200 Block of Playa del Rey	3.16
8/11/2020	22	6700 Block of Weber Rd	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/11/2020	99	3900 Block of Elvis Dr	3.25
8/11/2020	89	3800 Block of Castle Ridge Dr	3.19
8/11/2020	84	3600 Block of Flour Bluff Dr	3.24
8/11/2020	27	2800 Block of S Port Ave	3.41
8/11/2020	4	14200 Block of Playa del Rey	3.15
8/11/2020	6	1200 Block of 10th St	3.14
8/11/2020	20	3900 Block of Cott St	3.08
8/12/2020	90	11700 Block of Haven Dr	3.23
8/12/2020	47	8100 Block of Barrogate Dr	3.60
8/12/2020	77	5000 Block of Cape Ann Dr	2.79
8/12/2020	50	5500 Block of IH 37 Access Rd	3.39
8/12/2020	85	300 Block of Glenmore St	2.79
8/12/2020	76	1100 Block of Harbor Lights Dr	2.84
8/12/2020	14	900 Block of Rosedale Dr	3.23
8/12/2020	68	5300 Block of Alejandro St	3.19
8/12/2020	91	2700 Block of Wind Rock Dr	3.51
8/12/2020	32	4900 Block of Hakel Dr	3.33
8/12/2020	71	5500 Block of Fox Run Dr	3.07
8/12/2020	40	9500 Block of Quetzal St	2.72
8/12/2020	36	1300 Block of Sandstone Dr	2.85
8/12/2020	49	100 Block of Commerce St	3.42
8/12/2020	21	900 Block of Lum Ave	2.82
8/12/2020	83	4100 Block of Summit Dr	2.75
8/12/2020	45	15200 Block of Cruiser St	3.19
8/12/2020	42	700 Block of Orleans Dr	2.91
8/12/2020	9	1000 Block of International Dr	3.35
8/12/2020	45	15200 Block of Cruiser St	3.29

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/12/2020	28	1700 Block of Bois d' Arc Pl	3.38
8/13/2020	88	4200 Block of Western Dr	3.51
8/13/2020	53	9100 Block of Stock Dr	2.81
8/13/2020	67	500 Block of S Carancahua St	2.91
8/13/2020	90	11700 Block of Haven Dr	3.35
8/13/2020	5	4600 Block of Evelyn St	2.82
8/13/2020	7	600 Block of Carmel Pkwy	2.94
8/13/2020	81	6600 Block of Meadowheights Dr	2.80
8/13/2020	79	900 Block of Egyptian Dr	2.95
8/13/2020	75	2900 Block of Oso Pkwy	2.92
8/13/2020	56	200 Block of Amistad St	3.12
8/13/2020	82	2100 Block of Whispering Oak Dr	3.29
8/13/2020	41	1600 Block of Amber Dr	2.79
8/13/2020	30	3100 Block of Brawner Pkwy	2.96
8/13/2020	98	15800 Block of Almeria Ave	2.67
8/13/2020	94	15200 Block of Caravel Dr	2.59
8/13/2020	59	3600 Block of Capri Dr	3.14
8/14/2020	91	2700 Block of Wind Rock Dr	3.19
8/14/2020	49	100 Block of Commerce St	3.11
8/14/2020	9	1000 Block of International Dr	2.99
8/14/2020	28	1700 Block of Bois d' Arc Pl	3.25
8/14/2020	32	4900 Block of Hakel Dr	3.15
8/14/2020	21	900 Block of Lum Ave	2.82
8/14/2020	42	700 Block of Orleans Dr	2.98
8/14/2020	45	15200 Block of Cruiser St	2.85
8/15/2020	93	11000 Block of Annville Rd	3.70
8/15/2020	25	4100 Block of Bascule Dr	2.99

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/15/2020	38	7500 Block of Annemasse St	3.03
8/15/2020	98	15800 Block of Almeria Ave	2.72
8/16/2020	86	14800 Block of Santa Gertrudis Dr	3.09
8/16/2020	26	200 Block of Eastgate Dr	3.19
8/16/2020	8	1100 Block of Cornerstone Dr	3.05
8/16/2020	97	13900 Block of Skysail St	3.05
8/17/2020	77	5000 Block of Cape Ann Dr	2.40
8/17/2020	85	300 Block of Glenmore St	2.52
8/17/2020	76	1100 Block of Harbor Lights Dr	2.64
8/17/2020	44	9600 Block of Wilkins Dr	3.78
8/17/2020	40	9500 Block of Quetzal St	2.59
8/17/2020	48	1200 Block of Southern Minerals Rd	3.82
8/17/2020	83	4100 Block of Summit Dr	2.68
8/17/2020	25	4100 Block of Bascule Dr	3.23
8/17/2020	33	3900 Block of Ocean Dr	2.83
8/17/2020	2	5800 Block of St. Andrews Dr	2.66
8/17/2020	72	7700 Block of Starnberg Lake Dr	2.91
8/17/2020	95	15800 Block of El Socorro Loop	2.83
8/18/2020	16	4200 Block of Wildcat Dr	3.34
8/18/2020	86	14800 Block of Santa Gertrudis Dr	2.93
8/18/2020	65	700 Block of Westchester Dr	3.36
8/18/2020	95	15800 Block of El Socorro Loop	2.48
8/18/2020	13	1500 Block of 6th St	3.09
8/18/2020	52	200 Block of Junior Beck Dr	3.09
8/18/2020	29	1600 Block of La Joya St	3.01
8/18/2020	23	5500 Block of Wooldridge Rd	3.03
8/18/2020	3	3000 Block of S Fork Dr	3.17

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/18/2020	4	14200 Block of Playa del Rey	3.07
8/19/2020	87	5200 Block of Northwest Trl	2.89
8/19/2020	26	200 Block of Eastgate Dr	2.82
8/19/2020	77	5000 Block of Cape Ann Dr	2.51
8/19/2020	90	11700 Block of Haven Dr	2.87
8/19/2020	85	300 Block of Glenmore St	2.58
8/19/2020	61	200 Block of Saratoga Blvd	2.77
8/19/2020	47	8100 Block of Barrogate Dr	3.55
8/19/2020	56	200 Block of Amistad St	2.73
8/19/2020	76	1100 Block of Harbor Lights Dr	2.58
8/19/2020	30	3100 Block of Brawner Pkwy	2.65
8/19/2020	40	9500 Block of Quetzal St	2.57
8/19/2020	73	5600 Block of King Acres Dr	2.70
8/19/2020	93	11000 Block of Annville Rd	3.55
8/19/2020	59	3600 Block of Capri Dr	2.69
8/19/2020	15	6100 Block of Parkway Dr	2.68
8/19/2020	83	4100 Block of Summit Dr	2.54
8/19/2020	7	600 Block of Carmel Pkwy	2.74
8/19/2020	16	4200 Block of Wildcat Dr	3.11
8/19/2020	70	1600 Block of E Manor Dr	2.75
8/19/2020	79	900 Block of Egyptian Dr	2.60
8/19/2020	82	2100 Block of Whispering Oak Dr	2.76
8/19/2020	8	1100 Block of Cornerstone Dr	2.39
8/19/2020	98	15800 Block of Almeria Ave	2.52
8/19/2020	96	14900 Block of Windward Dr	2.87
8/20/2020	91	2700 Block of Wind Rock Dr	2.98
8/20/2020	64	4000 Block of Hidalgo St	2.84

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/20/2020	66	600 Block of Southern St	2.53
8/20/2020	93	11000 Block of Annville Rd	3.19
8/20/2020	69	4000 Block of Donaho Dr	2.96
8/20/2020	51	200 Block of Gibson Ln	3.11
8/20/2020	78	7600 Block of Timber Crest Dr	2.27
8/20/2020	12	2200 Block of Buford Ave	2.93
8/20/2020	99	3900 Block of Elvis Dr	2.62
8/20/2020	54	3700 Block of Seagull Blvd	2.35
8/20/2020	38	7500 Block of Annemasse St	1.59
8/20/2020	31	4300 Block of Cedar St	2.27
8/20/2020	60	1300 Block of Calle San Marcos	2.42
8/20/2020	74	7900 Block of Impala Dr	1.99
8/20/2020	11	500 Block of Military Dr	2.26
8/20/2020	98	15800 Block of Almeria Ave	2.36
8/20/2020	97	13900 Block of Skysail St	2.79
8/21/2020	92	300 Block of Wildwood Dr	3.16
8/21/2020	19	1300 Block of Horne Rd	2.99
8/21/2020	58	4800 Block of French Dr	2.68
8/21/2020	35	4700 Block of Congressional Dr	3.48
8/21/2020	80	7000 Block of Arapahoe St	3.38
8/21/2020	38	7500 Block of Annemasse St	2.94
8/21/2020	16	4200 Block of Wildcat Dr	3.17
8/21/2020	96	14900 Block of Windward Dr	2.30
8/22/2020	16	4200 Block of Wildcat Dr	3.27
8/22/2020	14	900 Block of Rosedale Dr	2.82
8/22/2020	99	3900 Block of Elvis Dr	2.55
8/22/2020	96	14900 Block of Windward Dr	2.61

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/23/2020	87	5200 Block of Northwest Trl	2.92
8/23/2020	55	500 Block of Belden St	2.88
8/23/2020	82	2100 Block of Whispering Oak Dr	2.73
8/23/2020	95	15800 Block of El Socorro Loop	2.03
8/24/2020	46	8900 Block of McNorton Rd	3.49
8/24/2020	57	1400 Block of Arlington Dr	2.85
8/24/2020	10	3100 Block of Saratoga Blvd	2.99
8/24/2020	34	4300 Block of Harry St	2.87
8/24/2020	77	5000 Block of Cape Ann Dr	2.56
8/24/2020	85	300 Block of Glenmore St	2.42
8/24/2020	43	200 Block of Caribbean Dr	2.68
8/24/2020	76	1100 Block of Harbor Lights Dr	2.54
8/24/2020	97	13900 Block of Skysail St	2.50
8/24/2020	40	9500 Block of Quetzal St	2.41
8/24/2020	83	4100 Block of Summit Dr	2.35
8/25/2020	85	300 Block of Glenmore St	2.61
8/25/2020	31	4300 Block of Cedar St	2.84
8/25/2020	93	11000 Block of Annville Rd	3.93
8/25/2020	60	1300 Block of Calle San Marcos	2.70
8/25/2020	51	200 Block of Gibson Ln	3.35
8/25/2020	11	500 Block of Military Dr	2.06
8/25/2020	12	2200 Block of Buford Ave	3.53
8/25/2020	54	3700 Block of Seagull Blvd	2.61
8/25/2020	97	13900 Block of Skysail St	2.63
8/26/2020	77	5000 Block of Cape Ann Dr	2.72
8/26/2020	68	5300 Block of Alejandro St	3.24
8/26/2020	90	11700 Block of Haven Dr	3.15

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/26/2020	85	300 Block of Glenmore St	2.68
8/26/2020	47	8100 Block of Barrogate Dr	3.85
8/26/2020	71	5500 Block of Fox Run Dr	3.09
8/26/2020	76	1100 Block of Harbor Lights Dr	2.85
8/26/2020	50	5500 Block of IH 37 Access Rd	3.52
8/26/2020	40	9500 Block of Quetzal St	2.75
8/26/2020	36	1300 Block of Sandstone Dr	2.80
8/26/2020	14	900 Block of Rosedale Dr	3.17
8/26/2020	83	4100 Block of Summit Dr	2.33
8/26/2020	45	15200 Block of Cruiser St	3.06
8/27/2020	16	4200 Block of Wildcat Dr	3.39
8/27/2020	62	5800 Block of Hampshire Rd	3.34
8/27/2020	1	4800 Block of Neptune St	3.43
8/27/2020	44	9600 Block of Wilkins Dr	3.75
8/27/2020	18	900 Block of Nueces Bay Blvd	3.49
8/27/2020	48	1200 Block of Southern Minerals Rd	3.84
8/27/2020	55	500 Block of Belden St	3.08
8/27/2020	2	5800 Block of St. Andrews Dr	3.20
8/27/2020	25	4100 Block of Bascule Dr	3.29
8/27/2020	39	5900 Block of Long Creek Dr	3.02
8/27/2020	72	7700 Block of Starnberg Lake Dr	3.07
8/27/2020	33	3900 Block of Ocean Dr	3.11
8/27/2020	24	2300 Block of Rodd Field Rd	3.14
8/27/2020	43	200 Block of Caribbean Dr	3.08
8/27/2020	95	15800 Block of El Socorro Loop	2.04
8/27/2020	94	15200 Block of Caravel Dr	2.64
8/28/2020	10	3100 Block of Saratoga Blvd	2.85

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/28/2020	88	4200 Block of Western Dr	3.74
8/28/2020	37	6500 Block of Brockhampton St	2.73
8/28/2020	53	9100 Block of Stock Dr	2.85
8/28/2020	67	500 Block of S Carancahua St	3.14
8/28/2020	5	4600 Block of Evelyn St	2.99
8/28/2020	81	6600 Block of Meadowheights Dr	2.98
8/28/2020	75	2900 Block of Oso Pkwy	3.15
8/28/2020	41	1600 Block of Amber Dr	2.75
8/28/2020	94	15200 Block of Caravel Dr	2.95
8/29/2020	93	11000 Block of Annville Rd	3.75
8/29/2020	25	4100 Block of Bascule Dr	3.02
8/29/2020	38	7500 Block of Annemasse St	2.81
8/29/2020	98	15800 Block of Almeria Ave	2.50
8/30/2020	86	14800 Block of Santa Gertrudis Dr	2.78
8/30/2020	26	200 Block of Eastgate Dr	3.08
8/30/2020	8	1100 Block of Cornerstone Dr	2.66
8/30/2020	97	13900 Block of Skysail St	3.00
8/31/2020	77	5000 Block of Cape Ann Dr	2.51
8/31/2020	85	300 Block of Glenmore St	2.53
8/31/2020	88	4200 Block of Western Dr	3.68
8/31/2020	76	1100 Block of Harbor Lights Dr	2.56
8/31/2020	29	1600 Block of La Joya St	2.97
8/31/2020	40	9500 Block of Quetzal St	2.32
8/31/2020	58	4800 Block of French Dr	2.87
8/31/2020	83	4100 Block of Summit Dr	2.31
8/31/2020	4	14200 Block of Playa del Rey	2.70

September

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/1/2020	88	4200 Block of Western Dr	3.40
9/1/2020	53	9100 Block of Stock Dr	2.51
9/1/2020	67	500 Block of S Carancahua St	2.74
9/1/2020	5	4600 Block of Evelyn St	2.48
9/1/2020	81	6600 Block of Meadowheights Dr	2.51
9/1/2020	75	2900 Block of Oso Pkwy	2.41
9/1/2020	41	1600 Block of Amber Dr	2.29
9/1/2020	94	15200 Block of Caravel Dr	2.42
9/2/2020	89	3800 Block of Castle Ridge Dr	2.80
9/2/2020	27	2800 Block of S Port Ave	3.04
9/2/2020	91	2700 Block of Wind Rock Dr	2.90
9/2/2020	49	100 Block of Commerce St	2.94
9/2/2020	6	1200 Block of 10th St	2.83
9/2/2020	9	1000 Block of International Dr	2.83
9/2/2020	20	3900 Block of Cott St	2.80
9/2/2020	28	1700 Block of Bois d' Arc Pl	2.97
9/2/2020	77	5000 Block of Cape Ann Dr	2.30
9/2/2020	22	6700 Block of Weber Rd	2.95
9/2/2020	32	4900 Block of Hakel Dr	2.76
9/2/2020	59	3600 Block of Capri Dr	2.66
9/2/2020	85	300 Block of Glenmore St	2.29
9/2/2020	21	900 Block of Lum Ave	2.45
9/2/2020	99	3900 Block of Elvis Dr	2.39
9/2/2020	58	4800 Block of French Dr	2.63

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/2/2020	76	1100 Block of Harbor Lights Dr	2.29
9/2/2020	42	700 Block of Orleans Dr	2.46
9/2/2020	84	3600 Block of Flour Bluff Dr	2.66
9/2/2020	40	9500 Block of Quetzal St	2.20
9/2/2020	98	15800 Block of Almeria Ave	2.10
9/2/2020	45	15200 Block of Cruiser St	2.78
9/2/2020	95	15800 Block of El Socorro Loop	2.09
9/2/2020	83	4100 Block of Summit Dr	2.12
9/2/2020	4	14200 Block of Playa del Rey	2.71
9/3/2020	90	11700 Block of Haven Dr	2.91
9/3/2020	56	200 Block of Amistad St	2.59
9/3/2020	93	11000 Block of Annville Rd	3.65
9/3/2020	30	3100 Block of Brawner Pkwy	2.50
9/3/2020	51	200 Block of Gibson Ln	2.96
9/3/2020	59	3600 Block of Capri Dr	2.44
9/3/2020	12	2200 Block of Buford Ave	2.83
9/3/2020	54	3700 Block of Seagull Blvd	2.36
9/3/2020	7	600 Block of Carmel Pkwy	2.52
9/3/2020	31	4300 Block of Cedar St	2.65
9/3/2020	79	900 Block of Egyptian Dr	2.33
9/3/2020	60	1300 Block of Calle San Marcos	2.41
9/3/2020	11	500 Block of Military Dr	2.04
9/3/2020	82	2100 Block of Whispering Oak Dr	2.36
9/3/2020	97	13900 Block of Skysail St	2.69
9/3/2020	98	15800 Block of Almeria Ave	2.06
9/4/2020	90	11700 Block of Haven Dr	3.13
9/4/2020	47	8100 Block of Barrogate Dr	3.52

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/4/2020	50	5500 Block of IH 37 Access Rd	3.33
9/4/2020	14	900 Block of Rosedale Dr	2.86
9/4/2020	68	5300 Block of Alejandro St	2.62
9/4/2020	71	5500 Block of Fox Run Dr	2.69
9/4/2020	36	1300 Block of Sandstone Dr	2.35
9/4/2020	45	15200 Block of Cruiser St	2.58
9/5/2020	99	3900 Block of Elvis Dr	2.43
9/5/2020	96	14900 Block of Windward Dr	2.07
9/5/2020	14	900 Block of Rosedale Dr	2.57
9/5/2020	16	4200 Block of Wildcat Dr	3.21
9/6/2020	82	2100 Block of Whispering Oak Dr	2.63
9/6/2020	95	15800 Block of El Socorro Loop	1.76
9/6/2020	55	500 Block of Belden St	2.64
9/6/2020	87	5200 Block of Northwest Trl	3.12
9/7/2020	91	2700 Block of Wind Rock Dr	3.38
9/7/2020	69	4000 Block of Donaho Dr	2.96
9/7/2020	78	7600 Block of Timber Crest Dr	2.77
9/7/2020	64	4000 Block of Hidalgo St	3.27
9/7/2020	74	7900 Block of Impala Dr	2.56
9/7/2020	66	600 Block of Southern St	3.11
9/7/2020	4	14200 Block of Playa del Rey	2.68
9/7/2020	98	15800 Block of Almeria Ave	2.25
9/8/2020	29	1600 Block of La Joya St	3.05
9/8/2020	86	14800 Block of Santa Gertrudis Dr	3.25
9/8/2020	23	5500 Block of Wooldridge Rd	2.85
9/8/2020	65	700 Block of Westchester Dr	3.18
9/8/2020	3	3000 Block of S Fork Dr	3.10

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/8/2020	13	1500 Block of 6th St	3.09
9/8/2020	4	14200 Block of Playa del Rey	2.46
9/8/2020	52	200 Block of Junior Beck Dr	3.07
9/9/2020	92	300 Block of Wildwood Dr	3.63
9/9/2020	19	1300 Block of Horne Rd	3.20
9/9/2020	58	4800 Block of French Dr	3.00
9/9/2020	77	5000 Block of Cape Ann Dr	2.46
9/9/2020	87	5200 Block of Northwest Trl	3.31
9/9/2020	85	300 Block of Glenmore St	2.51
9/9/2020	76	1100 Block of Harbor Lights Dr	2.67
9/9/2020	35	4700 Block of Congressional Dr	3.10
9/9/2020	15	6100 Block of Parkway Dr	2.94
9/9/2020	40	9500 Block of Quetzal St	2.51
9/9/2020	80	7000 Block of Arapahoe St	3.02
9/9/2020	26	200 Block of Eastgate Dr	3.22
9/9/2020	70	1600 Block of E Manor Dr	3.00
9/9/2020	83	4100 Block of Summit Dr	2.45
9/9/2020	61	200 Block of Saratoga Blvd	3.50
9/9/2020	38	7500 Block of Annemasse St	3.06
9/9/2020	8	1100 Block of Cornerstone Dr	2.40
9/9/2020	73	5600 Block of King Acres Dr	3.68
9/9/2020	96	14900 Block of Windward Dr	2.34
9/9/2020	96	14900 Block of Windward Dr	2.42
9/10/2020	46	8900 Block of McNorton Rd	3.47
9/10/2020	57	1400 Block of Arlington Dr	2.82
9/10/2020	10	3100 Block of Saratoga Blvd	2.95
9/10/2020	34	4300 Block of Harry St	2.93

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/10/2020	55	500 Block of Belden St	3.10
9/10/2020	16	4200 Block of Wildcat Dr	3.52
9/10/2020	37	6500 Block of Brockhampton St	2.93
9/10/2020	39	5900 Block of Long Creek Dr	3.03
9/10/2020	24	2300 Block of Rodd Field Rd	3.03
9/10/2020	62	5800 Block of Hampshire Rd	3.35
9/10/2020	43	200 Block of Caribbean Dr	2.96
9/10/2020	1	4800 Block of Neptune St	3.39
9/10/2020	94	15200 Block of Caravel Dr	2.44
9/10/2020	97	13900 Block of Skysail St	2.79
9/10/2020	18	900 Block of Nueces Bay Blvd	3.30
9/11/2020	44	9600 Block of Wilkins Dr	3.69
9/11/2020	48	1200 Block of Southern Minerals Rd	3.61
9/11/2020	77	5000 Block of Cape Ann Dr	2.72
9/11/2020	25	4100 Block of Bascule Dr	3.06
9/11/2020	85	300 Block of Glenmore St	2.65
9/11/2020	76	1100 Block of Harbor Lights Dr	3.13
9/11/2020	33	3900 Block of Ocean Dr	3.04
9/11/2020	40	9500 Block of Quetzal St	2.86
9/11/2020	2	5800 Block of St. Andrews Dr	2.86
9/11/2020	83	4100 Block of Summit Dr	2.63
9/11/2020	72	7700 Block of Starnberg Lake Dr	3.17
9/11/2020	95	15800 Block of El Socorro Loop	2.79
9/12/2020	93	11000 Block of Annville Rd	3.88
9/12/2020	25	4100 Block of Bascule Dr	3.06
9/12/2020	38	7500 Block of Annemasse St	3.09
9/12/2020	98	15800 Block of Almeria Ave	2.46

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/13/2020	86	14800 Block of Santa Gertrudis Dr	3.39
9/13/2020	26	200 Block of Eastgate Dr	3.22
9/13/2020	8	1100 Block of Cornerstone Dr	2.55
9/13/2020	97	13900 Block of Skysail St	3.06
9/14/2020	89	3800 Block of Castle Ridge Dr	3.57
9/14/2020	27	2800 Block of S Port Ave	3.61
9/14/2020	6	1200 Block of 10th St	3.45
9/14/2020	20	3900 Block of Cott St	3.46
9/14/2020	77	5000 Block of Cape Ann Dr	2.81
9/14/2020	22	6700 Block of Weber Rd	3.48
9/14/2020	85	300 Block of Glenmore St	2.79
9/14/2020	76	1100 Block of Harbor Lights Dr	2.80
9/14/2020	40	9500 Block of Quetzal St	2.81
9/14/2020	83	4100 Block of Summit Dr	2.44
9/14/2020	99	3900 Block of Elvis Dr	2.96
9/14/2020	84	3600 Block of Flour Bluff Dr	3.53
9/14/2020	4	14200 Block of Playa del Rey	2.67
9/15/2020	91	2700 Block of Wind Rock Dr	3.61
9/15/2020	49	100 Block of Commerce St	3.48
9/15/2020	9	1000 Block of International Dr	3.36
9/15/2020	28	1700 Block of Bois d' Arc Pl	3.57
9/15/2020	32	4900 Block of Hakel Dr	3.41
9/15/2020	21	900 Block of Lum Ave	3.15
9/15/2020	42	700 Block of Orleans Dr	3.51
9/15/2020	45	15200 Block of Cruiser St	2.96
9/16/2020	90	11700 Block of Haven Dr	3.64
9/16/2020	93	11000 Block of Annville Rd	4.08

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/16/2020	56	200 Block of Amistad St	3.33
9/16/2020	51	200 Block of Gibson Ln	3.68
9/16/2020	30	3100 Block of Brawner Pkwy	3.22
9/16/2020	12	2200 Block of Buford Ave	3.61
9/16/2020	59	3600 Block of Capri Dr	3.46
9/16/2020	54	3700 Block of Seagull Blvd	2.92
9/16/2020	7	600 Block of Carmel Pkwy	3.23
9/16/2020	79	900 Block of Egyptian Dr	3.21
9/16/2020	77	5000 Block of Cape Ann Dr	3.04
9/16/2020	85	300 Block of Glenmore St	2.99
9/16/2020	31	4300 Block of Cedar St	3.18
9/16/2020	76	1100 Block of Harbor Lights Dr	3.12
9/16/2020	82	2100 Block of Whispering Oak Dr	3.45
9/16/2020	60	1300 Block of Calle San Marcos	3.23
9/16/2020	40	9500 Block of Quetzal St	3.03
9/16/2020	83	4100 Block of Summit Dr	2.98
9/16/2020	11	500 Block of Military Dr	2.75
9/16/2020	98	15800 Block of Almeria Ave	2.73
9/16/2020	97	13900 Block of Skysail St	3.38
9/17/2020	16	4200 Block of Wildcat Dr	3.86
9/17/2020	90	11700 Block of Haven Dr	3.37
9/17/2020	61	200 Block of Saratoga Blvd	3.54
9/17/2020	47	8100 Block of Barrogate Dr	3.77
9/17/2020	50	5500 Block of IH 37 Access Rd	3.64
9/17/2020	26	200 Block of Eastgate Dr	3.38
9/17/2020	14	900 Block of Rosedale Dr	3.24
9/17/2020	80	7000 Block of Arapahoe St	3.31

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/17/2020	68	5300 Block of Alejandro St	3.20
9/17/2020	38	7500 Block of Annemasse St	3.53
9/17/2020	71	5500 Block of Fox Run Dr	3.16
9/17/2020	36	1300 Block of Sandstone Dr	3.17
9/17/2020	96	14900 Block of Windward Dr	3.18
9/17/2020	45	15200 Block of Cruiser St	2.84
9/18/2020	86	14800 Block of Santa Gertrudis Dr	3.40
9/18/2020	65	700 Block of Westchester Dr	3.47
9/18/2020	13	1500 Block of 6th St	3.02
9/18/2020	52	200 Block of Junior Beck Dr	3.67
9/18/2020	29	1600 Block of La Joya St	3.43
9/18/2020	23	5500 Block of Wooldridge Rd	3.42
9/18/2020	3	3000 Block of S Fork Dr	3.49
9/18/2020	4	14200 Block of Playa del Rey	3.21
9/19/2020	16	4200 Block of Wildcat Dr	3.78
9/19/2020	14	900 Block of Rosedale Dr	2.94
9/19/2020	99	3900 Block of Elvis Dr	2.92
9/19/2020	96	14900 Block of Windward Dr	2.79
9/20/2020	87	5200 Block of Northwest Trl	3.67
9/20/2020	55	500 Block of Belden St	3.36
9/20/2020	82	2100 Block of Whispering Oak Dr	3.20
9/20/2020	95	15800 Block of El Socorro Loop	2.90
9/21/2020	69	4000 Block of Donaho Dr	3.54
9/21/2020	77	5000 Block of Cape Ann Dr	2.92
9/21/2020	85	300 Block of Glenmore St	2.86
9/21/2020	78	7600 Block of Timber Crest Dr	3.31
9/21/2020	91	2700 Block of Wind Rock Dr	3.79

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/21/2020	76	1100 Block of Harbor Lights Dr	2.94
9/21/2020	40	9500 Block of Quetzal St	2.92
9/21/2020	74	7900 Block of Impala Dr	3.23
9/21/2020	64	4000 Block of Hidalgo St	3.63
9/21/2020	83	4100 Block of Summit Dr	2.79
9/21/2020	66	600 Block of Southern St	3.52
9/21/2020	98	15800 Block of Almeria Ave	2.83
9/22/2020	35	4700 Block of Congressional Dr	3.61
9/22/2020	92	300 Block of Wildwood Dr	4.04
9/22/2020	80	7000 Block of Arapahoe St	3.15
9/22/2020	19	1300 Block of Horne Rd	3.56
9/22/2020	38	7500 Block of Annemasse St	3.19
9/22/2020	58	4800 Block of French Dr	3.29
9/22/2020	96	14900 Block of Windward Dr	2.78
9/23/2020	77	5000 Block of Cape Ann Dr	3.03
9/23/2020	37	6500 Block of Brockhampton St	3.14
9/23/2020	46	8900 Block of McNorton Rd	3.81
9/23/2020	85	300 Block of Glenmore St	2.89
9/23/2020	43	200 Block of Caribbean Dr	3.04
9/23/2020	76	1100 Block of Harbor Lights Dr	3.25
9/23/2020	57	1400 Block of Arlington Dr	3.22
9/23/2020	40	9500 Block of Quetzal St	2.85
9/23/2020	10	3100 Block of Saratoga Blvd	3.39
9/23/2020	97	13900 Block of Skysail St	2.87
9/23/2020	83	4100 Block of Summit Dr	2.83
9/23/2020	34	4300 Block of Harry St	3.31
9/24/2020	81	6600 Block of Meadowheights Dr	3.46

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/24/2020	64	4000 Block of Hidalgo St	3.53
9/24/2020	88	4200 Block of Western Dr	3.97
9/24/2020	75	2900 Block of Oso Pkwy	3.27
9/24/2020	53	9100 Block of Stock Dr	3.25
9/24/2020	66	600 Block of Southern St	3.35
9/24/2020	41	1600 Block of Amber Dr	3.19
9/24/2020	67	500 Block of S Carancahua St	3.51
9/24/2020	69	4000 Block of Donaho Dr	3.34
9/24/2020	78	7600 Block of Timber Crest Dr	3.48
9/24/2020	5	4600 Block of Evelyn St	3.27
9/24/2020	94	15200 Block of Caravel Dr	2.80
9/24/2020	74	7900 Block of Impala Dr	3.36
9/25/2020	44	9600 Block of Wilkins Dr	3.65
9/25/2020	48	1200 Block of Southern Minerals Rd	3.79
9/25/2020	25	4100 Block of Bascule Dr	3.33
9/25/2020	33	3900 Block of Ocean Dr	3.23
9/25/2020	2	5800 Block of St. Andrews Dr	3.13
9/25/2020	72	7700 Block of Starnberg Lake Dr	3.45
9/25/2020	95	15800 Block of El Socorro Loop	2.67
9/26/2020	93	11000 Block of Annville Rd	4.15
9/26/2020	25	4100 Block of Bascule Dr	3.38
9/26/2020	38	7500 Block of Annemasse St	3.34
9/26/2020	98	15800 Block of Almeria Ave	2.72
9/27/2020	86	14800 Block of Santa Gertrudis Dr	3.42
9/27/2020	26	200 Block of Eastgate Dr	3.54
9/27/2020	8	1100 Block of Cornerstone Dr	3.01
9/27/2020	97	13900 Block of Skysail St	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/28/2020	87	5200 Block of Northwest Trl	3.61
9/28/2020	26	200 Block of Eastgate Dr	3.36
9/28/2020	61	200 Block of Saratoga Blvd	3.60
9/28/2020	73	5600 Block of King Acres Dr	3.97
9/28/2020	15	6100 Block of Parkway Dr	3.39
9/28/2020	77	5000 Block of Cape Ann Dr	3.11
9/28/2020	85	300 Block of Glenmore St	3.09
9/28/2020	70	1600 Block of E Manor Dr	3.21
9/28/2020	76	1100 Block of Harbor Lights Dr	3.22
9/28/2020	8	1100 Block of Cornerstone Dr	3.05
9/28/2020	40	9500 Block of Quetzal St	3.13
9/28/2020	96	14900 Block of Windward Dr	2.69
9/28/2020	83	4100 Block of Summit Dr	2.89
9/29/2020	16	4200 Block of Wildcat Dr	3.59
9/29/2020	62	5800 Block of Hampshire Rd	3.60
9/29/2020	1	4800 Block of Neptune St	3.58
9/29/2020	18	900 Block of Nueces Bay Blvd	3.62
9/29/2020	55	500 Block of Belden St	3.40
9/29/2020	39	5900 Block of Long Creek Dr	3.35
9/29/2020	24	2300 Block of Rodd Field Rd	3.45
9/29/2020	94	15200 Block of Caravel Dr	2.78
9/30/2020	88	4200 Block of Western Dr	4.09
9/30/2020	77	5000 Block of Cape Ann Dr	3.11
9/30/2020	29	1600 Block of La Joya St	3.27
9/30/2020	85	300 Block of Glenmore St	3.09
9/30/2020	58	4800 Block of French Dr	3.38
9/30/2020	76	1100 Block of Harbor Lights Dr	3.27

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/30/2020	4	14200 Block of Playa del Rey	3.29
9/30/2020	40	9500 Block of Quetzal St	3.34
9/30/2020	83	4100 Block of Summit Dr	3.17

October

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/1/2020	88	4200 Block of Western Dr	4.06
10/1/2020	53	9100 Block of Stock Dr	3.88
10/1/2020	67	500 Block of S Carancahua St	3.85
10/1/2020	5	4600 Block of Evelyn St	2.81
10/1/2020	81	6600 Block of Meadowheights Dr	3.94
10/1/2020	75	2900 Block of Oso Pkwy	3.15
10/1/2020	41	1600 Block of Amber Dr	3.02
10/1/2020	94	15200 Block of Caravel Dr	3.17
10/2/2020	44	9600 Block of Wilkins Dr	3.71
10/2/2020	48	1200 Block of Southern Minerals Rd	3.58
10/2/2020	25	4100 Block of Bascule Dr	3.85
10/2/2020	33	3900 Block of Ocean Dr	3.57
10/2/2020	2	5800 Block of St. Andrews Dr	3.99
10/2/2020	72	7700 Block of Starnberg Lake Dr	3.91
10/2/2020	95	15800 Block of El Socorro Loop	2.75
10/3/2020	93	11000 Block of Annville Rd	3.87
10/3/2020	25	4100 Block of Bascule Dr	3.74
10/3/2020	38	7500 Block of Annemasse St	3.67
10/3/2020	98	15800 Block of Almeria Ave	3.22
10/4/2020	86	14800 Block of Santa Gertrudis Dr	3.75

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/4/2020	26	200 Block of Eastgate Dr	3.65
10/4/2020	8	1100 Block of Cornerstone Dr	3.41
10/4/2020	97	13900 Block of Skysail St	4.01
10/5/2020	77	5000 Block of Cape Ann Dr	2.98
10/5/2020	89	3800 Block of Castle Ridge Dr	3.33
10/5/2020	85	300 Block of Glenmore St	3.26
10/5/2020	22	6700 Block of Weber Rd	3.80
10/5/2020	76	1100 Block of Harbor Lights Dr	3.39
10/5/2020	99	3900 Block of Elvis Dr	3.53
10/5/2020	27	2800 Block of S Port Ave	3.71
10/5/2020	40	9500 Block of Quetzal St	3.31
10/5/2020	84	3600 Block of Flour Bluff Dr	3.94
10/5/2020	6	1200 Block of 10th St	3.78
10/5/2020	83	4100 Block of Summit Dr	3.27
10/5/2020	4	14200 Block of Playa del Rey	3.89
10/5/2020	20	3900 Block of Cott St	3.78
10/6/2020	88	4200 Block of Western Dr	3.89
10/6/2020	29	1600 Block of La Joya St	4.12
10/6/2020	58	4800 Block of French Dr	3.55
10/6/2020	4	14200 Block of Playa del Rey	3.80
10/7/2020	90	11700 Block of Haven Dr	4.00
10/7/2020	77	5000 Block of Cape Ann Dr	3.32
10/7/2020	7	600 Block of Carmel Pkwy	3.55
10/7/2020	85	300 Block of Glenmore St	3.29
10/7/2020	59	3600 Block of Capri Dr	3.63
10/7/2020	76	1100 Block of Harbor Lights Dr	3.48
10/7/2020	79	900 Block of Egyptian Dr	3.54

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/7/2020	56	200 Block of Amistad St	3.51
10/7/2020	58	4800 Block of French Dr	3.49
10/7/2020	40	9500 Block of Quetzal St	3.38
10/7/2020	82	2100 Block of Whispering Oak Dr	3.88
10/7/2020	30	3100 Block of Brawner Pkwy	3.42
10/7/2020	98	15800 Block of Almeria Ave	3.24
10/7/2020	83	4100 Block of Summit Dr	3.46
10/7/2020	95	15800 Block of El Socorro Loop	3.06
10/7/2020	98	15800 Block of Almeria Ave	3.31
10/7/2020	59	3600 Block of Capri Dr	3.73
10/8/2020	32	4900 Block of Hakel Dr	3.40
10/8/2020	60	1300 Block of Calle San Marcos	3.48
10/8/2020	91	2700 Block of Wind Rock Dr	3.57
10/8/2020	93	11000 Block of Annville Rd	3.59
10/8/2020	21	900 Block of Lum Ave	3.25
10/8/2020	49	100 Block of Commerce St	3.77
10/8/2020	31	4300 Block of Cedar St	3.27
10/8/2020	51	200 Block of Gibson Ln	3.80
10/8/2020	42	700 Block of Orleans Dr	3.52
10/8/2020	9	1000 Block of International Dr	3.59
10/8/2020	11	500 Block of Military Dr	3.16
10/8/2020	12	2200 Block of Buford Ave	3.56
10/8/2020	28	1700 Block of Bois d' Arc Pl	3.49
10/8/2020	45	15200 Block of Cruiser St	3.45
10/8/2020	54	3700 Block of Seagull Blvd	3.12
10/8/2020	97	13900 Block of Skysail St	3.55
10/9/2020	46	8900 Block of McNorton Rd	3.68

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/9/2020	57	1400 Block of Arlington Dr	3.27
10/9/2020	10	3100 Block of Saratoga Blvd	3.26
10/9/2020	34	4300 Block of Harry St	3.59
10/9/2020	37	6500 Block of Brockhampton St	3.61
10/9/2020	43	200 Block of Caribbean Dr	3.56
10/9/2020	97	13900 Block of Skysail St	3.73
10/10/2020	16	4200 Block of Wildcat Dr	4.09
10/10/2020	14	900 Block of Rosedale Dr	3.42
10/10/2020	99	3900 Block of Elvis Dr	3.51
10/10/2020	96	14900 Block of Windward Dr	3.65
10/11/2020	87	5200 Block of Northwest Trl	3.79
10/11/2020	55	500 Block of Belden St	3.51
10/11/2020	82	2100 Block of Whispering Oak Dr	3.76
10/11/2020	95	15800 Block of El Socorro Loop	3.17
10/12/2020	86	14800 Block of Santa Gertrudis Dr	3.36
10/12/2020	65	700 Block of Westchester Dr	3.19
10/12/2020	13	1500 Block of 6th St	3.05
10/12/2020	52	200 Block of Junior Beck Dr	3.56
10/12/2020	77	5000 Block of Cape Ann Dr	3.26
10/12/2020	85	300 Block of Glenmore St	3.17
10/12/2020	29	1600 Block of La Joya St	3.43
10/12/2020	76	1100 Block of Harbor Lights Dr	3.39
10/12/2020	23	5500 Block of Wooldridge Rd	3.44
10/12/2020	3	3000 Block of S Fork Dr	3.70
10/12/2020	40	9500 Block of Quetzal St	3.33
10/12/2020	4	14200 Block of Playa del Rey	3.79
10/12/2020	83	4100 Block of Summit Dr	3.24

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/13/2020	87	5200 Block of Northwest Trl	3.66
10/13/2020	26	200 Block of Eastgate Dr	3.24
10/13/2020	61	200 Block of Saratoga Blvd	3.65
10/13/2020	73	5600 Block of King Acres Dr	3.89
10/13/2020	15	6100 Block of Parkway Dr	3.52
10/13/2020	70	1600 Block of E Manor Dr	3.47
10/13/2020	8	1100 Block of Cornerstone Dr	3.57
10/13/2020	96	14900 Block of Windward Dr	3.85
10/14/2020	16	4200 Block of Wildcat Dr	3.91
10/14/2020	77	5000 Block of Cape Ann Dr	2.95
10/14/2020	85	300 Block of Glenmore St	2.84
10/14/2020	62	5800 Block of Hampshire Rd	3.12
10/14/2020	76	1100 Block of Harbor Lights Dr	3.23
10/14/2020	1	4800 Block of Neptune St	3.72
10/14/2020	40	9500 Block of Quetzal St	3.09
10/14/2020	18	900 Block of Nueces Bay Blvd	3.39
10/14/2020	83	4100 Block of Summit Dr	2.93
10/14/2020	55	500 Block of Belden St	3.31
10/14/2020	39	5900 Block of Long Creek Dr	3.48
10/14/2020	24	2300 Block of Rodd Field Rd	3.28
10/14/2020	94	15200 Block of Caravel Dr	3.42
10/15/2020	88	4200 Block of Western Dr	3.33
10/15/2020	53	9100 Block of Stock Dr	3.34
10/15/2020	91	2700 Block of Wind Rock Dr	3.27
10/15/2020	67	500 Block of S Carancahua St	3.40
10/15/2020	64	4000 Block of Hidalgo St	3.68
10/15/2020	5	4600 Block of Evelyn St	2.76

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/15/2020	66	600 Block of Southern St	3.57
10/15/2020	81	6600 Block of Meadowheights Dr	3.50
10/15/2020	69	4000 Block of Donaho Dr	3.71
10/15/2020	75	2900 Block of Oso Pkwy	2.82
10/15/2020	78	7600 Block of Timber Crest Dr	3.36
10/15/2020	41	1600 Block of Amber Dr	2.84
10/15/2020	74	7900 Block of Impala Dr	3.23
10/15/2020	94	15200 Block of Caravel Dr	2.99
10/15/2020	98	15800 Block of Almeria Ave	3.15
10/16/2020	92	300 Block of Wildwood Dr	3.53
10/16/2020	19	1300 Block of Horne Rd	3.36
10/16/2020	58	4800 Block of French Dr	3.24
10/16/2020	35	4700 Block of Congressional Dr	3.52
10/16/2020	80	7000 Block of Arapahoe St	3.37
10/16/2020	38	7500 Block of Annemasse St	3.42
10/16/2020	96	14900 Block of Windward Dr	2.54
10/17/2020	98	15800 Block of Almeria Ave	2.60
10/17/2020	38	7500 Block of Annemasse St	3.41
10/17/2020	25	4100 Block of Bascule Dr	3.13
10/17/2020	93	11000 Block of Annville Rd	3.98
10/18/2020	86	14800 Block of Santa Gertrudis Dr	3.09
10/18/2020	26	200 Block of Eastgate Dr	3.26
10/18/2020	8	1100 Block of Cornerstone Dr	3.05
10/18/2020	97	13900 Block of Skysail St	3.14
10/19/2020	89	3800 Block of Castle Ridge Dr	3.00
10/19/2020	27	2800 Block of S Port Ave	3.26
10/19/2020	6	1200 Block of 10th St	2.88

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/19/2020	20	3900 Block of Cott St	3.18
10/19/2020	77	5000 Block of Cape Ann Dr	2.91
10/19/2020	22	6700 Block of Weber Rd	3.26
10/19/2020	85	300 Block of Glenmore St	2.68
10/19/2020	76	1100 Block of Harbor Lights Dr	2.93
10/19/2020	99	3900 Block of Elvis Dr	2.98
10/19/2020	40	9500 Block of Quetzal St	2.84
10/19/2020	83	4100 Block of Summit Dr	2.79
10/19/2020	84	3600 Block of Flour Bluff Dr	3.34
10/19/2020	4	14200 Block of Playa del Rey	2.84
10/20/2020	90	11700 Block of Haven Dr	2.86
10/20/2020	68	5300 Block of Alejandro St	3.28
10/20/2020	47	8100 Block of Barrogate Dr	3.34
10/20/2020	71	5500 Block of Fox Run Dr	3.04
10/20/2020	36	1300 Block of Sandstone Dr	2.95
10/20/2020	50	5500 Block of IH 37 Access Rd	3.60
10/20/2020	45	15200 Block of Cruiser St	2.70
10/20/2020	14	900 Block of Rosedale Dr	3.06
10/21/2020	44	9600 Block of Wilkins Dr	3.61
10/21/2020	48	1200 Block of Southern Minerals Rd	3.84
10/21/2020	91	2700 Block of Wind Rock Dr	3.39
10/21/2020	49	100 Block of Commerce St	3.63
10/21/2020	2	5800 Block of St. Andrews Dr	3.43
10/21/2020	9	1000 Block of International Dr	3.39
10/21/2020	25	4100 Block of Bascule Dr	3.39
10/21/2020	77	5000 Block of Cape Ann Dr	2.97
10/21/2020	28	1700 Block of Bois d' Arc Pl	3.37

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/21/2020	85	300 Block of Glenmore St	2.73
10/21/2020	72	7700 Block of Starnberg Lake Dr	3.54
10/21/2020	32	4900 Block of Hakel Dr	3.38
10/21/2020	76	1100 Block of Harbor Lights Dr	2.99
10/21/2020	40	9500 Block of Quetzal St	2.88
10/21/2020	21	900 Block of Lum Ave	3.18
10/21/2020	33	3900 Block of Ocean Dr	3.25
10/21/2020	95	15800 Block of El Socorro Loop	2.37
10/21/2020	83	4100 Block of Summit Dr	2.61
10/21/2020	42	700 Block of Orleans Dr	3.14
10/21/2020	45	15200 Block of Cruiser St	3.31
10/22/2020	90	11700 Block of Haven Dr	3.33
10/22/2020	93	11000 Block of Annville Rd	3.99
10/22/2020	51	200 Block of Gibson Ln	3.85
10/22/2020	56	200 Block of Amistad St	3.19
10/22/2020	12	2200 Block of Buford Ave	3.56
10/22/2020	30	3100 Block of Brawner Pkwy	3.05
10/22/2020	59	3600 Block of Capri Dr	3.42
10/22/2020	54	3700 Block of Seagull Blvd	2.99
10/22/2020	7	600 Block of Carmel Pkwy	3.14
10/22/2020	31	4300 Block of Cedar St	3.14
10/22/2020	79	900 Block of Egyptian Dr	3.14
10/22/2020	60	1300 Block of Calle San Marcos	3.22
10/22/2020	11	500 Block of Military Dr	2.27
10/22/2020	82	2100 Block of Whispering Oak Dr	3.48
10/22/2020	97	13900 Block of Skysail St	3.05
10/22/2020	98	15800 Block of Almeria Ave	2.44

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/23/2020	90	11700 Block of Haven Dr	3.09
10/23/2020	47	8100 Block of Barrogate Dr	3.55
10/23/2020	50	5500 Block of IH 37 Access Rd	3.87
10/23/2020	50	5500 Block of IH 37 Access Rd	3.69
10/23/2020	14	900 Block of Rosedale Dr	3.36
10/23/2020	68	5300 Block of Alejandro St	3.40
10/23/2020	22	6700 Block of Weber Rd	3.46
10/23/2020	71	5500 Block of Fox Run Dr	3.46
10/23/2020	36	1300 Block of Sandstone Dr	3.26
10/23/2020	45	15200 Block of Cruiser St	2.48
10/24/2020	16	4200 Block of Wildcat Dr	3.93
10/24/2020	14	900 Block of Rosedale Dr	3.26
10/24/2020	99	3900 Block of Elvis Dr	3.12
10/24/2020	96	14900 Block of Windward Dr	2.54
10/25/2020	87	5200 Block of Northwest Trl	3.72
10/25/2020	55	500 Block of Belden St	3.38
10/25/2020	82	2100 Block of Whispering Oak Dr	3.85
10/25/2020	95	15800 Block of El Socorro Loop	2.50
10/26/2020	86	14800 Block of Santa Gertrudis Dr	3.52
10/26/2020	65	700 Block of Westchester Dr	3.43
10/26/2020	13	1500 Block of 6th St	3.47
10/26/2020	52	200 Block of Junior Beck Dr	3.48
10/26/2020	29	1600 Block of La Joya St	3.69
10/26/2020	77	5000 Block of Cape Ann Dr	3.05
10/26/2020	85	300 Block of Glenmore St	2.84
10/26/2020	23	5500 Block of Wooldridge Rd	3.61
10/26/2020	76	1100 Block of Harbor Lights Dr	3.27

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/26/2020	3	3000 Block of S Fork Dr	3.99
10/26/2020	40	9500 Block of Quetzal St	3.43
10/26/2020	4	14200 Block of Playa del Rey	3.35
10/26/2020	83	4100 Block of Summit Dr	3.38
10/27/2020	87	5200 Block of Northwest Trl	3.55
10/27/2020	26	200 Block of Eastgate Dr	3.33
10/27/2020	61	200 Block of Saratoga Blvd	3.72
10/27/2020	73	5600 Block of King Acres Dr	3.95
10/27/2020	15	6100 Block of Parkway Dr	3.43
10/27/2020	70	1600 Block of E Manor Dr	3.31
10/27/2020	3	3000 Block of S Fork Dr	3.63
10/27/2020	8	1100 Block of Cornerstone Dr	3.41
10/27/2020	96	14900 Block of Windward Dr	3.62
10/28/2020	16	4200 Block of Wildcat Dr	3.92
10/28/2020	62	5800 Block of Hampshire Rd	3.37
10/28/2020	1	4800 Block of Neptune St	3.78
10/28/2020	91	2700 Block of Wind Rock Dr	3.26
10/28/2020	18	900 Block of Nueces Bay Blvd	3.34
10/28/2020	55	500 Block of Belden St	3.13
10/28/2020	64	4000 Block of Hidalgo St	3.36
10/28/2020	66	600 Block of Southern St	3.28
10/28/2020	39	5900 Block of Long Creek Dr	3.39
10/28/2020	77	5000 Block of Cape Ann Dr	2.99
10/28/2020	24	2300 Block of Rodd Field Rd	3.36
10/28/2020	69	4000 Block of Donaho Dr	3.53
10/28/2020	85	300 Block of Glenmore St	2.82
10/28/2020	94	15200 Block of Caravel Dr	3.18

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/28/2020	76	1100 Block of Harbor Lights Dr	3.03
10/28/2020	78	7600 Block of Timber Crest Dr	3.34
10/28/2020	40	9500 Block of Quetzal St	3.01
10/28/2020	74	7900 Block of Impala Dr	3.36
10/28/2020	83	4100 Block of Summit Dr	3.12
10/28/2020	98	15800 Block of Almeria Ave	2.90
10/29/2020	46	8900 Block of McNorton Rd	3.46
10/29/2020	92	300 Block of Wildwood Dr	3.54
10/29/2020	57	1400 Block of Arlington Dr	3.28
10/29/2020	19	1300 Block of Horne Rd	3.51
10/29/2020	10	3100 Block of Saratoga Blvd	3.39
10/29/2020	58	4800 Block of French Dr	3.18
10/29/2020	35	4700 Block of Congressional Dr	3.72
10/29/2020	34	4300 Block of Harry St	3.13
10/29/2020	80	7000 Block of Arapahoe St	3.51
10/29/2020	38	7500 Block of Annemasse St	3.28
10/29/2020	37	6500 Block of Brockhampton St	3.24
10/29/2020	43	200 Block of Caribbean Dr	2.70
10/29/2020	96	14900 Block of Windward Dr	2.84
10/29/2020	97	13900 Block of Skysail St	3.16
10/30/2020	80	7000 Block of Arapahoe St	3.44
10/30/2020	88	4200 Block of Western Dr	3.87
10/30/2020	29	1600 Block of La Joya St	3.46
10/30/2020	58	4800 Block of French Dr	3.31
10/30/2020	4	14200 Block of Playa del Rey	2.81
10/31/2020	93	11000 Block of Annville Rd	4.09
10/31/2020	25	4100 Block of Bascule Dr	3.26

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
10/31/2020	38	7500 Block of Annemasse St	3.32
10/31/2020	98	15800 Block of Almeria Ave	2.55

November

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/1/2020	86	14800 Block of Santa Gertrudis Dr	3.65
11/1/2020	26	200 Block of Eastgate Dr	3.32
11/1/2020	8	1100 Block of Cornerstone Dr	3.05
11/1/2020	97	13900 Block of Skysail St	1.99
11/2/2020	77	5000 Block of Cape Ann Dr	3.16
11/2/2020	86	14800 Block of Santa Gertrudis Dr	3.78
11/2/2020	85	300 Block of Glenmore St	3.05
11/2/2020	29	1600 Block of La Joya St	3.64
11/2/2020	76	1100 Block of Harbor Lights Dr	3.17
11/2/2020	65	700 Block of Westchester Dr	3.48
11/2/2020	40	9500 Block of Quetzal St	2.96
11/2/2020	83	4100 Block of Summit Dr	2.49
11/2/2020	23	5500 Block of Wooldridge Rd	3.66
11/2/2020	3	3000 Block of S Fork Dr	3.86
11/2/2020	13	1500 Block of 6th St	3.43
11/2/2020	4	14200 Block of Playa del Rey	2.43
11/2/2020	52	200 Block of Junior Beck Dr	3.61
11/3/2020	15	6100 Block of Parkway Dr	3.74
11/3/2020	70	1600 Block of E Manor Dr	3.34
11/3/2020	8	1100 Block of Cornerstone Dr	3.03
11/3/2020	87	5200 Block of Northwest Trl	3.78

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/3/2020	26	200 Block of Eastgate Dr	3.60
11/3/2020	96	14900 Block of Windward Dr	3.01
11/3/2020	61	200 Block of Saratoga Blvd	3.96
11/3/2020	73	5600 Block of King Acres Dr	4.11
11/4/2020	55	500 Block of Belden St	3.51
11/4/2020	16	4200 Block of Wildcat Dr	3.82
11/4/2020	77	5000 Block of Cape Ann Dr	3.35
11/4/2020	59	3600 Block of Capri Dr	3.65
11/4/2020	85	300 Block of Glenmore St	3.22
11/4/2020	62	5800 Block of Hampshire Rd	3.45
11/4/2020	39	5900 Block of Long Creek Dr	3.76
11/4/2020	58	4800 Block of French Dr	3.59
11/4/2020	76	1100 Block of Harbor Lights Dr	3.51
11/4/2020	1	4800 Block of Neptune St	3.80
11/4/2020	24	2300 Block of Rodd Field Rd	3.75
11/4/2020	98	15800 Block of Almeria Ave	2.48
11/4/2020	40	9500 Block of Quetzal St	3.29
11/4/2020	18	900 Block of Nueces Bay Blvd	3.64
11/4/2020	95	15800 Block of El Socorro Loop	2.85
11/4/2020	83	4100 Block of Summit Dr	3.36
11/4/2020	94	15200 Block of Caravel Dr	2.80
11/5/2020	90	11700 Block of Haven Dr	3.10
11/5/2020	47	8100 Block of Barrogate Dr	3.66
11/5/2020	50	5500 Block of IH 37 Access Rd	3.70
11/5/2020	14	900 Block of Rosedale Dr	3.53
11/5/2020	68	5300 Block of Alejandro St	3.59
11/5/2020	71	5500 Block of Fox Run Dr	3.59

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/5/2020	69	4000 Block of Donaho Dr	3.78
11/5/2020	91	2700 Block of Wind Rock Dr	3.53
11/5/2020	78	7600 Block of Timber Crest Dr	3.52
11/5/2020	36	1300 Block of Sandstone Dr	3.37
11/5/2020	64	4000 Block of Hidalgo St	3.52
11/5/2020	45	15200 Block of Cruiser St	2.72
11/5/2020	74	7900 Block of Impala Dr	3.42
11/5/2020	66	600 Block of Southern St	3.34
11/5/2020	98	15800 Block of Almeria Ave	2.68
11/6/2020	91	2700 Block of Wind Rock Dr	3.49
11/6/2020	49	100 Block of Commerce St	3.80
11/6/2020	9	1000 Block of International Dr	3.57
11/6/2020	28	1700 Block of Bois d' Arc Pl	3.65
11/6/2020	32	4900 Block of Hakel Dr	3.65
11/6/2020	21	900 Block of Lum Ave	3.55
11/6/2020	42	700 Block of Orleans Dr	3.31
11/6/2020	45	15200 Block of Cruiser St	2.94
11/7/2020	16	4200 Block of Wildcat Dr	3.86
11/7/2020	14	900 Block of Rosedale Dr	3.39
11/7/2020	99	3900 Block of Elvis Dr	3.10
11/7/2020	96	14900 Block of Windward Dr	3.28
11/8/2020	87	5200 Block of Northwest Trl	3.84
11/8/2020	55	500 Block of Belden St	3.38
11/8/2020	82	2100 Block of Whispering Oak Dr	3.48
11/8/2020	95	15800 Block of El Socorro Loop	2.68
11/9/2020	90	11700 Block of Haven Dr	3.31
11/9/2020	56	200 Block of Amistad St	3.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/9/2020	30	3100 Block of Brawner Pkwy	3.13
11/9/2020	89	3800 Block of Castle Ridge Dr	3.20
11/9/2020	59	3600 Block of Capri Dr	3.53
11/9/2020	27	2800 Block of S Port Ave	3.59
11/9/2020	6	1200 Block of 10th St	3.61
11/9/2020	77	5000 Block of Cape Ann Dr	3.13
11/9/2020	20	3900 Block of Cott St	3.56
11/9/2020	7	600 Block of Carmel Pkwy	3.31
11/9/2020	85	300 Block of Glenmore St	3.09
11/9/2020	22	6700 Block of Weber Rd	3.65
11/9/2020	79	900 Block of Egyptian Dr	3.35
11/9/2020	99	3900 Block of Elvis Dr	3.08
11/9/2020	76	1100 Block of Harbor Lights Dr	3.45
11/9/2020	84	3600 Block of Flour Bluff Dr	3.65
11/9/2020	82	2100 Block of Whispering Oak Dr	3.62
11/9/2020	40	9500 Block of Quetzal St	3.12
11/9/2020	4	14200 Block of Playa del Rey	3.52
11/9/2020	98	15800 Block of Almeria Ave	3.10
11/9/2020	83	4100 Block of Summit Dr	2.88
11/10/2020	93	11000 Block of Annville Rd	4.01
11/10/2020	51	200 Block of Gibson Ln	3.82
11/10/2020	54	3700 Block of Seagull Blvd	3.28
11/10/2020	12	2200 Block of Buford Ave	3.80
11/10/2020	31	4300 Block of Cedar St	3.16
11/10/2020	60	1300 Block of Calle San Marcos	3.32
11/10/2020	11	500 Block of Military Dr	2.89
11/10/2020	97	13900 Block of Skysail St	3.75

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/11/2020	90	11700 Block of Haven Dr	3.15
11/11/2020	46	8900 Block of McNorton Rd	3.56
11/11/2020	47	8100 Block of Barrogate Dr	3.47
11/11/2020	50	5500 Block of IH 37 Access Rd	3.59
11/11/2020	57	1400 Block of Arlington Dr	3.25
11/11/2020	14	900 Block of Rosedale Dr	3.52
11/11/2020	10	3100 Block of Saratoga Blvd	3.56
11/11/2020	77	5000 Block of Cape Ann Dr	3.14
11/11/2020	68	5300 Block of Alejandro St	3.60
11/11/2020	34	4300 Block of Harry St	3.39
11/11/2020	85	300 Block of Glenmore St	2.99
11/11/2020	71	5500 Block of Fox Run Dr	3.51
11/11/2020	76	1100 Block of Harbor Lights Dr	3.35
11/11/2020	37	6500 Block of Brockhampton St	3.40
11/11/2020	40	9500 Block of Quetzal St	3.13
11/11/2020	36	1300 Block of Sandstone Dr	3.26
11/11/2020	43	200 Block of Caribbean Dr	3.46
11/11/2020	83	4100 Block of Summit Dr	2.82
11/11/2020	97	13900 Block of Skysail St	3.49
11/11/2020	45	15200 Block of Cruiser St	3.62
11/12/2020	44	9600 Block of Wilkins Dr	3.70
11/12/2020	48	1200 Block of Southern Minerals Rd	3.73
11/12/2020	25	4100 Block of Bascule Dr	3.53
11/12/2020	33	3900 Block of Ocean Dr	3.28
11/12/2020	2	5800 Block of St. Andrews Dr	3.57
11/12/2020	72	7700 Block of Starnberg Lake Dr	3.79
11/12/2020	95	15800 Block of El Socorro Loop	2.44

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/13/2020	86	14800 Block of Santa Gertrudis Dr	3.65
11/13/2020	65	700 Block of Westchester Dr	3.46
11/13/2020	13	1500 Block of 6th St	3.50
11/13/2020	52	200 Block of Junior Beck Dr	3.35
11/13/2020	29	1600 Block of La Joya St	3.56
11/13/2020	23	5500 Block of Wooldridge Rd	3.57
11/13/2020	3	3000 Block of S Fork Dr	3.59
11/13/2020	4	14200 Block of Playa del Rey	3.22
11/14/2020	93	11000 Block of Annville Rd	3.81
11/14/2020	25	4100 Block of Bascule Dr	3.16
11/14/2020	38	7500 Block of Annemasse St	3.56
11/14/2020	98	15800 Block of Almeria Ave	2.51
11/15/2020	97	13900 Block of Skysail St	2.93
11/15/2020	8	1100 Block of Cornerstone Dr	2.83
11/15/2020	26	200 Block of Eastgate Dr	3.21
11/15/2020	86	14800 Block of Santa Gertrudis Dr	3.65
11/16/2020	91	2700 Block of Wind Rock Dr	3.86
11/16/2020	64	4000 Block of Hidalgo St	3.81
11/16/2020	66	600 Block of Southern St	3.33
11/16/2020	69	4000 Block of Donaho Dr	3.66
11/16/2020	77	5000 Block of Cape Ann Dr	2.84
11/16/2020	85	300 Block of Glenmore St	2.70
11/16/2020	78	7600 Block of Timber Crest Dr	3.42
11/16/2020	76	1100 Block of Harbor Lights Dr	2.94
11/16/2020	74	7900 Block of Impala Dr	3.08
11/16/2020	40	9500 Block of Quetzal St	2.69
11/16/2020	83	4100 Block of Summit Dr	2.40

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/16/2020	98	15800 Block of Almeria Ave	2.43
11/17/2020	46	8900 Block of McNorton Rd	3.59
11/17/2020	57	1400 Block of Arlington Dr	3.54
11/17/2020	10	3100 Block of Saratoga Blvd	3.56
11/17/2020	34	4300 Block of Harry St	3.44
11/17/2020	37	6500 Block of Brockhampton St	3.54
11/17/2020	43	200 Block of Caribbean Dr	3.13
11/17/2020	97	13900 Block of Skysail St	3.28
11/17/2020	97	13900 Block of Skysail St	3.16
11/18/2020	91	2700 Block of Wind Rock Dr	4.01
11/18/2020	49	100 Block of Commerce St	3.85
11/18/2020	88	4200 Block of Western Dr	4.11
11/18/2020	53	9100 Block of Stock Dr	3.60
11/18/2020	67	500 Block of S Carancahua St	3.63
11/18/2020	9	1000 Block of International Dr	3.76
11/18/2020	28	1700 Block of Bois d' Arc Pl	3.67
11/18/2020	77	5000 Block of Cape Ann Dr	3.12
11/18/2020	5	4600 Block of Evelyn St	3.13
11/18/2020	85	300 Block of Glenmore St	3.00
11/18/2020	32	4900 Block of Hakel Dr	3.59
11/18/2020	81	6600 Block of Meadowheights Dr	3.71
11/18/2020	76	1100 Block of Harbor Lights Dr	3.24
11/18/2020	75	2900 Block of Oso Pkwy	3.28
11/18/2020	21	900 Block of Lum Ave	3.34
11/18/2020	40	9500 Block of Quetzal St	3.11
11/18/2020	41	1600 Block of Amber Dr	2.98
11/18/2020	42	700 Block of Orleans Dr	3.14

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/18/2020	83	4100 Block of Summit Dr	2.67
11/18/2020	94	15200 Block of Caravel Dr	2.31
11/18/2020	45	15200 Block of Cruiser St	2.21
11/19/2020	92	300 Block of Wildwood Dr	3.89
11/19/2020	19	1300 Block of Horne Rd	3.36
11/19/2020	89	3800 Block of Castle Ridge Dr	3.29
11/19/2020	27	2800 Block of S Port Ave	3.78
11/19/2020	58	4800 Block of French Dr	3.43
11/19/2020	6	1200 Block of 10th St	3.57
11/19/2020	35	4700 Block of Congressional Dr	3.67
11/19/2020	20	3900 Block of Cott St	3.67
11/19/2020	80	7000 Block of Arapahoe St	3.66
11/19/2020	22	6700 Block of Weber Rd	3.73
11/19/2020	38	7500 Block of Annemasse St	3.39
11/19/2020	99	3900 Block of Elvis Dr	3.07
11/19/2020	84	3600 Block of Flour Bluff Dr	3.69
11/19/2020	96	14900 Block of Windward Dr	1.93
11/19/2020	4	14200 Block of Playa del Rey	1.84
11/20/2020	44	9600 Block of Wilkins Dr	4.07
11/20/2020	48	1200 Block of Southern Minerals Rd	3.93
11/20/2020	25	4100 Block of Bascule Dr	3.60
11/20/2020	33	3900 Block of Ocean Dr	3.54
11/20/2020	2	5800 Block of St. Andrews Dr	3.54
11/20/2020	72	7700 Block of Starnberg Lake Dr	3.76
11/20/2020	95	15800 Block of El Socorro Loop	2.73
11/21/2020	96	14900 Block of Windward Dr	2.33
11/21/2020	99	3900 Block of Elvis Dr	3.24

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/21/2020	14	900 Block of Rosedale Dr	3.45
11/21/2020	16	4200 Block of Wildcat Dr	4.17
11/22/2020	87	5200 Block of Northwest Trl	4.07
11/22/2020	55	500 Block of Belden St	3.51
11/22/2020	82	2100 Block of Whispering Oak Dr	3.52
11/22/2020	95	15800 Block of El Socorro Loop	2.68
11/23/2020	88	4200 Block of Western Dr	3.86
11/23/2020	53	9100 Block of Stock Dr	3.38
11/23/2020	67	500 Block of S Carancahua St	3.43
11/23/2020	5	4600 Block of Evelyn St	3.16
11/23/2020	77	5000 Block of Cape Ann Dr	3.24
11/23/2020	81	6600 Block of Meadowheights Dr	3.54
11/23/2020	85	300 Block of Glenmore St	3.22
11/23/2020	75	2900 Block of Oso Pkwy	3.33
11/23/2020	76	1100 Block of Harbor Lights Dr	3.36
11/23/2020	41	1600 Block of Amber Dr	3.15
11/23/2020	40	9500 Block of Quetzal St	3.27
11/23/2020	94	15200 Block of Caravel Dr	2.93
11/23/2020	83	4100 Block of Summit Dr	3.10
11/24/2020	93	11000 Block of Annville Rd	4.13
11/24/2020	51	200 Block of Gibson Ln	4.05
11/24/2020	87	5200 Block of Northwest Trl	3.92
11/24/2020	12	2200 Block of Buford Ave	3.80
11/24/2020	26	200 Block of Eastgate Dr	3.55
11/24/2020	54	3700 Block of Seagull Blvd	3.18
11/24/2020	61	200 Block of Saratoga Blvd	4.04
11/24/2020	31	4300 Block of Cedar St	3.30

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/24/2020	73	5600 Block of King Acres Dr	4.12
11/24/2020	60	1300 Block of Calle San Marcos	3.39
11/24/2020	15	6100 Block of Parkway Dr	3.58
11/24/2020	70	1600 Block of E Manor Dr	3.29
11/24/2020	11	500 Block of Military Dr	2.75
11/24/2020	8	1100 Block of Cornerstone Dr	3.39
11/24/2020	97	13900 Block of Skysail St	3.33
11/24/2020	96	14900 Block of Windward Dr	2.76
11/25/2020	7	600 Block of Carmel Pkwy	3.38
11/25/2020	1	4800 Block of Neptune St	NA
11/25/2020	16	4200 Block of Wildcat Dr	4.08
11/25/2020	62	5800 Block of Hampshire Rd	3.42
11/25/2020	1	4800 Block of Neptune St	3.87
11/25/2020	18	900 Block of Nueces Bay Blvd	3.64
11/25/2020	30	3100 Block of Brawner Pkwy	3.31
11/25/2020	55	500 Block of Belden St	3.51
11/25/2020	79	900 Block of Egyptian Dr	3.41
11/25/2020	39	5900 Block of Long Creek Dr	3.76
11/25/2020	82	2100 Block of Whispering Oak Dr	3.62
11/25/2020	77	5000 Block of Cape Ann Dr	3.27
11/25/2020	24	2300 Block of Rodd Field Rd	3.11
11/25/2020	85	300 Block of Glenmore St	3.24
11/25/2020	76	1100 Block of Harbor Lights Dr	3.32
11/25/2020	94	15200 Block of Caravel Dr	3.02
11/25/2020	40	9500 Block of Quetzal St	3.23
11/25/2020	83	4100 Block of Summit Dr	3.01
11/26/2020	90	11700 Block of Haven Dr	3.44

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
11/26/2020	56	200 Block of Amistad St	3.42
11/26/2020	59	3600 Block of Capri Dr	3.54
11/26/2020	98	15800 Block of Almeria Ave	2.88
11/27/2020	92	300 Block of Wildwood Dr	3.84
11/27/2020	19	1300 Block of Horne Rd	3.66
11/27/2020	58	4800 Block of French Dr	3.48
11/27/2020	35	4700 Block of Congressional Dr	3.86
11/27/2020	80	7000 Block of Arapahoe St	3.70
11/27/2020	38	7500 Block of Annemasse St	3.55
11/27/2020	96	14900 Block of Windward Dr	3.09
11/28/2020	93	11000 Block of Annville Rd	3.94
11/28/2020	25	4100 Block of Bascule Dr	3.56
11/28/2020	38	7500 Block of Annemasse St	3.54
11/28/2020	98	15800 Block of Almeria Ave	2.98
11/29/2020	86	14800 Block of Santa Gertrudis Dr	3.68
11/29/2020	26	200 Block of Eastgate Dr	3.41
11/29/2020	8	1100 Block of Cornerstone Dr	3.41
11/29/2020	97	13900 Block of Skysail St	3.41
11/30/2020	88	4200 Block of Western Dr	3.78
11/30/2020	29	1600 Block of La Joya St	3.56
11/30/2020	58	4800 Block of French Dr	3.39
11/30/2020	4	14200 Block of Playa del Rey	3.20
11/30/2020	77	5000 Block of Cape Ann Dr	3.02
11/30/2020	85	300 Block of Glenmore St	2.92
11/30/2020	76	1100 Block of Harbor Lights Dr	3.08
11/30/2020	40	9500 Block of Quetzal St	3.02
11/30/2020	83	4100 Block of Summit Dr	2.90

December

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/1/2020	93	11000 Block of Annville Rd	4.28
12/1/2020	59	3600 Block of Capri Dr	3.67
12/1/2020	58	4800 Block of French Dr	3.37
12/1/2020	51	200 Block of Gibson Ln	4.06
12/1/2020	12	2200 Block of Buford Ave	3.80
12/1/2020	98	15800 Block of Almeria Ave	3.05
12/1/2020	95	15800 Block of El Socorro Loop	2.85
12/1/2020	54	3700 Block of Seagull Blvd	3.19
12/1/2020	31	4300 Block of Cedar St	3.25
12/1/2020	60	1300 Block of Calle San Marcos	3.35
12/1/2020	40	9500 Block of Quetzal St	3.06
12/1/2020	97	13900 Block of Skysail St	3.47
12/2/2020	86	14800 Block of Santa Gertrudis Dr	3.77
12/2/2020	65	700 Block of Westchester Dr	3.91
12/2/2020	13	1500 Block of 6th St	3.42
12/2/2020	52	200 Block of Junior Beck Dr	3.92
12/2/2020	29	1600 Block of La Joya St	3.61
12/2/2020	77	5000 Block of Cape Ann Dr	3.23
12/2/2020	85	300 Block of Glenmore St	3.11
12/2/2020	76	1100 Block of Harbor Lights Dr	3.15
12/2/2020	11	500 Block of Military Dr	2.74
12/2/2020	23	5500 Block of Wooldridge Rd	3.75
12/2/2020	83	4100 Block of Summit Dr	2.97
12/2/2020	3	3000 Block of S Fork Dr	3.57

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/2/2020	4	14200 Block of Playa del Rey	3.27
12/3/2020	16	4200 Block of Wildcat Dr	4.12
12/3/2020	62	5800 Block of Hampshire Rd	3.62
12/3/2020	87	5200 Block of Northwest Trl	3.90
12/3/2020	13	1500 Block of 6th St	3.46
12/3/2020	1	4800 Block of Neptune St	3.98
12/3/2020	26	200 Block of Eastgate Dr	3.66
12/3/2020	18	900 Block of Nueces Bay Blvd	3.74
12/3/2020	73	5600 Block of King Acres Dr	4.08
12/3/2020	55	500 Block of Belden St	3.70
12/3/2020	61	200 Block of Saratoga Blvd	4.03
12/3/2020	39	5900 Block of Long Creek Dr	3.86
12/3/2020	15	6100 Block of Parkway Dr	3.86
12/3/2020	70	1600 Block of E Manor Dr	3.55
12/3/2020	24	2300 Block of Rodd Field Rd	3.67
12/3/2020	8	1100 Block of Cornerstone Dr	3.34
12/3/2020	96	14900 Block of Windward Dr	3.13
12/3/2020	94	15200 Block of Caravel Dr	3.01
12/4/2020	91	2700 Block of Wind Rock Dr	3.79
12/4/2020	64	4000 Block of Hidalgo St	3.99
12/4/2020	66	600 Block of Southern St	2.97
12/4/2020	69	4000 Block of Donaho Dr	3.86
12/4/2020	78	7600 Block of Timber Crest Dr	3.66
12/4/2020	74	7900 Block of Impala Dr	3.62
12/4/2020	98	15800 Block of Almeria Ave	2.99
12/5/2020	16	4200 Block of Wildcat Dr	4.29
12/5/2020	14	900 Block of Rosedale Dr	3.72

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/5/2020	99	3900 Block of Elvis Dr	3.49
12/5/2020	96	14900 Block of Windward Dr	3.56
12/6/2020	87	5200 Block of Northwest Trl	3.94
12/6/2020	55	500 Block of Belden St	3.75
12/6/2020	82	2100 Block of Whispering Oak Dr	3.80
12/6/2020	95	15800 Block of El Socorro Loop	3.02
12/7/2020	92	300 Block of Wildwood Dr	4.09
12/7/2020	19	1300 Block of Horne Rd	3.79
12/7/2020	58	4800 Block of French Dr	3.73
12/7/2020	35	4700 Block of Congressional Dr	3.96
12/7/2020	77	5000 Block of Cape Ann Dr	3.54
12/7/2020	80	7000 Block of Arapahoe St	3.88
12/7/2020	85	300 Block of Glenmore St	3.40
12/7/2020	38	7500 Block of Annemasse St	3.65
12/7/2020	76	1100 Block of Harbor Lights Dr	3.56
12/7/2020	11	500 Block of Military Dr	3.15
12/7/2020	96	14900 Block of Windward Dr	3.51
12/7/2020	83	4100 Block of Summit Dr	3.27
12/8/2020	88	4200 Block of Western Dr	4.25
12/8/2020	53	9100 Block of Stock Dr	3.84
12/8/2020	67	500 Block of S Carancahua St	3.80
12/8/2020	5	4600 Block of Evelyn St	3.09
12/8/2020	81	6600 Block of Meadowheights Dr	3.83
12/8/2020	75	2900 Block of Oso Pkwy	3.35
12/8/2020	41	1600 Block of Amber Dr	3.34
12/8/2020	94	15200 Block of Caravel Dr	3.39
12/9/2020	77	5000 Block of Cape Ann Dr	3.37

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/9/2020	46	8900 Block of McNorton Rd	3.99
12/9/2020	85	300 Block of Glenmore St	3.27
12/9/2020	57	1400 Block of Arlington Dr	3.51
12/9/2020	76	1100 Block of Harbor Lights Dr	3.39
12/9/2020	37	6500 Block of Brockhampton St	3.62
12/9/2020	11	500 Block of Military Dr	3.02
12/9/2020	10	3100 Block of Saratoga Blvd	3.67
12/9/2020	43	200 Block of Caribbean Dr	3.58
12/9/2020	83	4100 Block of Summit Dr	3.27
12/9/2020	34	4300 Block of Harry St	3.64
12/9/2020	97	13900 Block of Skysail St	3.91
12/10/2020	44	9600 Block of Wilkins Dr	4.18
12/10/2020	48	1200 Block of Southern Minerals Rd	4.14
12/10/2020	25	4100 Block of Bascule Dr	3.68
12/10/2020	91	2700 Block of Wind Rock Dr	3.91
12/10/2020	33	3900 Block of Ocean Dr	3.62
12/10/2020	32	4900 Block of Hakel Dr	3.94
12/10/2020	49	100 Block of Commerce St	3.79
12/10/2020	32	4900 Block of Hakel Dr	3.94
12/10/2020	2	5800 Block of St. Andrews Dr	3.74
12/10/2020	21	900 Block of Lum Ave	3.44
12/10/2020	9	1000 Block of International Dr	3.81
12/10/2020	72	7700 Block of Starnberg Lake Dr	3.98
12/10/2020	28	1700 Block of Bois d' Arc Pl	3.80
12/10/2020	42	700 Block of Orleans Dr	3.63
12/10/2020	95	15800 Block of El Socorro Loop	3.01
12/10/2020	45	15200 Block of Cruiser St	3.84

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/11/2020	27	2800 Block of S Port Ave	3.99
12/11/2020	89	3800 Block of Castle Ridge Dr	3.70
12/11/2020	6	1200 Block of 10th St	3.99
12/11/2020	20	3900 Block of Cott St	4.01
12/11/2020	22	6700 Block of Weber Rd	3.79
12/11/2020	99	3900 Block of Elvis Dr	4.05
12/11/2020	84	3600 Block of Flour Bluff Dr	3.93
12/11/2020	4	14200 Block of Playa del Rey	3.65
12/12/2020	93	11000 Block of Annville Rd	4.10
12/12/2020	25	4100 Block of Bascule Dr	3.73
12/12/2020	38	7500 Block of Annemasse St	3.80
12/12/2020	98	15800 Block of Almeria Ave	3.27
12/13/2020	86	14800 Block of Santa Gertrudis Dr	3.80
12/13/2020	26	200 Block of Eastgate Dr	3.63
12/13/2020	8	1100 Block of Cornerstone Dr	3.65
12/13/2020	97	13900 Block of Skysail St	3.99
12/14/2020	90	11700 Block of Haven Dr	3.59
12/14/2020	56	200 Block of Amistad St	3.46
12/14/2020	77	5000 Block of Cape Ann Dr	3.28
12/14/2020	30	3100 Block of Brawner Pkwy	3.42
12/14/2020	59	3600 Block of Capri Dr	3.50
12/14/2020	85	300 Block of Glenmore St	3.26
12/14/2020	7	600 Block of Carmel Pkwy	3.49
12/14/2020	79	900 Block of Egyptian Dr	3.42
12/14/2020	76	1100 Block of Harbor Lights Dr	3.38
12/14/2020	82	2100 Block of Whispering Oak Dr	3.87
12/14/2020	11	500 Block of Military Dr	3.32

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/14/2020	98	15800 Block of Almeria Ave	3.73
12/14/2020	83	4100 Block of Summit Dr	3.36
12/15/2020	87	5200 Block of Northwest Trl	4.08
12/15/2020	26	200 Block of Eastgate Dr	3.47
12/15/2020	61	200 Block of Saratoga Blvd	3.97
12/15/2020	73	5600 Block of King Acres Dr	3.89
12/15/2020	15	6100 Block of Parkway Dr	3.68
12/15/2020	70	1600 Block of E Manor Dr	3.54
12/15/2020	8	1100 Block of Cornerstone Dr	3.60
12/15/2020	96	14900 Block of Windward Dr	3.74
12/16/2020	16	4200 Block of Wildcat Dr	4.32
12/16/2020	91	2700 Block of Wind Rock Dr	3.80
12/16/2020	64	4000 Block of Hidalgo St	3.82
12/16/2020	66	600 Block of Southern St	2.78
12/16/2020	69	4000 Block of Donaho Dr	3.82
12/16/2020	78	7600 Block of Timber Crest Dr	3.34
12/16/2020	74	7900 Block of Impala Dr	3.35
12/16/2020	98	15800 Block of Almeria Ave	3.46
12/16/2020	62	5800 Block of Hampshire Rd	3.75
12/16/2020	1	4800 Block of Neptune St	3.87
12/16/2020	77	5000 Block of Cape Ann Dr	3.32
12/16/2020	18	900 Block of Nueces Bay Blvd	3.85
12/16/2020	85	300 Block of Glenmore St	3.12
12/16/2020	76	1100 Block of Harbor Lights Dr	3.34
12/16/2020	55	500 Block of Belden St	3.73
12/16/2020	11	500 Block of Military Dr	3.07
12/16/2020	39	5900 Block of Long Creek Dr	3.75

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/16/2020	83	4100 Block of Summit Dr	3.33
12/16/2020	24	2300 Block of Rodd Field Rd	3.54
12/16/2020	94	15200 Block of Caravel Dr	3.35
12/17/2020	46	8900 Block of McNorton Rd	3.66
12/17/2020	57	1400 Block of Arlington Dr	3.35
12/17/2020	90	11700 Block of Haven Dr	3.26
12/17/2020	10	3100 Block of Saratoga Blvd	3.58
12/17/2020	47	8100 Block of Barrogate Dr	3.73
12/17/2020	50	5500 Block of IH 37 Access Rd	3.66
12/17/2020	14	900 Block of Rosedale Dr	3.65
12/17/2020	34	4300 Block of Harry St	3.52
12/17/2020	68	5300 Block of Alejandro St	3.68
12/17/2020	37	6500 Block of Brockhampton St	3.69
12/17/2020	71	5500 Block of Fox Run Dr	3.79
12/17/2020	36	1300 Block of Sandstone Dr	3.30
12/17/2020	43	200 Block of Caribbean Dr	3.44
12/17/2020	45	15200 Block of Cruiser St	3.68
12/17/2020	97	13900 Block of Skysail St	3.62
12/18/2020	88	4200 Block of Western Dr	3.94
12/18/2020	53	9100 Block of Stock Dr	3.64
12/18/2020	67	500 Block of S Carancahua St	3.59
12/18/2020	5	4600 Block of Evelyn St	3.23
12/18/2020	81	6600 Block of Meadowheights Dr	3.75
12/18/2020	75	2900 Block of Oso Pkwy	3.66
12/18/2020	41	1600 Block of Amber Dr	3.34
12/18/2020	94	15200 Block of Caravel Dr	3.40
12/19/2020	16	4200 Block of Wildcat Dr	3.80

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/19/2020	14	900 Block of Rosedale Dr	3.24
12/19/2020	99	3900 Block of Elvis Dr	3.27
12/19/2020	96	14900 Block of Windward Dr	3.41
12/20/2020	87	5200 Block of Northwest Trl	3.58
12/20/2020	55	500 Block of Belden St	3.39
12/20/2020	82	2100 Block of Whispering Oak Dr	3.38
12/20/2020	95	15800 Block of El Socorro Loop	2.96
12/21/2020	77	5000 Block of Cape Ann Dr	3.16
12/21/2020	85	300 Block of Glenmore St	3.01
12/21/2020	76	1100 Block of Harbor Lights Dr	2.96
12/21/2020	11	500 Block of Military Dr	2.75
12/21/2020	83	4100 Block of Summit Dr	2.84
12/21/2020	89	3800 Block of Castle Ridge Dr	3.23
12/21/2020	27	2800 Block of S Port Ave	3.56
12/21/2020	6	1200 Block of 10th St	3.47
12/21/2020	20	3900 Block of Cott St	3.47
12/21/2020	22	6700 Block of Weber Rd	3.61
12/21/2020	99	3900 Block of Elvis Dr	3.24
12/21/2020	84	3600 Block of Flour Bluff Dr	3.58
12/21/2020	4	14200 Block of Playa del Rey	3.64
12/22/2020	23	5500 Block of Wooldridge Rd	3.51
12/22/2020	86	14800 Block of Santa Gertrudis Dr	3.53
12/22/2020	65	700 Block of Westchester Dr	3.23
12/22/2020	13	1500 Block of 6th St	3.46
12/22/2020	52	200 Block of Junior Beck Dr	3.80
12/22/2020	29	1600 Block of La Joya St	3.62
12/22/2020	3	3000 Block of S Fork Dr	3.58

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/22/2020	4	14200 Block of Playa del Rey	3.24
12/23/2020	93	11000 Block of Annville Rd	3.79
12/23/2020	51	200 Block of Gibson Ln	3.80
12/23/2020	12	2200 Block of Buford Ave	3.78
12/23/2020	77	5000 Block of Cape Ann Dr	3.05
12/23/2020	54	3700 Block of Seagull Blvd	3.26
12/23/2020	85	300 Block of Glenmore St	2.98
12/23/2020	31	4300 Block of Cedar St	3.25
12/23/2020	76	1100 Block of Harbor Lights Dr	3.15
12/23/2020	60	1300 Block of Calle San Marcos	3.38
12/23/2020	11	500 Block of Military Dr	2.77
12/23/2020	40	9500 Block of Quetzal St	3.08
12/23/2020	97	13900 Block of Skysail St	3.39
12/23/2020	83	4100 Block of Summit Dr	2.89
12/24/2020	44	9600 Block of Wilkins Dr	3.83
12/24/2020	92	300 Block of Wildwood Dr	3.85
12/24/2020	48	1200 Block of Southern Minerals Rd	3.73
12/24/2020	25	4100 Block of Bascule Dr	3.53
12/24/2020	19	1300 Block of Horne Rd	3.45
12/24/2020	33	3900 Block of Ocean Dr	3.34
12/24/2020	58	4800 Block of French Dr	3.41
12/24/2020	2	5800 Block of St. Andrews Dr	3.36
12/24/2020	35	4700 Block of Congressional Dr	3.62
12/24/2020	72	7700 Block of Starnberg Lake Dr	3.62
12/24/2020	80	7000 Block of Arapahoe St	3.53
12/24/2020	95	15800 Block of El Socorro Loop	2.80
12/24/2020	38	7500 Block of Annemasse St	3.78

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/24/2020	96	14900 Block of Windward Dr	3.38
12/25/2020	87	5200 Block of Northwest Trl	4.01
12/25/2020	55	500 Block of Belden St	3.34
12/25/2020	8	1100 Block of Cornerstone Dr	3.58
12/25/2020	96	14900 Block of Windward Dr	3.23
12/26/2020	93	11000 Block of Annville Rd	3.93
12/26/2020	25	4100 Block of Bascule Dr	3.61
12/26/2020	38	7500 Block of Annemasse St	3.60
12/26/2020	98	15800 Block of Almeria Ave	3.09
12/27/2020	86	14800 Block of Santa Gertrudis Dr	3.38
12/27/2020	26	200 Block of Eastgate Dr	3.23
12/27/2020	8	1100 Block of Cornerstone Dr	3.46
12/27/2020	97	13900 Block of Skysail St	3.44
12/28/2020	91	2700 Block of Wind Rock Dr	3.37
12/28/2020	49	100 Block of Commerce St	3.45
12/28/2020	9	1000 Block of International Dr	3.27
12/28/2020	28	1700 Block of Bois d' Arc Pl	3.29
12/28/2020	32	4900 Block of Hakel Dr	3.28
12/28/2020	21	900 Block of Lum Ave	3.03
12/28/2020	42	700 Block of Orleans Dr	3.24
12/28/2020	45	15200 Block of Cruiser St	3.60
12/28/2020	77	5000 Block of Cape Ann Dr	2.90
12/28/2020	85	300 Block of Glenmore St	2.81
12/28/2020	76	1100 Block of Harbor Lights Dr	2.91
12/28/2020	11	500 Block of Military Dr	2.78
12/28/2020	83	4100 Block of Summit Dr	3.10
12/29/2020	90	11700 Block of Haven Dr	2.99

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
12/29/2020	56	200 Block of Amistad St	3.06
12/29/2020	30	3100 Block of Brawner Pkwy	2.98
12/29/2020	59	3600 Block of Capri Dr	3.31
12/29/2020	7	600 Block of Carmel Pkwy	3.08
12/29/2020	79	900 Block of Egyptian Dr	2.87
12/29/2020	82	2100 Block of Whispering Oak Dr	3.19
12/29/2020	98	15800 Block of Almeria Ave	3.23
12/30/2020	90	11700 Block of Haven Dr	2.92
12/30/2020	47	8100 Block of Barrogate Dr	3.56
12/30/2020	50	5500 Block of IH 37 Access Rd	3.56
12/30/2020	14	900 Block of Rosedale Dr	3.21
12/30/2020	68	5300 Block of Alejandro St	3.37
12/30/2020	71	5500 Block of Fox Run Dr	3.55
12/30/2020	36	1300 Block of Sandstone Dr	2.83
12/30/2020	45	15200 Block of Cruiser St	2.93
12/30/2020	77	5000 Block of Cape Ann Dr	3.03
12/30/2020	85	300 Block of Glenmore St	2.69
12/30/2020	76	1100 Block of Harbor Lights Dr	3.71
12/30/2020	11	500 Block of Military Dr	2.60
12/30/2020	83	4100 Block of Summit Dr	2.72
12/31/2020	88	4200 Block of Western Dr	4.01
12/31/2020	29	1600 Block of La Joya St	3.92
12/31/2020	58	4800 Block of French Dr	3.44
12/31/2020	4	14200 Block of Playa del Rey	3.27