




April 3, 2023 - April 9, 2023 Chlorine Residuals



Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/3/2023	86	14800 Block of Santa Gertrudis Dr	3.91
4/3/2023	65	700 Block of Westchester Dr	3.32
4/3/2023	13	1500 Block of 6th St	3.42
4/3/2023	52	200 Block of Junior Beck Dr	2.95
4/3/2023	29	1600 Block of La Joya St	3.69
4/3/2023	77	5000 Block of Cape Ann Dr	2.96
4/3/2023	23	5500 Block of Wooldridge Rd	3.51
4/3/2023	85	300 Block of Glenmore St	3.10
4/3/2023	3	3000 Block of S Fork Dr	3.51
4/3/2023	76	1100 Block of Harbor Lights Dr	3.06
4/3/2023	4	14200 Block of Playa del Rey	3.41
4/3/2023	11	500 Block of Military Dr	3.09
4/3/2023	83	4100 Block of Summit Dr	2.75
4/4/2023	52	200 Block of Junior Beck Dr	3.70
4/4/2023	44	9600 Block of Wilkins Dr	3.51
4/4/2023	91	2700 Block of Wind Rock Dr	3.62
4/4/2023	64	4000 Block of Hidalgo St	3.78
4/4/2023	33	3900 Block of Ocean Dr	3.27
4/4/2023	95	15800 Block of El Socorro Loop	2.64

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/4/2023	48	1200 Block of Southern Minerals Rd	3.55
4/4/2023	25	4100 Block of Bascule Dr	3.39
4/4/2023	2	5800 Block of St. Andrews Dr	3.29
4/4/2023	72	7700 Block of Starnberg Lake Dr	3.54
4/4/2023	69	4000 Block of Donaho Dr	3.69
4/4/2023	66	600 Block of Southern St	3.53
4/4/2023	78	7600 Block of Timber Crest Dr	3.42
4/4/2023	74	7900 Block of Impala Dr	3.06
4/4/2023	98	15800 Block of Almeria Ave	2.97
4/5/2023	89	3800 Block of Castle Ridge Dr	3.26
4/5/2023	27	2800 Block of S Port Ave	3.25
4/5/2023	27	2800 Block of S Port Ave	3.02
4/5/2023	6	1200 Block of 10th St	3.43
4/5/2023	20	3900 Block of Cott St	3.11
4/5/2023	4	14200 Block of Playa del Rey	3.11
4/5/2023	95	15800 Block of El Socorro Loop	2.97
4/5/2023	58	4800 Block of French Dr	3.52
4/5/2023	84	3600 Block of Flour Bluff Dr	2.38
4/5/2023	77	5000 Block of Cape Ann Dr	3.25
4/5/2023	85	300 Block of Glenmore St	3.09
4/5/2023	76	1100 Block of Harbor Lights Dr	3.01
4/5/2023	99	3900 Block of Elvis Dr	3.39
4/5/2023	22	6700 Block of Weber Rd	3.69

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/5/2023	11	500 Block of Military Dr	2.88
4/5/2023	83	4100 Block of Summit Dr	2.16
4/6/2023	40	9500 Block of Quetzal St	2.99
4/6/2023	97	13900 Block of Skysail St	3.59
4/6/2023	60	1300 Block of Calle San Marcos	3.36
4/6/2023	93	11000 Block of Annville Rd	3.89
4/6/2023	31	4300 Block of Cedar St	3.42
4/6/2023	51	200 Block of Gibson Ln	3.90
4/6/2023	54	3700 Block of Seagull Blvd	3.40
4/6/2023	12	2200 Block of Buford Ave	3.57
4/7/2023	87	5200 Block of Northwest Trl	3.83
4/7/2023	73	5600 Block of King Acres Dr	4.10
4/7/2023	61	200 Block of Saratoga Blvd	3.84
4/7/2023	26	200 Block of Eastgate Dr	3.48
4/7/2023	15	6100 Block of Parkway Dr	3.54
4/7/2023	70	1600 Block of E Manor Dr	3.38
4/7/2023	8	1100 Block of Cornerstone Dr	3.43
4/7/2023	96	14900 Block of Windward Dr	3.57
4/7/2023	16	4200 Block of Wildcat Dr	3.97
4/7/2023	86	14800 Block of Santa Gertrudis Dr	3.63
4/7/2023	87	5200 Block of Northwest Trl	3.80
4/8/2023	16	4200 Block of Wildcat Dr	4.02
4/8/2023	14	900 Block of Rosedale Dr	3.55

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/8/2023	99	3900 Block of Elvis Dr	3.18
4/8/2023	96	14900 Block of Windward Dr	3.37
4/9/2023	87	5200 Block of Northwest Trl	3.75
4/9/2023	55	500 Block of Belden St	3.29
4/9/2023	82	2100 Block of Whispering Oak Dr	3.18
4/9/2023	95	15800 Block of El Socorro Loop	2.69