



## April 6, 2020 - April 12, 2020 Chlorine Residuals

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
4/6/2020	77	5018 Cape Ann Dr.	3.00
4/6/2020	85	302 Glenmore St.	2.88
4/6/2020	76	1109 Harbor Lights Dr.	2.95
4/6/2020	89	3814 Castle Ridge Dr.	3.35
4/6/2020	40	9550 Quetzal St.	2.90
4/6/2020	27	2823 S Port Ave.	3.62
4/6/2020	22	6713 Weber Rd.	3.58
4/6/2020	83	4101 Summit Dr.	2.69
4/6/2020	6	1213 10th St.	3.16
4/6/2020	20	3901 Cott St.	3.36
4/6/2020	99	3926 Elvis Dr.	3.45
4/6/2020	84	3640 Flour Bluff Dr.	3.20
4/6/2020	4	14233 Playa del Rey	3.18
4/7/2020	45	15222 Cruiser St.	2.74
4/7/2020	42	753 Orleans Dr.	3.11
4/7/2020	91	2713 Wind Rock Dr.	3.62
4/7/2020	49	113 Commerce St.	3.36

<b>Date Sampled</b>	<b>Site #</b>	<b>Address</b>	<b>Total Chlorine Residual (mg/L)</b>
4/7/2020	21	913 Lum Ave.	3.22
4/7/2020	9	1000 International Dr.	3.43
4/7/2020	32	4901 Haket Dr.	3.51
4/7/2020	28	1718 Bois d' Arc Pl.	3.67
4/8/2020	16	4205 Wildcat Dr.	3.84
4/8/2020	62	5809 Hampshire Rd.	3.78
4/8/2020	1	4810 Neptune St.	3.73
4/8/2020	18	902 Nueces Bay Blvd.	3.54
4/8/2020	77	5018 Cape Ann Dr.	2.96
4/8/2020	55	514 Belden St.	3.55
4/8/2020	7	617 Carmel Pkwy.	3.32
4/8/2020	85	302 Glenmore St.	2.85
4/8/2020	90	11722 Haven Dr.	3.77
4/8/2020	79	905 Egyptian Dr.	3.04
4/8/2020	39	5929 Long Creek Dr.	3.51
4/8/2020	76	1109 Harbor Lights Dr.	3.01
4/8/2020	40	9550 Quetzal St.	2.87
4/8/2020	82	2101 Whispering Oak Dr.	3.01
4/8/2020	24	2342 Rodd Field Rd.	3.68
4/8/2020	56	202 Amistad St.	3.30
4/8/2020	83	4101 Summit Dr.	2.67

<b>Date Sampled</b>	<b>Site #</b>	<b>Address</b>	<b>Total Chlorine Residual (mg/L)</b>
4/8/2020	98	15806 Almeria Ave.	2.81
4/8/2020	94	15209 Caravel Dr.	3.00
4/8/2020	30	3100 Brawner Pkwy.	3.05
4/8/2020	59	3633 Capri Dr.	3.65
4/9/2020	98	15806 Almeria Ave.	2.75
4/9/2020	74	7910 Impala Dr.	3.32
4/9/2020	93	11025 Annville Rd.	4.04
4/9/2020	31	4306 Cedar St.	3.13
4/9/2020	78	7602 Timber Crest Dr.	3.34
4/9/2020	51	249 Gibson Ln.	3.71
4/9/2020	69	4013 Donaho Dr.	3.68
4/9/2020	60	1346 Calle San Marcos	3.09
4/9/2020	12	2219 Buford Ave.	3.71
4/9/2020	66	635 Southern St.	3.77
4/9/2020	54	3710 Seagull Blvd.	3.29
4/9/2020	11	534 Military Dr.	2.70
4/9/2020	64	4013 Hidalgo St.	3.74
4/9/2020	97	13902 Skysail St.	3.19
4/9/2020	91	2713 Wind Rock Dr.	3.87
4/10/2020	92	334 Wildwood Dr.	3.97
4/10/2020	19	1301 Horne Rd.	3.44

<b>Date Sampled</b>	<b>Site #</b>	<b>Address</b>	<b>Total Chlorine Residual (mg/L)</b>
4/10/2020	58	4801 French Dr.	3.15
4/10/2020	35	4702 Congressional Dr.	3.51
4/10/2020	80	7042 Arapahoe St.	3.46
4/10/2020	38	7525 Annemasse St.	3.52
4/10/2020	96	14926 Windward Dr.	3.24
4/11/2020	93	11025 Annville Rd.	3.99
4/11/2020	38	7525 Annemasse St.	3.41
4/11/2020	25	4101 Bascule Dr.	3.47
4/11/2020	98	15806 Almeria Ave.	2.88
4/12/2020	86	14814 Santa Gertrudis Dr.	3.29
4/12/2020	26	225 Eastgate Dr.	3.46
4/12/2020	8	1126 Cornerstone Dr.	3.40
4/12/2020	97	13902 Skysail St.	3.30