



August 31 - September 6, 2020 Chlorine Residuals

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
8/31/2020	77	5000 Block of Cape Ann Dr	2.51
8/31/2020	85	300 Block of Glenmore St	2.53
8/31/2020	88	4200 Block of Western Dr	3.68
8/31/2020	76	1100 Block of Harbor Lights Dr	2.56
8/31/2020	29	1600 Block of La Joya St	2.97
8/31/2020	40	9500 Block of Quetzal St	2.32
8/31/2020	58	4800 Block of French Dr	2.87
8/31/2020	83	4100 Block of Summit Dr	2.31
8/31/2020	4	14200 Block of Playa del Rey	2.70
9/1/2020	88	4200 Block of Western Dr	3.40
9/1/2020	53	9100 Block of Stock Dr	2.51
9/1/2020	67	500 Block of S Carancahua St	2.74
9/1/2020	5	4600 Block of Evelyn St	2.48
9/1/2020	81	6600 Block of Meadowheights Dr	2.51
9/1/2020	75	2900 Block of Oso Pkwy	2.41
9/1/2020	41	1600 Block of Amber Dr	2.29
9/1/2020	94	15200 Block of Caravel Dr	2.42

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/2/2020	89	3800 Block of Castle Ridge Dr	2.80
9/2/2020	27	2800 Block of S Port Ave	3.04
9/2/2020	91	2700 Block of Wind Rock Dr	2.90
9/2/2020	49	100 Block of Commerce St	2.94
9/2/2020	6	1200 Block of 10th St	2.83
9/2/2020	9	1000 Block of International Dr	2.83
9/2/2020	20	3900 Block of Cott St	2.80
9/2/2020	28	1700 Block of Bois d' Arc Pl	2.97
9/2/2020	77	5000 Block of Cape Ann Dr	2.30
9/2/2020	22	6700 Block of Weber Rd	2.95
9/2/2020	32	4900 Block of Hakel Dr	2.76
9/2/2020	59	3600 Block of Capri Dr	2.66
9/2/2020	85	300 Block of Glenmore St	2.29
9/2/2020	21	900 Block of Lum Ave	2.45
9/2/2020	99	3900 Block of Elvis Dr	2.39
9/2/2020	58	4800 Block of French Dr	2.63
9/2/2020	76	1100 Block of Harbor Lights Dr	2.29
9/2/2020	42	700 Block of Orleans Dr	2.46
9/2/2020	84	3600 Block of Flour Bluff Dr	2.66
9/2/2020	40	9500 Block of Quetzal St	2.20
9/2/2020	98	15800 Block of Almeria Ave	2.10

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/2/2020	45	15200 Block of Cruiser St	2.78
9/2/2020	95	15800 Block of El Socorro Loop	2.09
9/2/2020	83	4100 Block of Summit Dr	2.12
9/2/2020	4	14200 Block of Playa del Rey	2.71
9/3/2020	90	11700 Block of Haven Dr	2.91
9/3/2020	56	200 Block of Amistad St	2.59
9/3/2020	93	11000 Block of Annville Rd	3.65
9/3/2020	30	3100 Block of Brawner Pkwy	2.50
9/3/2020	51	200 Block of Gibson Ln	2.96
9/3/2020	59	3600 Block of Capri Dr	2.44
9/3/2020	12	2200 Block of Buford Ave	2.83
9/3/2020	54	3700 Block of Seagull Blvd	2.36
9/3/2020	7	600 Block of Carmel Pkwy	2.52
9/3/2020	31	4300 Block of Cedar St	2.65
9/3/2020	79	900 Block of Egyptian Dr	2.33
9/3/2020	60	1300 Block of Calle San Marcos	2.41
9/3/2020	11	500 Block of Military Dr	2.04
9/3/2020	82	2100 Block of Whispering Oak Dr	2.36
9/3/2020	97	13900 Block of Skysail St	2.69
9/3/2020	98	15800 Block of Almeria Ave	2.06
9/4/2020	90	11700 Block of Haven Dr	3.13

Date Sampled	Site #	Address	Total Chlorine Residual (mg/L)
9/4/2020	47	8100 Block of Barrogate Dr	3.52
9/4/2020	50	5500 Block of IH 37 Access Rd	3.33
9/4/2020	14	900 Block of Rosedale Dr	2.86
9/4/2020	68	5300 Block of Alejandro St	2.62
9/4/2020	71	5500 Block of Fox Run Dr	2.69
9/4/2020	36	1300 Block of Sandstone Dr	2.35
9/4/2020	45	15200 Block of Cruiser St	2.58
9/5/2020	99	3900 Block of Elvis Dr	2.43
9/5/2020	96	14900 Block of Windward Dr	2.07
9/5/2020	14	900 Block of Rosedale Dr	2.57
9/5/2020	16	4200 Block of Wildcat Dr	3.21
9/6/2020	82	2100 Block of Whispering Oak Dr	2.63
9/6/2020	95	15800 Block of El Socorro Loop	1.76
9/6/2020	55	500 Block of Belden St	2.64
9/6/2020	87	5200 Block of Northwest Trl	3.12